

Till now the maximum generation is :-				7356 MW	20:00	Hrs on 30-Mar-14	Reporting Date : 22-Jun-14		
The Summary of Yesterday's ( 21-Jun-14				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	4602.0	MW	Hour :	12:00	Min. Gen. at 7:00	3773	MW		
Evening Peak Generation :	6336.0	MW	Hour :	21:00	Max Generation :	6846	MW		
E.P. Demand (at gen end) :	6336.0	MW	Hour :	21:00	Max Demand :	6800	MW		
Maximum Generation :	6486.0	MW	Hour :	22:00	Shortage :	-46	MW		
Total Gen. (MKWH) :	121.2	System L/ Factor :		78.37%	Load Shed :	0	MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum			-110	MW at 10:00	Energy	7.867	MKWHR.		
Import from West grid to East grid :- Maximum			-	MW at -	Energy	-	MKWHR.		
Actual : 87.64		Water Level of Kaptai Lake at 6:00 A M on 22-Jun-14		Rule curve : 81.57		Ft.( MSL )			
Gas Consumed : Total		870.47		MMCFD.		Oil Consumed (PDB) :			
						HSD :	Liter		
						FO :	Liter		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk72,883,098						
		Coal :	Tk16,288,654		Oil :	Tk193,905,155		Total : Tk283,076,908	
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand(s/s end)		Today		Rates of Shedding		
	MW		MW		Estimated Shedding (s/s end)		(On Estimated Demand)		
Dhaka	-	0.00	2416		-		-		
Chittagong Area	-	0.00	621		-		-		
Khulna Area	-	0.00	679		-		-		
Rajshahi Area	-	0.00	658		-		-		
Comilla Area	-	0.00	453		-		-		
Mymensingh Area	-	0.00	374		-		-		
Sylhet Area	-	0.00	305		-		-		
Barisal Area	-	0.00	135		-		-		
Rangpur Area	-	0.00	383		-		-		
Total	0		6024		0				
Information of the Generating machines under shut down.									
Planned Shut- Down			Forced Shut- Down						
1) Haripur SBU GT-3 (18/06/09)			1) Ghorasal #6 (18/07/10)			9) Khulna 110 MW (15/05/2014)			
			2) Khulna-60MW (24/1/12)			10) Ghorasal #4(16/6/2014)			
			3) Shahjibazar #5 & 6 (21/7/11)			11) Santahar 50 MW (20/06/2014)			
			4) WMPL #1(1/5/12)			12) Khulna 150 MW (20/06/2014)			
			5) WMPL #2(24/4/13)						
			6) Ashuganj GT-1(CCPP) (06/01/14)						
			7) Meghnaghat 450MW (21/04/2014)						
			8) Ghorasal #3 (08/05/2014)						
Additional Information of Machines. lines. Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Due to rain and storm less system demand observed yesterday.									
b) Mirpur 132 kV capacitor bank was shut down from 10:15 to 13:35 due to cleaning work.									
c) Palashbari 132/33 kV T3 transformer was shut down at 11:20 due to replacement work.									
d) Comilla (S) 132/33 kV T1 transformer was shut down from 12:33 to 20:32 for testing work.									
e) Ishurdi 132/33 kV T2 transformer tripped at 12:59 showing earth fault relay from both end and was switched on at 13:22.									
f) HVDC Bheramara 230 kV AC filter No-11 tripped at 13:10 showing unbalance signal & normal and was switched on at 20:22.									
g) Saidpur-Purbasaidpur 132 kV Ckt-1 was shut down from 15:50 to 17:25 due to maintenance work.									
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Despatch Circle			