

Till now the maximum generation is :-		7356 MW		20:00		Hrs on 30-Mar-14		Reporting Date : 26-Jun-14	
The Summary of Yesterday's (25-Jun-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :		5828.0		MW		Hou 12:00		Min. Gen. at 8:00 4949 MW	
Evening Peak Generation :		6630.0		MW		Hou 20:00		Max Generation : 6944 MW	
E.P. Demand (at gen end) :		6800.0		MW		Hou 20:00		Max Demand : 6850 MW	
Maximum Generation :		6760.0		MW		Hou 23:00		Shortage : -94 MW	
Total Gen. (MKWH) :		136.6		System L/ Factor :		78.37%		Load Shed : 0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :-		Maximum		0		MW at 18:30		Energy 7.867 MKWHR.	
Import from West grid to East grid :-		Maximum		-		MW at -		Energy - MKWHR.	
Actual :		87.64		Ft.(MSL) ,		Rule curve :		82.65 Ft.(MSL)	
Gas Consumed : Total		865.57		MMCFD.		Oil Consumed (PDB) :		HSD : Liter FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk73,026,496		Oil :		Tk383,835,600 Total : Tk472,955,438	
Coal :		Tk16,093,342							
Load Shedding & Other Information									
Area									
Yesterday									
MW									
Estimated Demand(s/s end)									
MW									
Today									
Estimated Shedding (s/s end)									
MW									
Rates of Shedding (On Estimated Demand)									
Dhaka - 0.00 2442 - -									
Chittagong Area 28 19:05:00:30 628 - -									
Khulna Area 33 19:05:00:31 687 - -									
Rajshahi Area 30 19:05:00:32 666 - -									
Comilla Area 22 19:05:00:33 458 - -									
Mymensingh Area 17 19:05:00:34 378 - -									
Sylhet Area - 0.00 308 - -									
Barisal Area 6 19:05:00:34 137 - -									
Rangpur Area 17 19:05:00:35 386 - -									
Total 153 6090 0									
Information of the Generating machines under shut down.									
Planned Shut- Down									
Forced Shut- Down									
1) Haripur SBU GT-3 (18/06/09)									
1) Ghorasal #6 (18/07/10) 9) Khulna 110 MW (15/05/2014)									
2) Khulna-60MW (24/1/12) 10) Ghorasal #4(16/6/2014)									
3) Shahjibazar #5 & 6 (21/7/11)									
4) WMPL #1(1/5/12)									
5) WMPL #2(24/13)									
6) Ashuganj GT-1(CCPP) (06/01/14)									
7) Meghnaghat 450MW (21/04/2014)									
8) Ghorasal #3 (08/05/2014)									
Additional Information of Machines. lines. Interruption / Forced Load shed etc.									
Description									
Forced load shaded / Interrupted Areas									
a) There was generation shortage in the evening peak hour yesterday.									
So about 153 MW load shed was imposed									
b) Ishurdi 132/33 kV T1 transformer was shut down from 10:30 to 11:40 due to red hot maintenance work at 33 kV end.									
c) Meghnaghat 230 kV bus-1 was shut down from 10:34 to 20:38 due to project work.									
d) Saidpur-Purbasadipur 132 kV Ckt-1 was shut down from 12:01 to 12:43 due to red hot maintenance work at 132 kV end.									
e) Chowmohani 132/33 kV T3 transformer was shut down from 12:01 to 17:32 due to painting work.									
f) Ashuganj #1 was shut down at 12:03 due to bypass valve tube oil leakage.									
g) Tongi-Kabirpur 132 kV Ckt-1 & 2 tripped at 12:10 showing distance relay from both end and were switched on at 12:32, 12:26 respectively.									
About 115 MW power interruption occurred under Mymensingh & Manikganj S/S areas from 12:10 to 12:32.									
h) Bogra-Seraiganj 132 kV Ckt-1 tripped at 14:25 showing distance relay from Seraiganj end and was switched on at 15:07.									
i) Bogra-Seraiganj 132 kV Ckt-2 tripped at 14:23 due to lighting arrester burnt at Bogra end and was switched on at 21:40.									
j) Rajshahi 132/33 kV T1 & T3 transformers were shut down from 16:47 to 18:10 due to red hot maintenance work at 33 kV Durgapur feeder.									
About 50 MW power interruption occurred under Rajshahi S/S areas from 16:47 to 18:10.									
k) Sitalakhya-Hasnabad 132 kV Ckt tripped at 16:35 showing distance relay from both end and was switched on at 17:12. At the same time Gagonnagar power plant was also tripped and was synchronized on at 20:32.									
l) After maintenance Haripur -Meghnaghat 230kV Ckt-2 switched on at 20:56.									
m) Haripur-Meghnaghat 230 kV Ckt-2 tripped at 22:24 showing dist relay 3 phase at Haripur end and dist ABC, Z1,Z2 at Meghnaghat end and was switched on at 01:59 (26/06/2014)									
n) Beghabari 100 MW was shut down at 00:23(26/06/14) due to compressor bleed valve problem.									
o) Ashuganj-Ghorasal 230 kV Ckt-1, & 2 tripped at 07:36(26/06/14) showing ANZ1 at Ashuganj end(both Ckt) and AN-AQZ2 at Ckt-1 and AN-AQZ1 at Ckt-2 from Ghorasal end and were switched on at 08:26 and 09:25 respectively, at the same time 132 kV Ckt-2 tripped showing dist AQ relay from both end and was switched on at 08:02(26/06/2014)									
p) Ashuganj-Seraiganj 230 kV Ckt-2 tripped at 07:36(26/06/14) showing SOTF at Ashuganj end and , DTT-2 general trip at Seraiganj end at the same time Ashuganj # 5 ,TSK, midland and Shahjibazar 86 MW ,50 MW machine tripped.									
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Despatch Circle			