POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date : 17-Jul-14 Till now the maximum generation is:-7403 MW 21:00 The Summary of Yesterday's (16-Jul-14 Generation & Demand Today's Actual N Day Peak Generation MW Hour : 5150 Min. Gen. at Evening Peak Generation 7403.0 MW Hour: 21:00 Max Generation 7474 E.P. Demand (at gen end) : 7403.0 MWHour : 21:00 Max Demand 7450 Maximum Generation 7403.0 MW Hour: 21:00 Shortage -24 Total Gen. (MKWH) 148.1 System L/ Factor 78.37% Load Shed 0 EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW a 9:00 7.867 -60 Energy Import from West grid to East grid :- Maximum MW Energy Water Level of Kaptai Lake at 6:00 A M on 17-Jul-14 Ft.(MSL) Rule curve : 87.64 86.56 Ft.(MSL) Actual: 954.43 Gas Consumed: Total MMCFD. Oil Consumed (PDB): HSD : FO Cost of the Consumed Fuel (PDB+Pvt): Gas Tk91,299,638

Tk16,132,410

Load Shedding & Other Information

Coal

Area	Yesterday		Today			
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding	
	MW		MW	MW	(On Estimated Dem	
Dhaka	-	0:00	2715	-	-	
Chittagong Area	-	0:00	704	-	-	
Khulna Area	-	0:00	773	-	-	
Rajshahi Area	-	0:00	745	-	-	
Comilla Area	-	0:00	511	-	-	
Mymensingh Area	-	0:00	417	-	-	
Sylhet Area	-	0:00	339	-	-	
Barisal Area	-	0:00	150	-	-	
Rangpur Area	-	0:00	426	-	-	
i	-					
Total	0		6780	0		

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010)
	2) Megnaghat CCPP (21/04/2014)
	3) Ghorasal ST : Unit-3 (08/05/2014)
	4) Sikalbaha ST (03/07/2014)
	5) Sikalbaha Peaking GT (29/06/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Siddhirgani-Maniknagor 230 kV Ckt-1 & 2 tripped at 09:20 showing distance relay at Maniknagar end	

- and were switched on at 09:49, 09:44 respectively.
 b) Feni-Hathazari 132 kV Ckt-1 tripped at 10:55 showing distance relay from both end and was switched
- on at 11:01.
- c) After maintenance Khulna ST 110 MW was synchronized on at 13:04.
- d) After maintenance Sikalbaha-Bakulia 132 kV Ckt-1 was switched on at 01:55.
- e) Kabirpur 132/33 kV T1 & T2 transformers tripped at 20:20 due to 33 kV Tangail feeder fault and were switched on at 20:25.
- f) Fenchuganj CCPP-1 GT-1 was shut down at 23:30 due to boiler tube leakage.
- g) Hasnabad 132/33 kV T5 transformer was shut down at 07:58(17/07/2014) due to replacement of 33 kV CT.

About 60 MW power interruption occurred under Kabirpur S/S from 20:20 to 20:25.

: Tk414,860,445

Total: Tk522,292,493

Sub Divisional Engineer Executive Engineer Superintendent Engineer
Network Operation Division Network Operation Division Load Despatch Circle

MW	
MW	
MW	
MW	
N/N//	

MKWHR. MKWHR.

Liter Liter

and)

areas