

Reporting Date : 3-Aug-14

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

The Summary of Yesterday's (2-Aug-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	5091.0	MW	Hou 10:00	Min. Gen. at 7:00	4726 MW
Evening Peak Generation :	6661.0	MW	Hou 20:00	Max Generation :	7033 MW
E.P. Demand (at gen end) :	6661.0	MW	Hou 20:00	Max Demand :	6900 MW
Maximum Generation :	6661.0	MW	Hou 20:00	Shortage :	-133 MW
Total Gen. (MKWH) :	130.1	System L/ Factor :	78.37%	Load Shed :	0 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	-320	MW	at	18:30	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.

Water Level of Kaptai Lake at 6:00 A M on 3-Aug-14

Actual :	87.64	Ft.(MSL) ,	Rule curve :	89.64	Ft.(MSL)
----------	-------	------------	--------------	-------	------------

Gas Consumed : Total	953.29	MMCFD.	Oil Consumed (PDB) :	
			HSD :	Liter
			FO :	Liter

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk79,075,091		
	Coal :	Tk7,773,243	Oil :	Tk303,508,150
			Total :	Tk390,356,483

Load Shedding & Other Information

Area	Yesterday		Today		
	MW		Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0.00	2470	-	-
Chittagong Area	-	0.00	636	-	-
Khulna Area	-	0.00	696	-	-
Rajshahi Area	-	0.00	674	-	-
Comilla Area	-	0.00	463	-	-
Mymensingh Area	-	0.00	382	-	-
Sylhet Area	-	0.00	311	-	-
Barisal Area	-	0.00	138	-	-
Rangpur Area	-	0.00	390	-	-
	-				
Total	0		6160	0	

Information of the Generating machines under shut down.

	Planned Shut- Down	Forced Shut- Down
	1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sikalbaha ST (03/07/2014) 4) Sylhet 150 MW GT (28/07/14) 5) Ashuganj ST: Unit-1(27/07/14) 6) Barapukuria ST: Unit-2 (31/07/2014) 7) Fenchuganj CCPP-2 (01/08/2014) 8) Sikalbaha GT 150 MW(03/08/14)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Madaripur 132/33 kV T3 transformer was shut down from 10:27 to 12:45 due to oil leakage of 33 kV B-phase CT.	
b) Haripur-Maniknagar 132 kV Ckt was shut down from 10:30 to 12:45 due to red hot maintenance work at Haripur end.	
c) Comilla (S) 132/33 kV T4 transformer was shut down from 07:50 to 09:20(02/08/2014) due to red maintenance work at 33 kV Choddagram feeder.	About 20 MW power interruption occurred under Comilla (S) S/S areas from 07:50 to 09:20(02/08/2014).
d) Pabna 132/33 kV T1 & T2 transformers tripped at 07:43(03/08/2014) showing no relay from both were switched on at 08:10(03/08/2014).	About 47 MW power interruption occurred under Pabna S/S areas from 07:43 to 08:10(03/08/2014).

Sub Divisional Engineer
Network Operation DivisionExecutive Engineer
Network Operation DivisionSuperintendent Engineer
Load Despatch Circle