POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1 Reporting Date : 21-Aug-14 18-Jul-14 | Reporting Date : 21-Aug-14 |
| Today's Actual Min Gen. & Probable Gen. & Dec |
| Min. Gen. at | 7:00 | 5086 |
| Max Generation | : 6870 | Till now the maximum generation is:

The Summary of Yesterday's (
Day Peak Generation :
Evening Peak Generation :
E.P. Demand (at gen end) : 7418 MW 21:00 Generation & Demand
MW
MW
MW 20-Aug-14 5735.0 6676.0 6900.0 Hour : Hour : Hour : MW MW MW MW 20:00 Max Demand 20:00 7000 MW Maximum Generation 6676.0 Hour: 20:00 Shortage 130 System L/ Factor :

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Total Gen. (MKWH) 137.1 78.37% 118 MW Export from East grid to West grid :- Maximum MKWHR 50 Energy 7.867 Import from West grid to East grid :- Maximum - Water Level of Kaptai Lake at 6:00 A M on MW Energy MKWHR 21-Aug-14 Actual : 87.64 Ft.(MSL) 95.40 Ft.(MSL) Gas Consumed : Total Oil Consumed (PDB) : HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Total : Tk540,189,204 Oil : Tk447,232,495 Coal Tk7,812,307 Load Shedding & Other Information Area Yesterday Today Estimated Shedding (s/s end) Estimated Demand(s/s end) Rates of Shedding MW (On Estimated Demand) Dhaka 66 (18:40-22:45) Chittagong Area Khulna Area 26 30 28 (18:40-22:45) 668 22 (18:40-22:45) 731 24 24 708 486 400 315 145 Rajshahi Area (18:40-22:45) Comilla Area 20 15 (18:40-22:45) 16 13 Mymensingh Area (18:40-22:45) Sylhet Area Barisal Area 0:00 (18:40-22:45) Rangpur Area 12 (18:40-22:45) 410 14 Total 202 6368 118 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Sylhet 150 MW GT (28/07/14) 4) Barapukuria ST: Unit-1(16/08/2014) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Description
a) There was generation shortage in the evening peak hour yesterday. Forced load shaded / Interrupted Areas So about 202 MW (20:00) of load shed was imposed over the whole areas (Except Sylhet) of the national grid. About 6 MW power interruption occurred under Sreemongal S/S areas from 09:15 to 10:15. o) Sreemongal 132/33 kV T2 transformer was shut down from 09:15 to 10:15 due to red hot maintenance c) Kabirpur-Tangail 132 kV Ckt-2 tripped at 13:02 showing earth fault relay at Kabirpur end and was switched on at 13:27.
d) After maintenance Rangpur 132/33 kV T1 transformer was switched on at 01:35(21/08/2014).

Sub Divisional Engineer Network Operation Division Executive Engineer
Network Operation Division

Superintendent Engineer

Load Despatch Circle