POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Page -1 Reporting Date : 2-Sep-14 Till now the maximum generation is: 7418 MW 21:00 Hrs 18-Jul-14 The Summary of Yesterday's (1-Sep-14 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 5418.0 MW Hour 12:00 Min. Gen. at 7:00 4927 MW Evening Peak Generation MW 6369.0 Hour: 21:00 Max Generation 6875 MW E.P. Demand (at gen end) : 6800.0 MW 21:00 Max Demand MW Hour: 7000 Maximum Generation 6369.0 MW Hour: 21:00 Shortage 125 MW Total Gen. (MKWH) 132.8 System L/ Factor 78.37% Load Shed 109 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MKWHR. Export from East grid to West grid :- Maximum 16:00 7.867 220 MW at Energy Import from West grid to East grid :- Maximum MKWHR. MW at Energy Water Level of Kaptai Lake at 6:00 A M on 2-Sep-14 87.64 Ft.(MSL) Actual: Ft.(MSL) Rule curve 99.23 Gas Consumed: Total 828.72 MMCFD. Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk61,000,549 Tk13,319,977 Total : Tk545,207,825 : Tk470,887,299 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand(s/s end) Estimated Shedding (s/s end) Rates of Shedding MW MW (On Estimated Demand) Dhaka 133 (18:15-23:30) 2413 (18:15-23:30) 655 Chittagong Area 48 35 Khulna Area 55 (18:15-23:30) 715 37 Rajshahi Area 52 (18:15-23:30) 694 37 Comilla Area 33 (18:15-23:30) 452 Mymensingh Area 20 (18:15-23:30) 374 Sylhet Area 14 304 (18:15-23:30) Barisal Area 8 (18:15-23:30) 135 Rangpur Area 25 (18:15-23:30) 382 Total 6124 388 109 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut-Down I) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Ghorasal ST : Unit -3 (19/08/2014) 4) Ashugani ST: Unit-1(23/08/2014) 5) Ashuganj CCPP: GT-2(22/08/2014) Additional Information of Machines. lines. Interruption / Forced Load shed etc Forced load shaded / Interrupted Areas Description a) There was generation shortage in the evening peak hour yesterday. So about 388 MW (21:00) of load shed was imposed over the whole areas of the national grid. b) Sylhet-Fenchugani 132 kV Ckt shut down from 09:22 to 14:40 due to dismantle a 33 kV tower inside the R/W of this ckt. c) Meghnaghat CCPP (Summit) tripped at 10:11 due to fuel line problem and was synchronized on at 12:34. d) After maintenance Haripur 412 MW CCPP was synchronized on at 11:20 and was shut down at 14:11 due to turbine cooling air leakage e) After maintenance Haripur-Maniknagor 132 kV Ckt-2 was switched on at 16:33. f) Maniknagor-Bangabhaban 132 kV Ckt-2 tripped from Maniknagor end at 18:38 showing pilot wire protection and was switched on at 19:03. g) Chandpur-Chowmohani 132 kV Ckt-2 was shut down from 22:40 to 01:40 (02/09/2014) due to red hot maintenance at Chowmohani end. n) Ullon-Rampura 132 kV Ckt-2 was shut down from 05:37 to 07:51(02/09/2014) due to red hot maintenance work at Ullon end. Sub Divisional Engineer Superintendent Engineer Executive Engineer letwork Operation Division Network Operation Division Load Despatch Circle