

Till now the maximum generation is :- **7418 MW** **21:00** Hrs on **18-Jul-14** Reporting Date : 11-Sep-14

The Summary of Yesterday's (10-Sep-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	5235.0	MW	Hour :	9:00	Min. Gen. at 8:00 5188 MW
Evening Peak Generation :	6144.0	MW	Hour :	20:00	Max Generation : 6305 MW
E.P. Demand (at gen end) :	7000.0	MW	Hour :	20:00	Max Demand : 7000 MW
Maximum Generation :	6336.0	MW	Hour :	1:00	Shortage : 695 MW
Total Gen. (MKWH) :	131.9	System L/ Factor :	78.37%	Load Shed :	603 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from East grid to West grid :- Maximum		150	MW at 10:00	Energy	7.867 MKWHR.
Import from West grid to East grid :- Maximum		-	MW at -	Energy	- MKWHR.
Actual : 87.64		Water Level of Kaptai Lake at 6:00 A M on		11-Sep-14	
Ft.(MSL) ,		Rule curve : 101.30		Ft.(MSL)	
Gas Consumed : Total 791.65		MMCFD.		Oil Consumed (PDB) :	
				HSD :	Liter
				FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk58,724,626		
		Coal :	Tk14,062,150	Oil :	Tk518,622,662
				Total :	Tk591,409,438

Load Shedding & Other Information

Area	Yesterday		Today		Rates of Shedding (On Estimated Demand)
	MW		Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	
Dhaka	249	(8:50-02:30)	2400	204	-
Chittagong Area	99	(8:50-02:30)	628	68	-
Khulna Area	112	(8:50-02:30)	685	75	-
Rajshahi Area	103	(8:50-02:30)	668	73	-
Comilla Area	70	(8:50-02:30)	460	49	-
Mymensingh Area	45	(8:50-02:30)	386	43	-
Sylhet Area	28	(8:50-02:30)	310	31	-
Barisal Area	16	(8:50-02:30)	140	16	-
Rangpur Area	53	(8:50-02:30)	395	44	-
-	-				
Total	775		6072	603	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 9) Chandpur 150 MW (07/09/2014) 2) Meghnaghat CCPP (21/04/2014) 10) Meghnaghat (Summit)GT-1 (30/08/2014) 3) Ashuganj ST: Unit-1(23/08/2014) 4) Ashuganj CCPP: GT-2(22/08/2014) 5) Haripur 412 MW CCPP ST(06/09/2014) 6) Baghabari GT 71 MW (04/09/2014) 7) Siddhirgonj ST (31/08/2014) 8) Ghorasal 100 MW (08/09/2014)8)

Additional Information of Machines. lines. Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 775 MW (20:00) of load shed was imposed over the whole areas of the national grid.
b) Ishurdi 132/33 kV T1 transformer was shut down from 09:50 to 13:59 due to red hot maintenance.	
c) Chandpur-Comilla(n) 132 kV Ckt-1 was shut down from 16:57 to 18:30 due to protection work.	
d) Shyampur 132/33 kV GT3 & GT4 transformer was shut down from 06:36 to 07:12 due to red hot at 33 kV side .	About 50 MW power interruption occurred under Shyampur S/S areas from 06:36 to 07:12.
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division
	Superintendent Engineer Load Despatch Circle