

Till now the maximum generation is : - 7418 MW 21:00 Hrs on 18-Jul-14 Reporting Date : 30-Sep-14

The Summary of Yesterday's (29-Sep-14				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5453.0	MW	Hour :	12:00	Min. Gen. at	7:00	5198	MW	
Evening Peak Generation :	6180.0	MW	Hour :	20:00	Max Generation :		6320	MW	
E.P. Demand (at gen end) :	6800.0	MW	Hour :	20:00	Max Demand :		6800	MW	
Maximum Generation :	6272.0	MW	Hour :	1:00	Shortage :		480	MW	
Total Gen. (MKWH) :	133.8	System L/ Factor :		78.37%	Load Shed :		420	MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum		-30		MW	at	19:30	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum		-		MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on				30-Sep-14					
Actual :	87.64	Ft.(MSL) ,		Rule curve :	105.76	Ft.(MSL)			
Gas Consumed : Total		776.58	MMCFD.		Oil Consumed (PDB) :				
				HSD :		Liter			
				FO :		Liter			
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk64,483,750						
		Coal :	Tk8,124,795		Oil :	Tk500,859,867	Total :	Tk573,468,412	

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		MW	
Dhaka	163	(18:20-01:30)	2327	106
Chittagong Area	74	(18:20-01:30)	620	54
Khulna Area	82	(18:20-01:30)	675	58
Rajshahi Area	73	(18:20-01:30)	660	58
Cornilla Area	53	(18:20-01:30)	455	39
Mymensingh Area	40	(18:20-01:30)	379	33
Sylhet Area	18	(18:20-01:30)	309	27
Barisal Area	14	(18:20-01:30)	137	12
Rangpur Area	41	(18:20-01:30)	387	33
-	-			-
Total	558		5949	420

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Meghnaghat CCPP (21/04/2014) 3) Ashuganj ST: Unit-1(23/08/2014) 4) Ashuganj CCPP: GT-2(22/08/2014) 5) Ghorasal ST: Unit-1 (11/09/2014) 6) Barapukuria ST: Unit-2 (28/09/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 558 MW (20:00) of load shed was imposed over the whole areas of the national grid .
b) Ashuganj-Kishorganj 132 kV Ckt-1 was under shut down from 08:24 to 14:56 due to insulator crack at Kishorganj end.	
c) Naogaon-Niamatpur 132 kV Ckt was under shut down from 11:05 to 17:03 due to 132 kV B-Phase CT change.	
d) Meghnaghat-Aminbazar 400 kV Ckt-2 was under shut down from 10:27 to 18:46 due to DFDR connection at Meghnaghat end.	
e) Siddhirganj-Maniknagar 132 kV Ckt-2 tripped at 12:40 from both end showing dist.relay at Siddhirganj end and diff.relay at Maniknagar end and was switched on at 13:09.	
f) Sikalbaha-Madunaghat 132 kV Ckt-1 was under shut down from 15:55 to 16:10 due to closing mid breaker of Sikalbaha-Bakulia 132 kV Ckt-1.	
g) Haripur-Meghnaghat 230 kV Ckt-1 was under shut down from 18:57 to 22:35 due to R-Phase T point maintenance.	
h) B.Barua 132/33 kV T1, T2 & T3 transformers tripped at 00:10 (30/09/2014) due to tripping of 33 kV Akhaura feeder and were switched on at 00:57 (30/09/2014).	
i) Jamalpur-Mymensingh 132 kV Ckt-1 & 2 were shut down at 05:17 due project work and switched on at 07:38 & 07:23 (30/09/2014) respectively.	Power interruption occurred (about 55 MW) under Jamalpur & Sherpur S/S areas from 05:17 to 07:23 (30/09/2014).
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle