

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

Reporting Date : 11-Oct-14

The Summary of Yesterday's (10-Oct-14)				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	:	4748.0	MW	Hour :	12:00	Min. Gen. at	7:00	4312	MW
Evening Peak Generation	:	6389.0	MW	Hour :	20:00	Max Generation	:	6928	MW
E.P. Demand (at gen end)	:	6389.0	MW	Hour :	20:00	Max Demand	:	6800	MW
Maximum Generation	:	6389.0	MW	Hour :	20:00	Shortage	:	-128	MW
Total Gen. (MKWH)	:	124.4	System L/ Factor	:	78.37%	Load Shed	:	0	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum		-160	MW	at	17:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on				11-Oct-14				
Actual :	87.64	Ft.(MSL) ,	Rule curve :	106.90	Ft.(MSL)			

Gas Consumed :	Total	883.96	MMCFD.	Oil Consumed (PDB) :	HSD :	Liter
					FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk66,446,315			
		Coal :	Tk15,858,974	Oil :	Tk221,122,283	Total : Tk303,427,572

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)
			MW	MW
Dhaka	-	0.00	2298	-
Chittagong Area	-	0.00	588	-
Khulna Area	-	0.00	642	-
Rajshahi Area	-	0.00	624	-
Comilla Area	-	0.00	430	-
Mymensingh Area	-	0.00	357	-
Sylhet Area	-	0.00	291	-
Barisal Area	-	0.00	129	-
Rangpur Area	-	0.00	365	-
	-			
Total	0		5724	0

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)		1) Ghorasal ST: Unit-6 (18/07/2010)
		2) Megnaghat CAPP (21/04/2014)
		3) Ashuganj ST: Unit-1(23/08/2014)
		4) Ghorasal ST: Unit-3 (03/10/2014)
		5) Barisal GT: Unit-1 (17/09/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Maniknagar-Bangabhaban 132 kV Ckt-2 was shut down from 10:15 to 11:40 due to tree trimming.	
b) Comilla (N)-Ashuganj 230 kV Ckt-1 tripped at 13:50 showing distance relay from Comilla (N) end and was switched on at 13:54.	
c) Dohazari-Cox's bazar 132 kV Ckt-2 tripped at 15:15 showing distance relay from both end and was switched on at 15:38.	
d) Siddhirganj 132/33 kV T2 transformer tripped at 15:42 showing PRD, lock out relay and was switched on at 18:00.	
e) Narsingdi-Haripur 132 kV Ckt was shut down from 20:30 to 23:25 due to red hot maintenance work at Narsingdi end.	
f) Shahjadpur 132/33 kV T4 transformer was shut down from 18:58 to 20:05 due to red hot maintenance work.	About 20 MW power interruption occurred under Joydevpur S/S areas
g) Joydevpur 132/33 kV T3 transformer tripped at 05:15(11/10/2014) due to 33 kV feeder fault and was switched on from 05:15 to 05:26(11/10/2014).	
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division
	Superintendent Engineer Load Despatch Circle