

**POWER GRID COMPANY OF BANGLADESH LTD.  
NATIONAL LOAD DESPATCH CENTER  
DAILY REPORT**

**QF-LDC-08  
Page -1**

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 6-Nov-14		Page - 1	
The Summary of Yesterday's ( 5-Nov-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand					
Day Peak Generation :		5222.0		MW		Hour : 12:00		Min. Gen. at 5:00		4175		MW	
Evening Peak Generation :		6752.0		MW		Hour : 18:30		Max Generation :		6856		MW	
E.P. Demand (at gen end) :		6752.0		MW		Hour : 18:30		Max Demand :		6800		MW	
Maximum Generation :		6752.0		MW		Hour : 18:30		Shortage :		-56		MW	
Total Gen. (MKWH) :		122.3		System L/ Factor :		78.37%		Load Shed :		0		MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR													
Export from East grid to West grid :- Maximum				120		MW at 15:00		Energy		7.867		MKWHR.	
Import from West grid to East grid :- Maximum				-		MW at -		Energy		-		MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on				6-Nov-14									
Actual :		87.64		Ft.(MSL) ,		Rule curve :		108.50		Ft.( MSL )			
Gas Consumed : Total		848.21		MMCFD.		Oil Consumed (PDB) :		HSD : FO :		Liter		Liter	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk65,253,013		Oil : Tk272,294,210		Total : Tk345,320,470					
Coal : Tk7,773,246													
Load Shedding & Other Information													
Area													
Yesterday													
Estimated Demand(s/s end)													
Today													
Estimated Shedding (s/s end)													
Rates of Shedding (On Estimated Demand)													
Dhaka - 0:00 2506 - -													
Chittagong Area - 0:00 646 - -													
Khulna Area - 0:00 707 - -													
Rajshahi Area - 0:00 684 - -													
Comilla Area - 0:00 470 - -													
Mymensingh Area - 0:00 387 - -													
Sylhet Area - 0:00 315 - -													
Barisal Area - 0:00 140 - -													
Rangpur Area - 0:00 396 - -													
Total 0 6251 0													
Information of the Generating machines under shut down.													
Planned Shut- Down													
Forced Shut- Down													
1) Haripur GT: Unit-3 (18/06/2009)													
1) Ghorasal ST: Unit-6 (18/07/2010)													
2) Ashuganj ST: Unit-1(23/08/2014)													
3) Ghorasal ST: Unit-1 (12/10/2014)													
4) Siddhirganj ST (14/10/2014)													
5) Ashuganj ST: Unit-2 (29/10/2014)													
6) Baghabari 71 MW (22/10/2014)													
7) Khulna ST 110 MW (04/11/2014)													
8) Fenchuganj CCPP-1 ST (01/11/2014)													
Additional Information of Machines. lines. Interruption / Forced Load shed etc													
Description													
Forced load shaded / Interrupted Areas													
a) Mymensing 132/33 kV T1 Transformer was shut down from 08:38 to 15:15 due to A/M.													
b) Mirpur - Tongi 132 kV Ckt was shut down from 08:30 to 15:13 due to A/M.													
c) Tongi 230/132 kV To1 Auto Transformer was shut down at 09:15 due to A/M.													
d) Aminbazar 230/132 kV TR2 Auto Transformer was shut down from 08:58 to 17:30 due to A/M.													
e) Khulna(S) 230/132 kV Auto Transformer T2 was shut down from 08:58 to 16:59 due to A/M.													
f) Kishorganj 132/33 kV T1 Transformer was shut down from 08:38 to 15:05 due to A/M.													
g) Comilla(n)-Chandpur 132/33 kV Ckt tripped at 09:17 showing dist protection at C phase and was switched on at 09:18.													
h) Kallyanpur 132 kV bus coupler was open at 09:28 due to A/M and was switched on at 14:12.													
i) After maint Sikalbaha 150 MW GT was synchronized at 11:13.													
j) Faridpur 132/33 kV T2 Transformer was shut down from 08:01 to 15:40 due to A/M.													
k) Mongla132/33 kV T2 Transformer was shut down from 09:05 to 15:31 due to A/M.													
l) Jamalpur 132/33 kV T1 Transformer was shut down from 10:40 to 12:40 due to project work.													
m) After maintenance Barapukuria unit-1 was synchronized at 16:32.													
n) Jamalpur - Sherpur 132 kV Ckt-1 was shut down from 15:22 to 15:58 due to project work.													
o) Matuail - Maniknagor 132 kV Ckt was switched on at 17:06 at Matuail end.													
p) After maintenance Ghorasal unit-3 was synchronized at 18:45.													
q) Haripur AES 360 MW was shut down at 00:01 (06/11/2014) due to maintenance work.													
r) Haripur -Maniknagor -Ullon 132 kV Ckt-2 was shut down from 06:20 to 08:57 (06/11/2014) due to jumper connection at tower # 12.													
s) Shyampur 132/33 kV T3 & T4 Transformers were under shut down from 06:55 to 10:35 (06/11/2014) due to red													
at CT terminal of T3.													
About 35 MW power interruption occurred under Shyampur S/S areas from 06:55 to10:35.													
Sub Divisional Engineer				Executive Engineer				Superintendent Engineer					
Network Operation Division				Network Operation Division				Load Despatch Circle					