

Till now the maximum generation is :-

7418 MW

21:00

Hrs

on

Reporting Date : 1-Nov-14

18-Jul-14

The Summary of Yesterday's (31-Oct-14)				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	:	4296.0	MW	Hour :	12:00	Min. Gen. at	5:00	3749	MW
Evening Peak Generation	:	6050.0	MW	Hour :	18:30	Max Generation	:	6626	MW
E.P. Demand (at gen end)	:	6050.0	MW	Hour :	18:30	Max Demand	:	6500	MW
Maximum Generation	:	6050.0	MW	Hour :	18:30	Shortage	:	-126	MW
Total Gen. (MKWH)	:	108.2	System L/ Factor	:	78.37%	Load Shed	:	0	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum		30	MW	at	10:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum		-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on					1-Nov-14			
Actual :	87.64	Ft.(MSL) ,	Rule curve :		109.00	Ft.(MSL)		
Gas Consumed : Total		760.24	MMCFD.		Oil Consumed (PDB) :		HSD :	Liter
							FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk59,781,114					
		Coal :	Tk13,007,484		Oil : Tk136,966,243		Total	: Tk209,754,840

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
			MW	
Dhaka	-	0.00	2239	-
Chittagong Area	-	0.00	571	-
Khulna Area	-	0.00	623	-
Rajshahi Area	-	0.00	607	-
Comilla Area	-	0.00	419	-
Mymensingh Area	-	0.00	349	-
Sylhet Area	-	0.00	284	-
Barisal Area	-	0.00	126	-
Rangpur Area	-	0.00	357	-
	-			
Total	0		5575	0

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CAPP (21/04/2014) 3) Ashuganj ST: Unit-1(23/08/2014) 4) Ghorasal ST: Unit-1 (12/10/2014) 5) Siddhirganj ST (14/10/2014) 6) Ghorasal ST : Unit-4 (23/10/2014) 7) Ashuganj ST: Unit-2 (29/10/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Ishurdi-Pabna 132 kV Ckt was under shut down from 08:50 to 15:27 due to A/M. b) Kallyanpur-Hasnabad 132 kV Ckt was under shut down from 08:50 to 16:18 due to A/M. c) Hasnabad 132 kV Main Bus, 132/33 kV Tr-1 & Tr-3 transformers were under shut down from 10:40 to 12:40 due to isolator maintenance work. d) Ashuganj 132/33 kV T4 transformer was shut down at 09:42 due to replacement work. e) Jamalpur-Mymensingh 132 kV Ckt-2 was shut down at 10:17 due to Project work. f) Bagerhat 132/33 kV T1 & T2 transformers tripped at 11:09 from both transformers showing O/C, E/F at 132 kV end and were switched on at 11:14. g) Ashuganj-Kishorgonj 132 kV Ckt-1 is under shut down at 07:57 (01/11/2014) due to 225 MW project work. h) Barisal-Madaripur 132 kV Ckt-1 is under shut down at 06:07 (01/11/2014) due to project work.	Power interruption occurred (about 14 MW) under Bagerhat S/S areas from 11:09 to 11:14.
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle