

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 16-Nov-14	
The Summary of Yesterday's (15-Nov-14				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand					
Day Peak Generation :	4328.0	MW	Hour :	12:00	Min. Gen. at	5:00	3520	MW			
Evening Peak Generation :	6174.0	MW	Hour :	18:30	Max Generation :		6626	MW			
E.P. Demand (at gen end) :	6174.0	MW	Hour :	18:30	Max Demand :		6600	MW			
Maximum Generation :	6174.0	MW	Hour :	18:30	Shortage :		-26	MW			
Total Gen. (MKWH) :	113.2	System L/ Factor :		78.37%	Load Shed :		0	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-42		MW	at	15:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum						MW	at		Energy	-	MKWHR.
Actual : 87.64				Water Level of Kaptai Lake at 6:00 A M on		16-Nov-14					
				Ft.(MSL) ,		Rule curve :		107.50 Ft.(MSL)			
Gas Consumed : Total		754.98		MMCFD.		Oil Consumed (PDB) :					
						HSD :		Liter			
						FO :		Liter			
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk64,459,381							
		Coal :		Tk12,773,120		Oil :		Tk191,803,399		Total : Tk269,035,899	
Load Shedding & Other Information											
Area	Yesterday			Estimated Demand(s/s end)			Today				
	MW			MW			Estimated Shedding (s/s end)			Rates of Shedding (On Estimated Demand)	
Dhaka	-	0.00		2214			-			-	
Chittagong Area	-	0.00		564			-			-	
Khulna Area	-	0.00		615			-			-	
Rajshahi Area	-	0.00		600			-			-	
Comilla Area	-	0.00		414			-			-	
Mymensingh Area	-	0.00		345			-			-	
Sylhet Area	-	0.00		281			-			-	
Barisal Area	-	0.00		125			-			-	
Rangpur Area	-	0.00		353			-			-	
Total	0			5511			0				
Information of the Generating machines under shut down.											
Planned Shut- Down						Forced Shut- Down					
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 3) Siddhirganj ST (14/10/2014) 4) Baghabari 71 MW (22/10/2014) 5) Khulna ST 110 MW (04/11/2014) 6) Fenchuganj CCP-2 ST (07/11/2014) 7) Sylhet 150MW GT(07/11/2014) 8) Ashuganj ST: Unit-4(08/11/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Hasnabad - Kalyanpur 132 kV Ckt was shut down from 08:05 to 19:22 due to A/M. b) Naogaon 132/33 kV T2 Transformer was Shut down from 08:15 to 10:15 due to A/M. c) Ghorasal - Ishurdi 230 kV Ckt-1 was shut down from 08:21 to 17:08 due to A/M. d) Dohazari - Sikalbaha 132 kV Ckt-1 was shut down from 08:22 to 15:59 due to A/M. e) Sonargaon - Meghnaghat IEL 132 kV Ckt was shut down from 08:27 to 15:28 due to A/M. f) Ashuganj - Kishorganj 132 kV Ckt-1 was shut down from 08:31 to 16:56 due to A/M. g) Comilla(N) 230/132 kV T02 Auto Transformer was shut down from 08:44 to 14:35 due to A/M. h) Hathazari - Feni 132 kV Ckt-2 was shut down from 08:47 to 15:13 due to A/M. i) Saver 132/33 kV T2 Transformer was shut down from 08:47 to 16:42 due to A/M. j) Satkhira 132/33 kV T1 Transformer was shut down from 08:56 to 17:03 due to A/M. k) Thakurgaon 132/33 kV S/S Capacitor bank was shut down from 08:50 to 14:30 due to A/M. l) Tangail 132/33 kV T2 Transformer was shut down from 08:58 to 16:10 due to A/M. m) Bottail - Jhenidah 132 kV Ckt-2 was shut down from 09:15 to 13:14 due to A/M. n) Hasnabad- Shyampur 132 kV Ckt was shut down from 09:24 to 18:15 due to A/M. o) Kabirpur 132 kV main bus was shut down from 09:25 to 17:46 due to A/M. p) Ghorasal 132/33 kV T1 Transformer was shut from 09:35 to 15:54 due to energy meter testing. q) Ishurdi - Pabna 132 kV Ckt was shut down from 10:30 to 10:45 for removing nest. r) Goalpara 132/33 kV T5 Transformer is under shut down since 07:50 (16/11/2014) due to A/M.						Power interruption occurred (about 35 MW) under Ghorasal S/S areas from 09:35 to 15:54.					
Sub Divisional Engineer		Executive Engineer				Superintendent Engineer					
Network Operation Division		Network Operation Division				Load Despatch Circle					