

Till now the maximum generation is :-			7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 19-Nov-14		
The Summary of Yesterday's (			18-Nov-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :			4677.0		MW		Hour: 12:00		Min. Gen. at 5:00 3523 MW		
Evening Peak Generation :			6126.0		MW		Hour: 18:30		Max Generation : 6249 MW		
E.P. Demand (at gen end) :			6126.0		MW		Hour: 18:30		Max Demand : 6200 MW		
Maximum Generation :			6126.0		MW		Hour: 18:30		Shortage : -49 MW		
Total Gen. (MKWH) :			108.6		System L/ Factor :		78.37%		Load Shed : 0 MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum					-180		MW at 21:00		Energy 7.867 MKWHR.		
Import from West grid to East grid :- Maximum							MW at -		Energy - MKWHR.		
Water Level of Kaptai Lake at 6:00 A M on 19-Nov-14											
Actual :			87.64		Ft.(MSL) ,		Rule curve : 107.20		Ft.( MSL )		
Gas Consumed : Total			822.73		MMCFD.		Oil Consumed (PDB) :		HSD : Liter		
									FO : Liter		
Cost of the Consumed Fuel (PDB+Pvt) :			Gas :		Tk64,588,020						
			Coal :		Tk3,710,843		Oil : Tk206,397,167		Total : Tk274,696,030		
Load Shedding & Other Information											
Area											
Yesterday			Estimated Demand(s/s end)				Today		Estimated Shedding (s/s end) Rates of Shedding (On Estimated Demand)		
MW			MW				MW				
Dhaka			- 0.00 2173				-		-		
Chittagong Area			- 0.00 553				-		-		
Khulna Area			- 0.00 602				-		-		
Rajshahi Area			- 0.00 588				-		-		
Comilla Area			- 0.00 406				-		-		
Mymensingh Area			- 0.00 339				-		-		
Sylhet Area			- 0.00 276				-		-		
Barisal Area			- 0.00 123				-		-		
Rangpur Area			- 0.00 347				-		-		
Total			0				5407		0		
Information of the Generating machines under shut down.											
Planned Shut- Down											
1) Haripur GT: Unit-3 (18/06/2009)											
Forced Shut- Down											
1) Ghorasal ST: Unit-6 (18/07/2010)											
2) Ashuganj ST: Unit-1(23/08/2014)											
4) Baghabari 71 MW (22/10/2014)											
5) Khulna ST 110 MW (04/11/2014)											
6) Fenchuganj CCGP-2 ST (07/11/2014)											
7) Sylhet 150 MW GT (07/11/2014)											
9) Ghorashal ST : Unit-4 (11/11/2014)											
9) Barapukuria ST: Unit-2 (17/11/2014)											
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description											
Forced load shaded / Interrupted Areas											
a) Kishoreganj - Ashuganj 132 kV Ckt-1 was shut down from 08:25 to 15:27 due to A/M.											
b) Kalyanpur - Aminbazar 132 kV Ckt-1 was shut down from 08:27 to 15:15 due to A/M.											
c) Rangpur - Palashbari 132 kV Ckt-2 was shut down from 08:40 to 17:27 due to A/M											
d) Aminbazar - Hasnabad 230 kV Ckt-1 was shut down from 08:45 to 17:17 due to A/M.											
e) Joydabpur -Kabirpur 132 kV Ckt-1 was shut down from 08:54 to17:12 due to A/M.											
f) Joydabpur -Kabirpur 132 kV Ckt-2 was shut down from 08:55 to18:50 due to CB maint at Kabirpur end.											
g) Madanganj-Basundhara Cement 132 kV Ckt was shut down from 12:12 to 15:03 . due to PT maint at Basundhara end.											
h) Goalpara 132/33 kV T6 Transformer was shut down from 08:46 to 14:44 due to A/M.											
i) Madaripur 132/33 kV T3 Transformer was shut down from 08:47 to 15:10 due to A/M.											
j) Mymensing - Kishoreganj 132 kV Ckt-1 was shut down from 08:52 to 13:30 due to A/M.											
k) Satkhira 132/33 kV T2 Transformer was shut down from 09:20 to 13:50 due to A/M.											
l) Shampur - Hasnabad 132 kV Ckt was shut down from 09:52 to 17:18 due to A/M.											
m) Haripur 230 kV Bus-1 was shut down from 10:46 to 15:45 due to A/M.											
n) Khulna 150 MW tripped at 12:43 due to differential pressure high and was switched on at 13:23.											
o) Madanhat - Sikalbaha-TK Chemical 132 kV Ckt-2 was shut down from 08:05 to 16:16 due to A/M.											
q) Tangail 132/33 kV T2 Transformer was shut down 08:52 to 15:21 due to A/M.											
r) Khulna 150 MW was shut down from 21:26 to 04:55 (19/11/2014) due to filter cleaning.											
s) Khulna@ 132/33 kV T1 Transformer is shut down at 07:26 (19/11/2014) due to A/M.											
t) Goalpara 132 kV A- bus is shut down at 07:35 (19/11/20014) due to A/M.											
u) Goalpara - Khulna 150 MW 132 kV Ckt is shut down at 07:35 (19/11/2014) due to A/M.											
q) Ashuganj - Comilla(N) 230 kV Ckt-1 tripped at 07:35 (19/11/2014) from both end showing distance relay and was switched on at 07:58.											
Sub Divisional Engineer				Executive Engineer				Superintendent Engineer			
Network Operation Division				Network Operation Division				Load Despatch Circle			