

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 24-Nov-14					
The Summary of Yesterday's (23-Nov-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand							
Day Peak Generation :				4533.0		MW		Hour :		12:00		Min. Gen. at 4:00 3298 MW			
Evening Peak Generation :				6066.0		MW		Hour :		18:00		Max Generation : 6254 MW			
E.P. Demand (at gen end) :				6066.0		MW		Hour :		18:00		Max Demand : 6150 MW			
Maximum Generation :				6038.0		MW		Hour :		18:30		Shortage : -104 MW			
Total Gen. (MKWH) :				104.1		System L/ Factor :		78.37%		Load Shed :		0 MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR															
Export from East grid to West grid :- Maximum				-170		MW		at 17:00		Energy 7.867		MKWHR.			
Import from West grid to East grid :- Maximum				-		MW		at -		Energy -		MKWHR.			
Actual :				87.64		Water Level of Kaptai Lake at 6:00 A M on Ft.(MSL) ,		Rule curve :		24-Nov-14 106.70		Ft.(MSL)			
Gas Consumed : Total				790.06		MMCFD.		Oil Consumed (PDB) :		HSD : Liter		FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk59,884,204		Coal : Tk0		Oil : Tk185,540,295		Total : Tk245,424,499					
Load Shedding & Other Information															
Area		Yesterday				Estimated Demand(s/s end)				Today					
		MW				MW				Estimated Shedding (s/s end)				Rates of Shedding (On Estimated Demand)	
Dhaka		- 0.00				1999				-				-	
Chittagong Area		- 0.00				504				-				-	
Khulna Area		- 0.00				547				-				-	
Rajshahi Area		- 0.00				538				-				-	
Comilla Area		- 0.00				373				-				-	
Mymensingh Area		- 0.00				315				-				-	
Sylhet Area		- 0.00				256				-				-	
Barisal Area		- 0.00				114				-				-	
Rangpur Area		- 0.00				322				-				-	
Total		0				4968				0					
Information of the Generating machines under shut down.															
		Planned Shut- Down						Forced Shut- Down							
		1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 10) Barapukuria ST: Unit-1 (20/11/2014) 2) Ashuganj ST: Unit-1(23/08/2014) 11) Ghorasal ST: Unit-5 (23/11/2014) 4) Baghabari 71 MW (22/10/2014) 5) Khulna ST 110 MW (04/11/2014) 6) Fenchuganj CCP-2 ST (07/11/2014) 7) Sylhet 150 MW GT (07/11/2014) 8) Ghorashal ST : Unit-4 (11/11/2014) 9) Barapukuria ST: Unit-2 (16/11/2014)							
Additional Information of Machines. lines. Interruption / Forced Load shed etc.															
Description								Forced load shaded / Interrupted Areas							
a) Modunaghat - Sikatbaha 132 kV Ckt-1 was shut down from 07:41 to 16:46 due to A/M.															
b) Ghorashal unit-5 tripped at 08:45 due to boiler tube leakage.															
c) Ashuganj - Kishoreganj 132 kV Ckt-1 was shut down from 08:21 to 16:35 due to A/M															
d) Bheramara HVDC - Ishurdi 230 kV Ckt-1 was shut down from 08:15 to 15:14 due to A/M.															
e) Kabirpur - Manikganj 132 kV Ckt-1 was shut down from 08:10 to 16:27 due to A/M.															
f) Bogra - Sirajganj 230 kV Ckt-1 was shut down from 08:37 to 15:30 due to A/M.															
g) Halishahar - Kulshi 132 kV Ckt-2 was shut down from 08:40 to 14:35 due to A/M.															
h) Jamalpur 132/33 kV T1 Transformer was shut down from 09:02 to 16:15 due to A/M.															
i) Aminbazar - Meghnaghat 230 kV Ckt-2 was shut down from 09:55 to 15:23 due to A/M.															
j) Aminbazar 230 kV bus-2 was shut down from 10:40 to 16:57 due to A/M.															
k) Hathazari - Feni 132 kV Ckt-1 was shut down from 08:56 to 15:18 due to A/M.															
l) Kabirpur - Tongi 132 kV Ckt-1 was shut down from 08:58 to 17:09 due to A/M.															
m) Kabirpur - Tangail was shut down from 09:09 to 16:05 due to A/M.															
n) Naogaon 132/33 kV T3 Transformer was shut down from 09:20 to 13:55 due to A/M.															
o) Sirajganj 132/33 kV T1 Transformer was shut down from 09:52 to 16:45 due to A/M.															
p) Mirpur 132 kV bus coupler CB was shut down at 14:55 (22/11/2014) due to A/M and was switched on at 10:45 (23/11/2014).															
q) Sirajganj 132/33 kV T1 Transformer was shut down from 09:58 to 16:45 due to A/M.															
r) Hasnabad 132 kV bus coupler was shut down from 09:56 to 13:20 due to A/M.															
s) Haripur - Rampura 230 kV Ckt-1 was shut down from 10:10 to 17:38 due to A/M.															
t) Basundhara - Rampura 132 kV Ckt-1 was shut down from 10:12 to 16:53 due to PT, CT,CB etc structure re- alignment work.															
u) Jessore 132/33 kV T2 Transformer was shut down from 09:07 to 13:38 due to A/M.															
v) Sylhet 132/33 kV T1 Transformer is shut down at 06:27 (24/11/2014) due to A/M.															
w) Natore - Rajshahi 132 kV Ckt-2 is shut down at 07:05 (24/11/2014) due to A/M.															
x) Patuakhali 132/33 kV T2 Transformer is shut down at 07:07 (24/11/2014) due to A/M.															
y) Khulna© 132/33 kV T3 Transformer is shut down at 07:10 (24/11/2014) due to A/M.															
z)T.K Chemical - Sikatbaha 132 kV Ckt is shut down at 07:40 (24/11/2014) due to A/M.															
aa) New Megnaghat - Daudkandi 132 kV Ckt-2 is shut down from 08:00 (24/11/2014) due to A/M.															
Sub Divisional Engineer				Executive Engineer				Superintendent Engineer							
Network Operation Division				Network Operation Division				Load Despatch Circle							