

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 29-Nov-14	
The Summary of Yesterday's (28-Nov-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		3648.0		MW		Hour :		9:00		Min. Gen. at 5:00 3053 MW	
Evening Peak Generation :		5410.0		MW		Hour :		19:00		Max Generation : 5956 MW	
E.P. Demand (at gen end) :		5410.0		MW		Hour :		19:00		Max Demand : 5900 MW	
Maximum Generation :		5410.0		MW		Hour :		19:00		Shortage : -56 MW	
Total Gen. (MKWH) :		93.3		System L/ Factor :				78.37%		Load Shed : 0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-160				MW at 17:00		Energy 7.867 MKWHR.	
Import from West grid to East grid :- Maximum				-				MW at -		Energy - MKWHR.	
Actual :		87.64		Water Level of Kaptai Lake at 6:00 A M on 29-Nov-14				Rule curve : 106.20 Ft.(MSL)			
Gas Consumed : Total		742.80		MMCFD.				Oil Consumed (PDB) :			
								HSD : Liter			
								FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) :				Gas :		Tk56,296,867					
				Coal :		Tk6,718,581		Oil : Tk98,690,772		Total : Tk161,706,220	
Load Shedding & Other Information											
Area		Yesterday				Today					
		MW				Estimated Demand(s/s end)		Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)	
						MW		MW			
Dhaka		-		0.00		2008		-		-	
Chittagong Area		-		0.00		507		-		-	
Khulna Area		-		0.00		550		-		-	
Rajshahi Area		-		0.00		540		-		-	
Comilla Area		-		0.00		375		-		-	
Mymensingh Area		-		0.00		316		-		-	
Sylhet Area		-		0.00		257		-		-	
Barisal Area		-		0.00		115		-		-	
Rangpur Area		-		0.00		323		-		-	
Total		0				4991		0			
Information of the Generating machines under shut down.											
Planned Shut- Down						Forced Shut- Down					
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 9) Barapukuria ST: Unit-1 (20/11/2014)					
						2) Ashuganj ST: Unit-1(23/08/2014) 10) Ghorasal ST: Unit-5 (23/11/2014)					
						4) Baghabari 71 MW (22/10/2014)					
						5) Khulna ST 110 MW (04/11/2014)					
						6) Fenchuganj CCPP-2 ST (07/11/2014)					
						7) Raozan unit-2 (27/11/2014)					
						8) Ghorashal ST : Unit-4 (11/11/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Sirajganj 210 MW only steam unit was shut down at 08:04 due to HPU system inspection and maintenance and was synchronized at 07:13 (29/11/2014).						Power interruption occurred (about 8 MW) under Mongla S/S areas from 09:18 to 16:12.					
b) Bagherhat-Mongla 132 kV Ckt was under shut down from 09:18 to 16:12 due to A/M.											
c) Halishahar 132/33 kV T1 transformer was under shut down from 07:52 to 12:30 due to A/M.						Power interruption occurred (about 60 MW) under Comilla (S) S/S areas from 07:02 to 09:20 (29/11/2014).					
d) Halishahar 132/33 kV T2 transformer was under shut down from 12:35 to 15:40 due to A/M.											
e) Kallyanpur-Aminbazar 132 kV Ckt-2 was under shut down from 12:39 to 17:10 due to A/M.											
f) Kallyanpur-Kamrangirchar 132 kV Ckt tripped at 13:50 showing E/F relay and was switched on at 14:25.											
g) Hasnabad-Lalbagh 132 kV Ckt tripped at 13:50 from both end showing main protection relay and was switched on at 14:29.											
h) Khulna 150 MW was forced shut down at 00:36 (29/11/2014) due to clean air filter.											
i) Rampura-Ghorasal 230 kV Ckt-2 was shut down at 07:32 (29/11/2014) due to A/M.											
j) Comilla (S) 132 kV bus was under shut down from 07:02 to 09:20 (29/11/2014) due to project work.											
K) Sirajganj 210 MW ST unit synchronized at 07:13 (29/11/2014).											
l) Ashuganj GT-2 tripped at 07:16 (29/11/2014) due to auxiliary supply failure.											
m) Tongi 132 kV circuit breaker (618 B) was switched off due to low hydraulic oil pressure at 07:10 (29/11/2014)											
Sub Divisional Engineer		Executive Engineer				Superintendent Engineer					
Network Operation Division		Network Operation Division				Load Despatch Circle					