

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 1-Dec-14	
The Summary of Yesterday's (30-Nov-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		4424.0		MW		Hour :		12:00		Min. Gen. at 4:00 3207 MW	
Evening Peak Generation :		5991.0		MW		Hour :		18:00		Max Generation : 6064 MW	
E.P. Demand (at gen end) :		5991.0		MW		Hour :		18:00		Max Demand : 6100 MW	
Maximum Generation :		5942.0		MW		Hour :		18:30		Shortage : 36 MW	
Total Gen. (MKWH) :		102.1		System L/ Factor :				78.37%		Load Shed : 43 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-200		MW at		3:00		Energy 7.867 MKWHR.	
Import from West grid to East grid :- Maximum				-		MW at		-		Energy - MKWHR.	
Actual :		87.64		Water Level of Kaptai Lake at 6:00 A M on Ft.(MSL) ,				Rule curve :		1-Dec-14 106.00 Ft.(MSL)	
Gas Consumed : Total		780.17		MMCFD.		Oil Consumed (PDB) :				HSD : Liter FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk59,106,717		Coal : Tk8,320,104		Oil : Tk129,931,362		Total : Tk197,358,182	
Load Shedding & Other Information											
Area		Yesterday		Estimated Demand(s/s end)		Today		Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)	
		MW		MW		MW		MW			
Dhaka		-		0.00		2173		18		-	
Chittagong Area		-		0.00		553		5		-	
Khulna Area		-		0.00		602		5		-	
Rajshahi Area		-		0.00		588		5		-	
Comilla Area		-		0.00		406		3		-	
Mymensingh Area		-		0.00		339		2		-	
Sylhet Area		-		0.00		276		2		-	
Barisal Area		-		0.00		123		1		-	
Rangpur Area		-		0.00		347		2		-	
Total		0		5407		43					
Information of the Generating machines under shut down.											
Planned Shut- Down						Forced Shut- Down					
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 10) Barapukuria ST: Unit-1 (20/11/2014) 2) Ashuganj ST: Unit-1(23/08/2014) 11) Ghorasal ST: Unit-5 (23/11/2014) 4) Baghabari 71 MW (22/10/2014) 5) Khulna ST 110 MW (04/11/2014) 6) Fenchuganj CCPP-2 ST (07/11/2014) 7) Chittagong ST: unit-2 (26/11/2014) 8) Ghorashal ST : Unit-4 (11/11/2014) 9) Chittagong ST: unit-1 (04/11/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Dohazari - Sikalbaha 132 kV Ckt-1 was shut down from 08:25 to 16:45 due to A/M. b) Madaripur - Faridpur 132 kV Ckt-1 was shut down from 08:09 to 15:54 due to A/M. c) Rampura - Basundhara 132 kV Ckt-1 was shut down from 09:05 to 14:23 due to A/M. d) Kabirpur - Tongi 132 kV Ckt-2 was shut down from 09:04 to 16:27 due to A/M. e) Rampura 230/132 kV Tx-2 Auto Transformer was shut down from 09:21 to 17:02 due to A/M. f) Palashbari - Bogra 132 kV Ckt-2 was shut down from 09:20 to 17:05 due to A/M. g) Mymensingh - Netrokona 132 kV Ckt-1 was shut down from 09:20 to 13:40 due to A/M. h) Monsiganj 132/33 kV Transformer was shut down from 09:25 to 16:44 due to A/M. i) Tangail - Kabirpur 132 kV Ckt-1 was shut down from 09:50 to 14:44 due to A/M and protection work. j) Comilla(N) - Feni 132 kV Ckt-2 (T-line) was shut down from 09:02 to 15:32 due to A/M. k) Tongi - Uttara 132 kV Ckt was shut down from 09:14 to 17:05 due to A/M. l) Rajshahi S/S - NPSL 132 kV Ckt was shut down from 09:15 to 15:18 due to A/M. m) Khulna 150 MW is forced shut down at 07:19 (01/12/2014) due to DP high. It is now under maintenance for air filter cleaning.											
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division					
						Superintendent Engineer Load Despatch Circle					