

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 2-Dec-14	
The Summary of Yesterday's (1-Dec-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		4285.0		MW		Hour :		12:00		Min. Gen. at 4:00 3228 MW	
Evening Peak Generation :		5987.0		MW		Hour :		18:00		Max Generation : 6086 MW	
E.P. Demand (at gen end) :		5987.0		MW		Hour :		18:00		Max Demand : 6050 MW	
Maximum Generation :		5987.0		MW		Hour :		18:00		Shortage : -36 MW	
Total Gen. (MKWH) :		103.8		System L/ Factor :				78.37%		Load Shed : 0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-170				MW at 3:00		Energy 7.867 MKWHR.	
Import from West grid to East grid :- Maximum				-				MW at -		Energy - MKWHR.	
Actual :		87.64		Water Level of Kaptai Lake at 6:00 A.M on Ft.(MSL) ,				Rule curve :		2-Dec-14 105.90 Ft.(MSL)	
Gas Consumed : Total		771.93		MMCFD.				Oil Consumed (PDB) :		HSD : Liter	
								FO :		Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk60,058,283				Oil :		Tk176,216,457 Total : Tk244,555,784	
		Coal :		Tk8,281,043							
Load Shedding & Other Information											
Area		Yesterday				Today					
		MW		Estimated Demand(s/s end) MW		Estimated Shedding (s/s end) MW		Rates of Shedding (On Estimated Demand)			
Dhaka		-		0.00		2214		-		-	
Chittagong Area		-		0.00		564		-		-	
Khulna Area		-		0.00		615		-		-	
Rajshahi Area		-		0.00		600		-		-	
Comilla Area		-		0.00		414		-		-	
Mymensingh Area		-		0.00		345		-		-	
Sylhet Area		-		0.00		281		-		-	
Barisal Area		-		0.00		125		-		-	
Rangpur Area		-		0.00		353		-		-	
Total		0		5511		0					
Information of the Generating machines under shut down.											
Planned Shut- Down						Forced Shut- Down					
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 10) Barapukuria ST: Unit-1 (20/11/2014)					
						2) Ashuganj ST: Unit-1(23/08/2014) 11) Ghorasal ST: Unit-5 (23/11/2014)					
						4) Baghabari 71 MW (22/10/2014) 12) Baghabari GT 100 MW (01/12/2014)					
						5) Khulna ST 110 MW (04/11/2014)					
						6) Fenchuganj CCPP-2 ST (07/11/2014)					
						7) Chittagong ST: unit-2 (26/11/2014)					
						8) Ghorashat ST : Unit-4 (11/11/2014)					
						9) Chittagong ST: unit-1 (04/11/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Dohazari - Sikalbaha 132 kV Ckt-2 was shut down from 08:30 to 16:15 due to A/M.											
b) Faridpur - Madaripur 132 kV Ckt-1 was shut down from 08:31 to 16:28 due to A/M.											
c) Kamrangirchar - Kallyanpur 132 kV Ckt was shut down at 08:42 due to isolator replacement work.											
d) Khulna(S) - Khulna @ 132 kV Ckt-1 was shut down from 08:50 to 16:02 due to A/M.											
e) Kabirpur -Tangail 132 kV Ckt-1 was shut down from 09:17 to 13:17 due to A/M.											
f) Magura 132/33 kV T2 Transformer was shut down from 09:02 to 14:38 due to A/M.						About 5 MW Power interruption occurred under Magura S/S areas from 09:02 to 14:38.					
g) Palashbari - Rangpur 132 kV Ckt-2 was shut down from 09:30 to 16:42 due to A/M.											
h) Meghnaghat - Hasnabad 230 kV Ckt-1 was shut down from 08:50 to 17:18 due to A/M.											
i) Bakulia 132 kV bus-2 was shut down from 09:20 to 14:16 due to A/M.											
j) Rampura 230/132 kV Tx-2 Transformer was shut down from 09:39 to 14:22 due to A/M.											
k) After maintenance Khulna 150 MW GT was synchronized at 11:14.											
l) Bhulta - Haripur 132 kV Ckt tripped at 11:56 from Haripur end showing dist. Z1 relay and was switched on at 12:04.						About 32 MW Power interruption occurred under Bhulta S/S areas from 11:57 to 12:10.					
m) Ghorasal - Bhulta 132 kV Ckt tripped at 11:57 from both end and was switched on at 12:10.											
n) Manikganj - Siddirganj 230 kV Ckt-2 tripped at 12:39 from both end showing diff.relay and was switched on at 13:02.											
o) Baghabari 100 MW tripped at 12:45 due to high vibration.											
p) Haripur - Maniknagar - Ullon 132 kV Ckt is shut down from 06:18 to 07:53 (02/12/2014) due to development work.											
Sub Divisional Engineer		Executive Engineer		Superintendent Engineer							
Network Operation Division		Network Operation Division		Load Despatch Circle							