

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 3-Dec-14	
The Summary of Yesterday's (2-Dec-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	4319.0	MW	Hour :	12:00	Min. Gen. at	4:00	3219	MW			
Evening Peak Generation :	6054.0	MW	Hour :	19:00	Max Generation :		6184	MW			
E.P. Demand (at gen end) :	6054.0	MW	Hour :	19:00	Max Demand :		6100	MW			
Maximum Generation :	6054.0	MW	Hour :	19:00	Shortage :		-84	MW			
Total Gen. (MKWH) :	99.0	System L/ Factor :		78.37%	Load Shed :		0	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-170		MW	at	17:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum						MW	at		Energy	-	MKWHR.
Actual : 87.64				Water Level of Kaptai Lake at 6:00 A M on		3-Dec-14					
				Ft.(MSL) ,		Rule curve :		105.82		Ft.(MSL)	
Gas Consumed : Total				750.40		MMCFD.		Oil Consumed (PDB) :			
								HSD :		Liter	
								FO :		Liter	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas :		Tk60,117,285					
				Coal :		Tk8,046,671		Oil :		Tk199,754,782 Total : Tk267,918,738	
Load Shedding & Other Information											
Area	Yesterday				Today						
	MW		Estimated Demand(s/s end)		Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)				
			MW		MW						
Dhaka	-	0.00	2280		-		-				
Chittagong Area	-	0.00	583		-		-				
Khulna Area	-	0.00	636		-		-				
Rajshahi Area	-	0.00	619		-		-				
Comilla Area	-	0.00	427		-		-				
Mymensingh Area	-	0.00	355		-		-				
Sylhet Area	-	0.00	289		-		-				
Barisal Area	-	0.00	128		-		-				
Rangpur Area	-	0.00	363		-		-				
Total	0		5680		0						
Information of the Generating machines under shut down.											
Planned Shut- Down				Forced Shut- Down							
1) Haripur GT: Unit-3 (18/06/2009)				1) Ghorasal ST: Unit-6 (18/07/2010)				10) Barapukuria ST: Unit-1 (20/11/2014)			
				2) Ashuganj ST: Unit-1(23/08/2014)				11) Ghorasal ST: Unit-5 (23/11/2014)			
				4) Baghabari 71 MW (22/10/2014)				12) Baghabari GT 100 MW (01/12/2014)			
				5) Khulna ST 110 MW (04/11/2014)				13) Khulna 150 MW (01/12/2014)			
				6) Fenchuganj CCPP-2 ST (07/11/2014)				14) Sikalbaha 150 MW (01/12/2014)			
				7) Chittagong ST: unit-2 (26/11/2014)							
				8) Ghorashat ST : Unit-4 (11/11/2014)							
				9) Chittagong ST: unit-1 (04/11/2014)							
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Hasnabad - Meghnaghat 230 kV Ckt-2 was shut down from 08:14 to 17:10 due to A/M.											
b) Feni - Comilla(N) 132 kV Ckt-1 was shut down from 08:37 to 15:28 due to A/M.											
c) Ashuganj - Kishoreganj 132 kV Ckt-2 was shut down from 08:40 to 17:34 due to A/M.											
d) Hathazari 230/132 kV T4 Transformer was shut down from 08:25 to 13:30 due to A/M.											
e) Dohazari - Sikalbaha 132 kV Ckt-2 was shut down from 08:35 to 17:05 due to A/M.											
f) Faridpur - Madaripur 132 kV Ckt-1 was shut down from 08:24 to 15:05 due to A/M.											
g) Ashuganj - Ghorasal 230 kV Ckt-2 was shut down from 09:12 to 15:28 due to loop connector maintenance work of tower # 93.											
h) Aminbazar 132 kV capacitor bank was shut down from 09:10 to 15:30 due to A/M.											
i) Tongi - Mirpur 132 kV Ckt was shut down from 09:20 to 21:10 due to dead line checking.											
j) Matuail 132/33 kV GT-2 Transformer was shut down from 09:13 to 16:25 due to A/M.											
k) Palashbari - Rangpur 132 kV Ckt-1 was shut down from 09:15 to 16:34 due to A/M.											
l) Khulna(S) - Khulna© 132 kV Ckt-1 was shut down from 09:08 to 15:02 due to A/M.											
m) Jhenidah - Magura 132 kV Ckt was shut down from 09:18 to 16:54 due to A/M.											
n) Joydabpur 132/33 kV GT-2 transformer was shut down from 10:44 to 16:10 due to A/M.											
o) Agargoan - Satmosjid 132 kV Ckt-1 & 2 were switched on at 11:54 & 12:30 respectively.											
p) Seraiganj 132/33 kV T3 Transformer was shut down from 13:20 to 17:44 due to CT test.											
q) Gopalganj Peaking tripped at 20:46 due to tripping of auxiliary boiler.											
r) Siddhirganj S/S - Dutch Bangla Ckt is under shut down since at 06:20 (3/12/14) due to project work.											
s) Ashuganj - Ghorasal 132 kV Ckt-1 is under shut down since at 07:19 (3/12/14) due to dead line checking.											
t) Modunaghat - Chandraghona 132 kV Ckt is under shut down since at 07:17 (03/12/14) due to A/M.											
Sub Divisional Engineer						Executive Engineer					
Network Operation Division						Network Operation Division					
						Superintendent Engineer					
						Load Despatch Circle					