

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 4-Dec-14	
The Summary of Yesterday's (3-Dec-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	4470.0	MW	Hour :	12:00	Min. Gen. at	4:00	3256	MW			
Evening Peak Generation :	6055.0	MW	Hour :	19:00	Max Generation :		6160	MW			
E.P. Demand (at gen end) :	6055.0	MW	Hour :	19:00	Max Demand :		6100	MW			
Maximum Generation :	6055.0	MW	Hour :	19:00	Shortage :		-60	MW			
Total Gen. (MKWh) :	106.1	System L/ Factor :		78.37%	Load Shed :		0	MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-230		MW	at	17:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum				-		MW	at	-	Energy	-	MKWHR.
Actual :		87.64		Water Level of Kaptai Lake at 6:00 A M on				4-Dec-14			
		Ft.(MSL) ,		Rule curve :		105.73		Ft.(MSL)			
Gas Consumed : Total		772.85		MMCFD.		Oil Consumed (PDB) :		HSD :		Liter	
								FO :		Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk61,902,559							
		Coal :		Tk8,437,288		Oil :		Tk195,415,798		Total : Tk265,755,646	
Load Shedding & Other Information											
Area	Yesterday						Today				
	MW		Estimated Demand(s/s end)				Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)		
			MW				MW				
Dhaka	-	0.00	2217				-		-		
Chittagong Area	-	0.00	565				-		-		
Khulna Area	-	0.00	616				-		-		
Rajshahi Area	-	0.00	601				-		-		
Comilla Area	-	0.00	415				-		-		
Mymensingh Area	-	0.00	346				-		-		
Sylhet Area	-	0.00	281				-		-		
Barisal Area	-	0.00	125				-		-		
Rangpur Area	-	0.00	354				-		-		
Total	0		5520				0				
Information of the Generating machines under shut down.											
	Planned Shut- Down					Forced Shut- Down					
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 3) Baghabari 71 MW (22/10/2014) 4) Khulna ST 110 MW (04/11/2014) 5) Fenchuganj CCPP-2 ST (07/11/2014) 6) Chittagong ST: unit-2 (26/11/2014) 7) Chittagong ST: unit-1 (04/11/2014) 8) Barapukuria ST: Unit-1 (20/11/2014) 10) Ghorasal ST: Unit-5 (23/11/2014) 11) Baghabari GT 100 MW (01/12/2014) 12) Sikalbaha 150 MW (01/12/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) After maintenance Ghorasal # 4 was synchronous at 14:04. b) Feni - Comilla(N) 132 kV Ckt-1 was shut down from 08:32 to 15:55 due to A/M. c) Shitalakkhya - Madanganj 132 kV Ckt was shut down from 08:43 to 16:50 due to A/M. d) Barapukuria 132/33 kV T4 Transformer was shut down from 08:50 to 15:17 due to A/M. e) Khulna(S) - Khulna@ 132 kV Ckt-2 was shut down from 09:55 to 15:34 due to A/M. f) Faridpur - Madaripur 132 kV Ckt-1 was shut down from 08:24 to 15:05 due to A/M. g) Tongi - Mirpur 132 kV Ckt was shut down from 09:13 to 18:08 due to A/M. h) Hathazari 132/33 kV T1 Transformer was shut down from 09:10 to 17:16 due to A/M. i) Rampura - Gulshan 132 kV Ckt-1 was shut down from 09:18 to 16:56 due to A/M j) Palashbari - Rangpur 132 kV Ckt-2 was shut down from 09:35 to 16:55 due to A/M. k) Mymensingh-Netrokona 132 kV Ckt-2 was shut down from 09:41 to 16:29 due to A/M l) Tangail -Kabirpur 132 kV Ckt-2 was shut down from 09:41 to 14:03 due to A/M. m) Sreemongal - Fenchuganj 132 kV Ckt-1 was shut down from 09:50 to 16:55 due to A/M. n) Pabna 132/33 kV T1 Transformer was shut down from 09:19 to 16:43 due to A/M. o) Naogaon-Bogra 132 kV Ckt-1 was shut down from 08:00 to 16:20 due to A/M. p) Rampura 132 kV Capacitor bank was shut down since at 15:36 due to maintain the voltage level. q) Sylhet 132/33 kV T1 Transformer is under shut down since at 06:25 (04/12/2014) due to A/M. r) Meghnaghat - Hasnabad 230 kV Ckt-1 tripped at 06:35 (04/12/14) showing Z2, Z3 at Meghnaghat end and Z1 & E/F at Hasnabad end and was switched on at 07:48 (04/12/14). s) Tongi 230/132 kV T03 transformer tripped at 06:42 (04/12/14) due to R phase lightning arrester burst showing O/C at 132 kV side. t) Madunaghat -Chandraghona 132 kV Ckt is under shut down since at 07:11 (04/12/14) due to A/M.											
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Despatch Circle					