

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 5-Dec-14		
The Summary of Yesterday's (				4-Dec-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :		4458.0		MW		Hour :		12:00		Min. Gen. at 5:00 3277 MW		
Evening Peak Generation :		5972.0		MW		Hour :		19:00		Max Generation : 6002 MW		
E.P. Demand (at gen end) :		5972.0		MW		Hour :		19:00		Max Demand : 5900 MW		
Maximum Generation :		5972.0		MW		Hour :		19:00		Shortage : -102 MW		
Total Gen. (MKWH) :		100.3		System L/ Factor :				78.37%		Load Shed : 0 MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR												
Export from East grid to West grid :- Maximum				-220		MW at		17:00		Energy 7.867 MKWHR.		
Import from West grid to East grid :- Maximum				-		MW at		-		Energy - MKWHR.		
Water Level of Kaptai Lake at 6:00 A M on								5-Dec-14				
Actual :		87.64		Ft.(MSL) ,		Rule curve :		105.64		Ft.( MSL )		
Gas Consumed : Total		790.42		MMCFD.		Oil Consumed (PDB) :				HSD : Liter		
										FO : Liter		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk59,010,735								
		Coal :		Tk8,476,352		Oil :		Tk163,976,931		Total : Tk231,464,017		
Load Shedding & Other Information												
Area	Yesterday		Estimated Demand(s/s end)				Today		Estimated Shedding (s/s end)		Rates of Shedding	
	MW		MW				MW		(On Estimated Demand)			
Dhaka	-	0.00				2157		-		-		
Chittagong Area	-	0.00				548		-		-		
Khulna Area	-	0.00				597		-		-		
Rajshahi Area	-	0.00				583		-		-		
Comilla Area	-	0.00				403		-		-		
Mymensingh Area	-	0.00				337		-		-		
Sylhet Area	-	0.00				274		-		-		
Barisal Area	-	0.00				122		-		-		
Rangpur Area	-	0.00				345		-		-		
Total	0		5366				0					
Information of the Generating machines under shut down.												
	Planned Shut- Down						Forced Shut- Down					
	1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 10) Ghorasal ST: Unit-5 (23/11/2014) 2) Ashuganj ST: Unit-1(23/08/2014) 11) Baghabari GT 100 MW (01/12/2014) 3) Baghabari 71 MW (22/10/2014) 12) Sikalbaha 150 MW (01/12/2014) 5) Khulna ST 110 MW (04/11/2014) 13) Ashuganj Unit-5 (05/12/2014) 6) Fenchuganj CCPP-2 ST (07/11/2014) 7) Chittagong ST: unit-2 (26/11/2014) 8) Chittagong ST: unit-1 (04/11/2014) 9) Barapukuria ST: Unit-1 (20/11/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.												
Description							Forced load shaded / Interrupted Areas					
a) Ashuganj-Kishorganj 132 kV Ckt-1 was under shut down from 08:30 to 15:03 due to A/M. b) Ghorasal-Ashuganj 132 kV Ckt-1 was under shut down from 08:45 to 17:38 due to A/M. c) Bogra 230/132 kV T2 transformer was under shut down from 09:40 to due to project work. d) Hasnabad-Aminbazar 230 kV Ckt-1 was under shut down from 08:41 to 11:59 due to A/M. e) Hathazari-Feni 132 kV Ckt-1 was under shut down from 08:57 to 16:20 due to A/M. f) Khulna (S)-Khulna @ 132 kV Ckt-2 was under shut down from 09:37 to 15:25 due to A/M. g) Aminbazar-Kallyanpur 132 kV Ckt-2 was under shut down from 09:21 to 16:55 due to A/M. h) Hasnabad-Aminbazar 230 kV Ckt-2 was under shut down from 11:59 to 15:17 due to A/M. i) Madanganj-Munshiganj 132 kV Ckt-1 was under shut down from 09:46 to 16:20 due to A/M j) Kabirpur-Tangail 132 kV Ckt-2 was under shut down from 09:10 to 17:28 due to A/M. k) Fenchuganj-Sreemongal 132 kV Ckt-1 was under shut down from 09:44 to 16:24 due to A/M l) Mymensingh-Netrokona 132 kV Ckt-2 was under shut down from 09:55 to 14:59 due to A/M. m) Haripur-Matuail 132 kV Ckt was under shut down from 10:35 to 14:59 due to A/M. n) Hasnabad 230/132 kV T2 transformer tripped at 10:55 showing without any relay and was switched on at 11:25. o) Naogaon-Bogra 132 kV Ckt-1 was under shut down from 08:15 to 16:40 due to A/M. p) Chapainawabganj 132/33 kV T3 transformer was under shut down from 09:27 to 17:10 due to A/M. q) Ghorasal 132/33 kV 1T transformer was under shut down from 15:20 to 15:45 due to gas filling of incomer breaker. r) Ullon-Rampura 132 kV under ground Ckt-1 was shut down at 07:35 (05/12/2014) due to maintenance works. s) Rampura-Moghbazar 132 kV Ckt-2 was shut down at 07:37 (05/12/2014) due to maintenance work. t) Dutchbangla P/S-Siddhirganj S/S 132 kV Ckt was shut down at 06:40 (05/12/2014) due to project work. u) Hasnabad-Lalbagh 132 kV Ckt was shut down at 07:15 (05/12/2014) due to A/M. v) Hasnabad-Keraniganj-Kallyanpur 132 kV Ckt was shut down at 07:15 (05/12/2014) due to A/M. w) Ashuganj-Seraiganj 230 kV Ckt-2 was shut down at 05:55 (05/12/2014) due to 450 MW P/S project work. x) Madanganj-Madanganj Summit 132 kV Ckt was shut down at 05:50 (05/12/2014) due to power station works. y) Halishahar 132/33 kV T3 transformer was shut down at 07:25 (05/12/2014) due to A/M.												
Sub Divisional Engineer Network Operation Division							Executive Engineer Network Operation Division					
							Superintendent Engineer Load Despatch Circle					