

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 10-Dec-14			
The Summary of Yesterday's (9-Dec-14		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand					
Day Peak Generation :		4326.0		MW		Hour :		12:00		Min. Gen. at 4:00 3086 MW			
Evening Peak Generation :		5980.0		MW		Hour :		18:30		Max Generation : 6015 MW			
E.P. Demand (at gen end) :		5980.0		MW		Hour :		18:30		Max Demand : 6000 MW			
Maximum Generation :		5980.0		MW		Hour :		18:30		Shortage : -15 MW			
Total Gen. (MKWH) :		101.6		System L/ Factor :				78.37%		Load Shed : 0 MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR													
Export from East grid to West grid :- Maximum				-240		MW		at 3:00		Energy 7.867 MKWHR.			
Import from West grid to East grid :- Maximum				-		MW		at -		Energy - MKWHR.			
Actual :		87.64		Ft.(MSL) ,		Rule curve :		105.19		Ft.(MSL)			
Gas Consumed : Total		762.36		MMCFD.		Oil Consumed (PDB) :				HSD : Liter			
										FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk59,353,062									
		Coal :		Tk8,554,472		Oil :		Tk201,713,192		Total : Tk269,620,726			
Load Shedding & Other Information													
Area		Yesterday				Today							
		MW				Estimated Demand(s/s end)				Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)	
		MW				MW				MW			
Dhaka		oad shed (S/S en) 0.00				2156				-		-	
Chittagong Area		MW 0.00				548				-		-	
Khulna Area		- 0.00				597				-		-	
Rajshahi Area		- 0.00				583				-		-	
Comilla Area		- 0.00				403				-		-	
Mymensingh Area		- 0.00				337				-		-	
Sylhet Area		- 0.00				274				-		-	
Barisal Area		- 0.00				122				-		-	
Rangpur Area		- 0.00				345				-		-	
Total		0				5365				0			
Information of the Generating machines under shut down.													
		Planned Shut- Down				Forced Shut- Down							
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 10) Baghabari GT 100 MW (01/12/2014) 2) Ashuganj ST: Unit-1(23/08/2014) 11) Sikkabaha 150 MW (01/12/2014) 4) Baghabari 71 MW (22/10/2014) 12) Ashuganj Unit-5 (05/12/2014) 5) Khulna ST 110 MW (04/11/2014) 6) Fenchuganj CCBP-2 ST (07/11/2014) 7) Chittagong ST: unit-2 (26/11/2014) 8) Chittagong ST: unit-1 (04/11/2014) 9) Barapukuria ST: Unit-1 (20/11/2014)							
Additional Information of Machines. lines. Interruption / Forced Load shed etc.													
Description						Forced load shaded / Interrupted Areas							
a) Cox's bazar-Dohazari 132 kV Ckt-2 was shut down from 07:55 to 16:37 due to A/M. b) Haripur-Shyampur 132 kV Ckt was shut down from 08:50 to 17:06 due to A/M c) Bogra-Palashbari 132 kV Ckt-2 was shut down from 09:3 to 16:17 due to A/M. d) Ishurdi 132/33 kV T2 Transformer was shut down from 09:17 to 17:44 due to oil leakage from 132 kV bushing. e) Khulna-Gopalpara 132 kV Ckt-2 was shut down from 09:27 to 14:53 due to A/M. f) Hathazari 132/33 kV T2 Transformer was shut down from 09:36 to 13:01 due to A/M. g) Haripur-Rampura 230 kV Ckt-1 was shut down from 09:42 to 15:26 due to A/M. h) After maintenance Haripur EGCB 412 MW was synchronized at 12:12. i) Kabirpur 132/33 kV T1 Transformer was shut down from 10:55 to 15:43 due to A/M. j) Haripur EGCB 412 MW was forced shut down at 22:50 due to differential pressure high of air filter. k) Comilla(n)-Meghnaghat 230 kV Ckt-2 was shut down from 08:24 to 16:35 due to A/M. l) Rangpur-Barapukuria 132 kV Ckt-1 was shut down from 08:40 to 15:30 due to A/M. m) Netrokona 132/33 kV T3 transformer was shut down from 10:03 to 16:20 due to A/M. n) Faridpur-Madaripur 132 kV Ckt-2 was shut down from 10:10 to 16:42 due to A/M. o) Barapukuria 132/33 kV T4 Transformer was shut down from 16:50 to 17:10 due to conservator oil leakage. p) Ashuganj-Kishoreganj 132 kV Ckt-2 is under shut down since at 07:08 due to A/M. q) Sylhet-Fenchuganj 132 kV Ckt is under shut down since at 07:29 due to A/M.													
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division							
						Superintendent Engineer Load Despatch Circle							