## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT OF-LDC-08 Page -1 Reporting Date: 10-Mar-15 Till now the maximum generation is: 7418 MW 21:00 Hrs on 18-Jul-14 The Summary of Yesterday's 9-Mar-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 5989.0 MW Hour: 12:00 Min. Gen. at 4:00 4296 MW 7252 Evening Peak Generation : 6622.0 MW Hour: 20:00 Max Generation MW 6622.0 20:00 Max Demand MW E.P. Demand (at gen end) : MW 7150 Hour: Maximum Generation 6622.0 MW 20:00 Shortage -102 MW Hour: Total Gen. (MKWH) 128.1 System L/ Factor 80.61% Load Shed 0 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW at 24:00 Energy 7.867 MKWHR Import from West grid to East grid :- Maximum MW MKWHR Water Level of Kaptai Lake at 6:00 A M on 10-Mar-15 87.64 Ft.(MSL) 91.56 Ft.( MSL.) Actual Rule curve 907.08 MMCFD. Gas Const Total Oil Consumed (PDB): HSD : Liter FO : Liter Cost of the Consumed Fuel (PDB+Pvt): Gas Tk69,160,748 Coal Tk16,952,700 Oil : Tk289,664,772 Total: Tk375,778,220 Load Shedding & Other Information Yesterday Today Area Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 2512 648 0:00 Chittago 0:00 709 Khulna A Rajshahi 0:00 686 472 Comilla 0:00 0:00 388 Mymens Sylhet A 0:00 316 Barisal A 0:00 140 Rangpur 0:00 397 Total 6268 0 0 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 3) Khulna ST 110 MW (04/11/2014) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Sikalbaha Peaking GT (01/12/2014) 7) Ghorasal ST:Unit-4 (05/01/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Madaripur 132/33 kV T2 transformer was under shut down from 08:10 to 17:59 due to painting work b) Dohazari-Cox's Bazar 132 kV Ckt-1 was under shut down from 08:18 to 15:50 due to A/M. c) Bhulta-Haripur 132 kV Ckt tripped at 09:36 from Haripur end showing dist.relay and power was fed from Ghorasal through Ghorasal-Bhulta 132 kV Ckt at 09:46. Power interruption occurred (about 89 MW) under Bhulta S/S areas rom 09:36 to 09:46. d) Haripur-Meghnaghat 230 kV Ckt-1 tripped at 09:38 from both end showing phase discordance at Meghnaghat end and VT fail, Z2 at Haripur end and was switched on at 10:20. e) After maintenance Haripur-Bhulta 132 kV Ckt was switched on at 14:43. f) Raozan Unit-2 was synchronized at 15:06. g) Khulshi 132/33 kV T2 transformer (120 MVA new) was taken to the system with load at 17:42. h) Ashuganj 132 kV bus-1 & 230 kV bus-1 tripped at 18:03 showing bus differential relay. At the same time the following Generators also tripped: Power interruption occurred (about 275 MW) under Mymensingh zone except Unit Name Tripping Time Synchronizing time Ashuganj Unit-2 18:03 50 MW 00:45 (10/03/2015) Ashuganj Unit-3 18:03 130 MW 20:45 02:06 (10/03/2015) Ashuganj Unit-5 18:03 135 MW Ashugani GT Unit-2 40 MW 11:43 (10/03/2015) 18:03 50 MW Ashuganj 55 MW 18:03 21:08 Ashuganj Engine 18:03 30 MW 22:15 Ashuganj United 18:03 53 MW 21:32 Ashuganj Aggreko 18:03 95 MW Ashuganj Midland 18:03 45 MW 10 Mymensingh RPCL 18:03 180 MW 18:53 11 B.Baria 85 MW 18:03 61 MW 18:35 Shahjibazar 50 MW 45 MW 18:03 18:10 40 MW Shahjibazar 86 MW 18:03 18:15 Feni 11 MW 18:03 10.7 MW 18:44 Total about 969 MW generation tripped Siddhirganj GT 240 MW tripped at 00:16 (10/03/2015) due to gas booster problem. Tongi GT 105 MW was synchronized at 01:08 (10/03/2015).