

Till now the maximum generation is :-				7418 MW	21:00	Hrs	on	18-Jul-14	Reporting Date : 26-Mar-15
The Summary of Yesterday's (25-Mar-15	Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	6349.0	MW	Hour :	12:00	Min. Gen. at	7:00	5125	MW	
Evening Peak Generation :	7308.0	MW	Hour :	19:30	Max Generation :		7135	MW	
E.P. Demand (at gen end) :	7308.0	MW	Hour :	19:30	Max Demand :		7000	MW	
Maximum Generation :	7308.0	MW	Hour :	19:30	Shortage :		-135	MW	
Total Gen. (MKWH) :	148.6	System L/ Factor :		84.71%	Load Shed :		0	MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-110	MW	at	14:00	Energy	7.867
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-
Water Level of Kaptai Lake at 6:00 A M on				26-Mar-15					
Actual :	87.64	Ft.(MSL) ,			Rule curve :	89.00	Ft.(MSL)		
Gas Consumed :	Total	909.84	MMCFD.		Oil Consumed (PDB) :				
					HSD :		Liter		
					FO :		Liter		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk77,250,614						
		Coal :	Tk17,108,944		Oil :	Tk542,662,360	Total :	Tk637,021,919	
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand (S/S end)			Today			
	MW		MW			Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)	
Dhaka	-	0:00	2618			-		-	
Chittagong Area	-	0:00	677			-		-	
Khulna Area	-	0:00	743			-		-	
Rajshahi Area	-	0:00	717			-		-	
Comilla Area	-	0:00	492			-		-	
Mymensingh Area	-	0:00	403			-		-	
Sylhet Area	-	0:00	328			-		-	
Barisal Area	-	0:00	146			-		-	
Rangpur Area	-	0:00	412			-		-	
Total	0		6536			0			
Information of the Generating machines under shut down.									
	Planned Shut- Down				Forced Shut- Down				
	1) Haripur GT: Unit-3 (18/06/2009)				1) Ghorasal ST: Unit-6 (18/07/2010) 09) Sikalbaha 60 MW (18/03/2015) 2) Ashuganj ST: Unit-1(23/08/2014) 10) Ghorasal ST:Unit-3 (22/03/2015) 3) Khulna ST 110 MW (04/11/2014) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Ghorasal ST:Unit-4 (05/01/2015) 7)Chittagong ST: Unit-1 (10/03/2015) 8) Haripur 412 MW CCPP (16/03/2015)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Faridpur S/S-Faridpur P/S 132 kV Ckt-132 kV was under shut down from 09:15 to 12:00 due to maintenance work.					Power interruption occurred (about 50 MW) under Chowmohani S/S area from 18:28 to 18:40. Power interruption occurred (about 110 MW) under Bhandaria, Bagerhat, Mongla & Patuakhali S/S areas from 20:30 to 20:35. Power interruption occurred (about 6 MW) under Kulaura S/S area from 19:59 to 20:07.				
b) Chowmohani 132/33 kV T2 transformer tripped at 18:28 showing dir.O/C relay and was switched on at 18:40.									
c) Halishahar-Julda 132 kV Ckt-1 tripped at 19:55 showing E/F & O/C relays and was switched on at 20:15									
d) Bagerhat-Goalpara 132 kV Ckt tripped at 20:30 showing O/C relay and was switched on at 20:35.									
e) Mirpur-Aminbazar 132 kV Ckt-2 was under shut down from 12:35 to 12:54 due to problem at R-phase CVT loop.									
f) Kulaura 132/33 kV T2 transformer tripped at 19:59 showing dir.O/C relay and was switched on at 20:07.									
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle			