			POWER GRID COMPANY OF BA NATIONAL LOAD DESPA DAILY REPORT	NGLADESH LTD. ATCH CENTER				QF-LDC- Page			
Till now the may	simum generation is		7418 MW	21:00	Hrs on	Reporting Date: 18-Jul-14	28-Mar-15	Luge			
The Summary of		27-Mar-15	Generation & Demand	21.00		Min Gen. & Probabl	e Gen & Dem	and			
Day Peak Generation		5600.0	MW Hour:	12:00	Min. Gen. at	5:00	5201	MW			
Evening Peak Gener		7003.0	MW Hour:	21:00	Max Generation		7424	MW			
E.P. Demand (at ger		7003.0	MW Hour:	21:00	Max Demand	:	7350	MW			
Maximum Generat		7003.0	MW Hour:	21:00	1		-74	MW			
Maximum General Total Gen. (MKWH		136.7	System L/ Factor :	81.31%	Shortage Load Shed	:	-74	MW			
iotai Gen. (MKW F	1) :		System L/ Factor : KPORT / IMPORT THROUGH EAST-WEST		Load Sned		0	MW			
	rid to West grid :- Ma	ximum	-110	MW at	17:00	Energy	7.867	MKWHR.			
import from West g	grid to East grid :- Ma:			MW at	-	Energy	-	MKWHR.			
Actual :		iter Level of Kapta .(MSL),	i Lake at 6:00 A M on	28-Mar-15 Rule curve : 88.68	Ft.(MSL)						
Gas Consumed :	Total	970.20	MMCFD.	Oil Consumed (P							
sas consumed .	Total	970.20	WINICI D.	On Consumed (i	DB) .	HSD :		Liter			
						FO :		Liter			
								Liter			
Cost of the Consum	ned Fuel (PDB+Pvt) :	Gas :	Tk75,117,995								
Cost of the Consun	iled Fuer (FDB+FVI).	Coal :	Tk17,343,316	Oil	: Tk329,298,477	Total · 1	k421,759,789				
		com .	1817,545,510	Oil	. 1k327,270,477	Total	R421,732,762				
	Los	ad Shedding & Otl	ner Information								
Area	Yesterday				Today						
			Estimated Demand (S/S en	d)	Estimated Shedd	. ,	Rates of Shedd				
	MW		MW			MW (On Estimated I	emand)			
Dhaka	-	0:00	2705			-	-				
Chittagong Area	-	0:00	701			-	-				
Khulna Area	-	0:00	770			-	-				
Rajshahi Area	-	0:00	742			-	-				
Comilla Area	-	0:00	509			-	-				
Mymensingh Area	-	0:00	415			-	-				
Sylhet Area	_	0:00	338			_	-				
Barisal Area	_	0:00	150			_	_				
Rangpur Area	_	0:00	425			-	-				
Kangpai / Hea	_	0.00	423								
Total	0		6755			0					
	Information of th	e Generating machi	nes under shut down.								
	Planned Shut- Down			Forced Shut- Dow	n						
	1) Haripur GT: Unit-3 (1	18/06/2009)		1) Ghorasal ST: Ui		09) Sikalbaha 60 MW	(18/03/2015)				
	,			2) Ashuganj ST: U		10) Ghorasal ST:Un		0			
				3) Khulna ST 110 I		.,					
					PP-1 ST (07/11/2014	9)					
					00 MW (01/12/2014						
				6) Ghorasal ST:U							
				7)Chittagong ST: U							
						8) Haripur 412 MW CCPP (16/03/2015)					
			es, Interruption / Forced Load shed etc.								
	Additional Information	on of Machines, lin	s, interruption / Forcea Load shed etc.				Forced load shaded / Interrupted Areas				
	Additional Information	on of Machines, lin	es, interruption/ rorect Load sied etc.	Forced load shade	ed / Interrupted Ar	eas					
	Description		haympur end due to low voltage.	Forced load shade	ed / Interrupted Ar	eas					
a) Hasnabad-Shayr	Description mpur 132 kV Ckt close	ed at 11:12 from Si				reas red under Rajshahi S/S	areas from 15:1	5 to 16:55.			
a) Hasnabad-Shayr b) Rajshahi 33 kV b	Description mpur 132 kV Ckt close ous under T1 transform	ed at 11:12 from Siner was shut down	haympur end due to low voltage.	About 30 MW powe	er interruption occurr						
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33	Description mpur 132 kV Ckt close ous under T1 transform 8 kV T1 transformer wa	ed at 11:12 from Siner was shut down	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault	About 30 MW powe	er interruption occurr er interruption occurr	ed under Rajshahi S/S	areas from 15:2	6 to 15:40			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapar	Description mpur 132 kV Ckt close ous under T1 transform 8 kV T1 transformer wa ra 132 kV Ckt-1,2 tripp	ed at 11:12 from Siner was shut down	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake	About 30 MW powe About 30 MW powe nd were About 228 MW pow	er interruption occurr er interruption occurr ver interruption occu	red under Rajshahi S/S red under Ghorasal S/S	areas from 15:2	6 to 15:40			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapara switched on at 19	Description mpur 132 kV Ckt close bus under T1 transform 8 kV T1 transformer wa ra 132 kV Ckt-1,2 tripp 9:58	ed at 11:12 from Siner was shut down as shut down from ed at 19:53 from J	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a	About 30 MW powe	er interruption occurr er interruption occurr ver interruption occu	red under Rajshahi S/S red under Ghorasal S/S	areas from 15:2	6 to 15:40			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapara switched on at 19 e) Barisal-Patuakha	Description mpur 132 kV Ckt close ous under T1 transform 8 kV T1 transformer wa ra 132 kV Ckt-1,2 tripp 9:58 ali 132 kV Ckt is under	ed at 11:12 from Siner was shut down as shut down from ed at 19:53 from J	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M.	About 30 MW powe r About 30 MW powe nd were About 228 MW pow areas from 19:53 t	er interruption occurr er interruption occurr ver interruption occu o 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen	areas from 15:2 aida,Magura,Chi	6 to 15:40 adanga S/S			
a) Hasnabad-Shayro O Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapar- switched on at 19 e) Barisal-Patuakha f) Sylhet 132/33 kV	Description Impur 132 kV Ckt close Insu under T1 transform I8 kV T1 transformer wa I8 132 kV Ckt-1,2 tripp I9:58 Iali 132 kV Ckt is under I74 transformer was s	ed at 11:12 from Siner was shut down from Jas shut down from Jashut down since 1 shut down from 06:	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M. 30 to 07:52 due to red hot at R phase 33 kV feed	About 30 MW powe In About 30 MW powe Ind were About 228 MW powe Ind were About 228 MW powe Ind were About 30 MW powe Ind About 30 MW powe	er interruption occurrer interruption occurrer interruption occur or 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen red under Sylhet S/S an	areas from 15:2 aida,Magura,Chi eas from 06:30 to	6 to 15:40 uadanga S/S o 07:52.			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapar- switched on at 18: e) Barisal-Patuakha f) Sylhet 132/33 kV g) Shyampur 132/33	Description mpur 132 kV Ckt closes pus under 71 transformer we ra 132 kV Ckt-1,2 tripp 9:58 ali 132 kV Ckt is under 74 transformer was s 3 kV GT3 & GT4 trans	ed at 11:12 from Si ner was shut down as shut down from ed at 19:53 from J shut down since 1 hut down from 06: sformer tripped at 0	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M.	About 30 MW powe In About 30 MW powe Ind were About 228 MW powe Ind were About 228 MW powe Ind were About 30 MW powe Ind About 30 MW powe	er interruption occurrer interruption occurrer interruption occur or 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen	areas from 15:2 aida,Magura,Chi eas from 06:30 to	6 to 15:40 uadanga S/S o 07:52.			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapar- switched on at 19: e) Barisal-Patuakha f) Sylhet 132/33 kV g) Shyampur 132/33	Description mpur 132 kV Ckt closes pus under 71 transformer we ra 132 kV Ckt-1,2 tripp 9:58 ali 132 kV Ckt is under 74 transformer was s 3 kV GT3 & GT4 trans	ed at 11:12 from Si ner was shut down as shut down from ed at 19:53 from J shut down since 1 hut down from 06: sformer tripped at 0	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M. 30 to 07:52 due to red hot at R phase 33 kV feede 07:00(2/03/15) showing back up protection lock o	About 30 MW powe In About 30 MW powe Ind were About 228 MW powe Ind were About 228 MW powe Ind were About 30 MW powe Ind About 30 MW powe	er interruption occurrer interruption occurrer interruption occur or 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen red under Sylhet S/S an	areas from 15:2 aida,Magura,Chi eas from 06:30 to	6 to 15:40 uadanga S/S o 07:52.			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapar- switched on at 19: e) Barisal-Patuakha f) Sylhet 132/33 kV g) Shyampur 132/33	Description mpur 132 kV Ckt closes pus under 71 transformer we ra 132 kV Ckt-1,2 tripp 9:58 ali 132 kV Ckt is under 74 transformer was s 3 kV GT3 & GT4 trans	ed at 11:12 from Si ner was shut down as shut down from ed at 19:53 from J shut down since 1 hut down from 06: sformer tripped at 0	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M. 30 to 07:52 due to red hot at R phase 33 kV feede 07:00(2/03/15) showing back up protection lock o	About 30 MW powe In About 30 MW powe Ind were About 228 MW powe Ind were About 228 MW powe Ind were About 30 MW powe Ind About 30 MW powe	er interruption occurrer interruption occurrer interruption occur or 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen red under Sylhet S/S an	areas from 15:2 aida,Magura,Chi eas from 06:30 to	6 to 15:40 uadanga S/S o 07:52.			
a) Hasnabad-Shayr b) Rajshahi 33 kV b c) Ghorasal 132/33 d) Jessore-Noapar switched on at 19 e) Barisal-Patuakha f) Sylhet 132/33 kV g) Shyampur 132/3: 132 kV end & E/F	Description mpur 132 kV Ckt close sus under T1 transformer wa a 132 kV Ckt-1,2 tripp 9:58 ali 132 kV Ckt is under T4 transformer was s 3 kV GT3 & GT4 trans relay at 33 kV end and	ed at 11:12 from Si ner was shut down as shut down from ed at 19:53 from J shut down since 1 hut down from 06: sformer tripped at 0	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M. 30 to 07:52 due to red hot at R phase 33 kV feede 07:00(Z/03/15) showing back up protection lock of at 07:33,07:34 respectively.	About 30 MW powe In About 30 MW powe Ind were About 228 MW powe Ind were About 228 MW powe Ind were About 30 MW powe Ind About 30 MW powe	er interruption occurrer interruption occurrer interruption occur or 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen red under Sylhet S/S ar red under Sylhet S/S ar red under Shyampur S/S	areas from 15:2 aida,Magura,Chi eas from 06:30 to a areas from 07:0	6 to 15:40 uadanga S/S o 07:52.			
i) Hasnabad-Shayr i) Rajshahi 33 kV b i:) Ghorasal 133/3 i) Jessore-Noapar switched on at 19 i) Barisal-Patuakha j) Sylhet 132/33 kV i) Shyampur 132/3;	Description mpur 132 kV Ckt close sus under T1 transformer wa a 132 kV Ckt-1,2 tripp 9:58 ali 132 kV Ckt is under T4 transformer was s 3 kV GT3 & GT4 trans relay at 33 kV end and	ed at 11:12 from Si ner was shut down as shut down from ed at 19:53 from J shut down since 1 hut down from 06: sformer tripped at 0	haympur end due to low voltage. from 15:15 to 16:55 due to 33 kV feeder fault 15:26 to 15:40 due to gas failure at 33 kV breake essore end showing RYB Z1,Z2,Z3 & E/F relay a 6:18 (28/03/15) due to A/M. 30 to 07:52 due to red hot at R phase 33 kV feede 07:00(2/03/15) showing back up protection lock o	About 30 MW powe In About 30 MW powe Ind were About 228 MW powe Ind were About 228 MW powe Ind were About 30 MW powe Ind About 30 MW powe	er interruption occurrer interruption occurrer interruption occur or 19:58.	red under Rajshahi S/S red under Ghorasal S/S rred under Jessore,Jen red under Sylhet S/S an	areas from 15:2 aida,Magura,Chi eas from 06:30 to a areas from 07:0	6 to 15:40 ladanga S/S o 07:52.			