POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER OF-LDC-08										
Till now the max	ximum generation is :	-	7418 MW	DAILY REPORT	21:00	Hrs on	Reporting Date : 18-Jul-14	8-Apr-15	Page -1	
The Summary of	f Yesterday's (	7-Apr-15	Generation & De	emand		Today's Actual	Min Gen. & Proba	ble Gen. & Den	nand	
Day Peak Generati	on :	5556.0	MW	Hour :	12:00	Min. Gen. at	5:00	2954	MW	
Evening Peak Gene		5663.0	MW	Hour :	18:30	Max Generation	:	6822	MW	
E.P. Demand (at ge		5663.0	MW	Hour :	18:30	Max Demand	:	6500	MW	
Maximum Genera		5885.0	MW	Hour :	15:00	Shortage	:	-322	MW	
Total Gen. (MKW)	H) :	114.3	System L/ Factor		80.89%	Load Shed	:	0	MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNI Export from East grid to West grid :- Maximum -10 Import from West grid to East grid :- Maximum -				MW at MW at	23:00	Energy Energy	7.867	MKWHR. MKWHR.		
Actual :		r Level of Kapt MSL) ,	ai Lake at 6:00 A M o	n Rule curve	8-Apr-15 : 86.60	Ft.( MSL )				
Gas Consumed :	Total	837.43	MMCFD.		Oil Consumed (	PDB) :	HSD : FO :		Liter Liter	
Cost of the Consumed Fuel (PDB+Pvt) : Gas : Coal :			Tk63,302,734 Tk9,257,577	Oil	: Tk162,417,693	Total :	Tk234,978,005			
	Load	Shedding & Otl	ner Information							
Area	Yesterday					Today				
			I	Estimated Demand (S/S end)		Estimated Shedd		Rates of Shedd		
	MW	0.07		MW			MW	(On Estimated I	Demand)	
Dhaka	-	0:00		2595			-	-		
Chittagong Area	-	0:00		671			-	-		
Khulna Area	-	0:00		735			-	-		
Rajshahi Area	-	0:00		710			-	-		
Comilla Area Mymensingh Area	-	0:00 0:00		488 399			-	-		
Sylhet Area	-	0:00		325			-	-		
Barisal Area	-	0:00		144			-	-		
Rangpur Area	-	0:00		409			-	-		
rungpui i neu	-	0.00		107						
Total	0			6476			0			
	Information of the	Generating machi	nes under shut down.			·				
						Forced Shut- Down				
	1) Haripur GT: Unit-3 (18	/06/2009)			1) Ghorasal ST: U		09) B.Pukuria-2(7/4	4/15)		
					2) Ashuganj ST: U 3) Khulna ST 110					
						MW (04/11/2014) PP-1 ST (07/11/2014	•			
						100 MW (01/12/2014				
					6) Ghorasal ST:Unit-4 (05/01/2015)					
						7) Haripur 412 MW CCPP (16/03/2015)				
					8) Siddhirgonj ST	F (29/03/2015)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.										
	Description				Forced load shad	ed / Interrupted Ar	reas			
				es demand was comparatively low.						
				at 33 kV Savar dairy farm feeder .	About 60 MW power interruption occurred under Saver S/S areas from 09:40 to 15:15.					
				Trip & High speed trip relay	About 52 MW po	About 52 MW power interruption occurred under Ullon S/S areas from 09:40 to 15:15.				
and was switched on at 10:15 respectively. At the same time Ckt-2 was shut down for long time.										
d) Ghorasal-Ishurdi 230 kV Ckt-1 tripped at 11;05 from both end showing Dist.LZ96,DT at Ishurdi end and DST										
relay at Ghorasal end and was switched on at 20:05.										
e) Naogaon 132/33 kV T3 transformer was shut down from 09:52 to 16:40 due to painting work.										
f) Ashuganj-Comilla(N) 230 kV Ckt-1 was under shut down from 09;44 to 12:40 due to red hot maintenance at all phase at Ashuganj end.										
g) Barapukuria unit-2 was shut down at 09:48 due to as superheter tube got burst.										
<ul> <li>g) Barapukurla unit-2 was shut down at 09:48 due to as superneter tube got burst.</li> <li>h) Ashuganj #2 was synchronized at 12:15.</li> </ul>										
<ul> <li>i) Ashuganj #2 was synchronized at 12.15.</li> <li>ii) Ashuganj-Comilla(N) 230 kV Ckt-2 was under shut down from 16:24 to 04:08(08/04/2015) due to maintenance work.</li> </ul>										
	<ul> <li>i) Ishurdi-Baghabari 132 kV Ckt tripped at 16:15 from both end showing CAT,CD,CE at Ishurdi end and Dist. Z1 B-phase</li> </ul>									
at Baghabari e	nd and was switched	on at 16:54.								
k) Ishurdi-Baghabari 132 kV Ckt tripped at 18:15 from both end showing CAR,CAS,CE at Ishurdi end and Dist. Z1 Y-phase										
at Baghabari end and was switched on at 20:12. And was again tripped at 21:22 due to same region										
I) Ishurdi 132/33 kV T2 transformer tripped at 18:46 showing E/F relay and was switched on at 18:58.										
m) Kallyanpur-Lalbag Ckt-1 & 2 were shut down at 19:16 due to Hasnabad-Lalbag line over load .										
n) Sirajganj 132/33 kV T3 transformer was shut down from 17:17 to 17:40 due to LT bushing tightening.										
<ul> <li>Nator-Rajlanka 132 kV Ckt tripped at 18:25 from both end showing under voltage and was switched on at 19:13.</li> <li>Siddirganj-Ullon 132/ kV Ckt was shut down at 21:19 due to red hot maintenance at Siddirganj end.</li> </ul>										
<ul> <li>g) Bhandaria-Bagerhat 132 kV Ckt tripped at 21:25 showing Dist relay and was switched on at 21:32.</li> </ul>					İ					
<ul> <li>r) Bhandaria-Bagemat 132 kV Ckt tripped at 21:25 showing Dist relay and was switched on at 21:32.</li> <li>r) Bhandaria-Barisal 132 kV Ckt tripped at 21:25 showing Dist relay and was switched on at 23:40.</li> </ul>										
s) Bagherhat-Mongla 132 kV Ckt tripped at 21:25 showing Dist. Z1, ABC relay and was switched on at 23:40.										
t) Madaripur-Faridpur 132 kV Ckt-2 tripped at 21:24 showing Dist. relay and was switched on at 00:20(08/04/2015).										
u) Madaripur-Gopalganj 132 kV Ckt was shut down from 22:04 to 23:45due to transformer breaker problem.										
<ul> <li>v) Raozan ST 1 tripped at 22:57 suspected voltage fluctuation due to bad weather around Raozan and was</li> </ul>										
synchronized at 06:55(08/04/2015)										
w) Siddhirganj-Ullon 132 kV Ckt-2 was shut down at 06:59(08/04/2015) due to red hot maintenance at isolator										
925 M at Ullon end.										
x) Kabirpur-Joydabpur 132 kV Ckt-2 was shut down at 07:12(08/04/2015) due to project work.										
					1					

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle