POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date: 16-Apr-15 7571 MW 21:00 Till now the maximum generation is: Hrs on 15-Apr-15 15-Apr-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's (6509.0 Hour: 12:00 Day Peak Generation Min. Gen. at 5898 Max Generation Evening Peak Generation 7571.0 MWHour: 21:00 7616 MWE.P. Demand (at gen end): 7571.0 MW 21:00 Max Demand 7600 MWHour: Maximum Generation 7571.0 MW 21:00 Shortage -16 MWHour: Total Gen. (MKWH) 152.0 System L/ Factor 83.67% Load Shed 0 MWEXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 15:00 MKWHR. -100 Energy 7.867 Import from West grid to East grid :- Maximum MW Energy MKWHR. at Water Level of Kaptai Lake at 6:00 A M on 16-Apr-15 87.64 Ft.(MSL) Ft.(MSL) Rule curve 85.00 Actual : 1002.08 MMCFD. Gas Consumed: Total Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt): Tk80,084,253 Gas : Coal Tk15,663,661 Oil : Tk494,327,459 Total: Tk590,075,373 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0.00 2819 Chittagong Area 0:00 733 Khulna Area 0:00 806 Rajshahi Area 0.00 775 Comilla Area 0:00 531 Mymensingh Area 0.00 431 Sylhet Area 0.00 351 Barisal Area 0.00 156 Rangpur Area 0:00 441 Total 0 7043 0 Information of the Generating machines under shut down Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 09) Siddiganj GT-2(8/4/15) 2) Ashuganj ST: Unit-1(23/08/2014) 10) Fenchuganj GT-3,4,ST(8/4/15) 3) Khulna ST 110 MW (04/11/2014) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Ghorasal ST:Unit-4 (05/01/2015) 7) Haripur 412 MW CCPP (16/03/2015) 8) Siddhirgonj ST (29/03/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Sreemongal-Fenchuganj 132 kV Ckt-2 was under shut down from 09:16 to 16:34 due to A/M. b) Kabirour-Joydeypur 132 kV Ckt-1 was under shut down from 09:30 to 17:55 for kadda 150 MW project work. c) Hathazari-Madnahat 132 kV Ckt-1 tripped at 09:57 from Madnahat end showing Dist. Relay and switched on at 10:55 d) Bibiyana-Gas turbine (Bibiyana) 400 kV line was shut down at 11:15 for metering & protection test. e) Chittagong ECPV 108 MW tripped at 15:40 due to cable problem and synchronized at 16:20. f) Sirajgonj CCPP tripped at 17:18 due to RMS problem and synchronized at 20:13. g) Ghorashal 230/132 kV AT1 Auto transformer tripped at 06:25 from 230 kV side showing failure of phase to switch force tripping and was switched on at 07:05. n) Dohazari 132/33 kV T1& T2 Transformers were shut down at 07:03 due to red hot at 33 kV side and were switched About 30 MW power interruption occurred under Dohazari S/S areas from 07:03 to 08:45. on at 08:45.

About 5 MW power interruption occurred under Natore S/S areas

Superintendent Engineer

Load Dispatch Circle

from 07:44 to 08:14.

) Saidpur 132/33 kV T3 Transformer was under shut down from 13:65 to15:25 due to red hot at L/T sideY-phase

Executive Engineer

Network Operation Division

Natore 132/33 kV T1 Transformer was shut down from 07:44 to 08:14 due to red hot at 33 kV incomer CB.

Sub Divisional Engineer

Network Operation Division