

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-				8122 MW	21:00	Hrs on		Reporting Date : 7-Jul-15	
The Summary of Yesterday's (6-Jul-15				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	6697.0	MW	Hour :	12:00	Min. Gen. at	7:00	6025		
Evening Peak Generation :	8122.0	MW	Hour :	21:00	Max Generation :		8342		
E.P. Demand (at gen end) :	8122.0	MW	Hour :	21:00	Max Demand :		8200		
Maximum Generation :	8122.0	MW	Hour :	21:00	Shortage :		-142		
Total Gen. (MKWH) :	167.4	System L/ Factor :		85.89%	Load Shed :		0		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-270	MW	a 11:00	Energy	7.867	
Import from West grid to East grid :- Maximum				-	MW	a -	Energy	-	
Water Level of Kaptai Lake at 6:00 A M on				7-Jul-15					
Actual :		87.64	Ft.(MSL) ,	Rule curve :	84.16	Ft.(MSL)			
Gas Consumed :	Total	1148.52	MMCFD.	Oil Consumed (PDB) :		HSD : FO :			
Cost of the Consumed Fuel (PDB+Pvt) :				Gas :	Tk79,424,181	Oil :		Tk435,720,339	Total : Tk527,917,639
Coal :				Tk12,773,120					
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand (S/S end)		Today		Rates of Shedding (On Estimated Demand)		
	MW		MW		Estimated Shedding (S/S end)				
Dhaka	-	0:00	3073						
Chittagong Area	-	0:00	794						
Khulna Area	-	0:00	886						
Rajshahi Area	-	0:00	828						
Comilla Area	-	0:00	635						
Mymensingh Area	-	0:00	483						
Sylhet Area	-	0:00	361						
Barisal Area	-	0:00	169						
Rangpur Area	-	0:00	469						
Total	0		7698		0				
Information of the Generating machines under shut down.									
	Planned Shut- Down				Forced Shut- Down				
	1) Meghanaghat GT-1 (29/05/2015)				1) Ghorasal ST: Unit-6 (18/07/2010)		9) Sylhet 150 MW GT(06/07/2015)		
					2) Ashuganj ST: Unit-1(28/04/2015)		10) Ashuganj 225 MW(GT)(06/07/2015)		
					3) Khulna ST 110 MW (04/11/2014)				
					4) Ghorasal ST: Unit-4 (05/01/2015)				
					5) Haripur GT 3 (24/05/2015)				
					6) Meghnaghat CCPP-ST:(21/04/2015)				
					7) Fenchuganj New ST(31/5/15)				
					8) Haripur-412 MW (25/5/15)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Bheramara-Bottail 132 kV Ckt-1 was under shut down from 08:08 to 15:39 due to project work.									
b) After maintenance Meghnaghat GT-2 was synchronized at 09:12.									
c) Halishahar-Julda 132 kV Ckt tripped at 13:02 from both end showing dist.relay at Halishahar end and E/F relay at Julda end and was switched on at 13:10.									
d) Mirpur 132/33 kV T1 & T3 transformers tripped at 15:15 showing differential relay and was switched on at 15:20.					About 74 MW Power interruption occurred under Mirpur S/S area from 15:15 to 15:20.				
e) Ashuganj 225 MW CCPP GT tripped at 17:03 due to gas leakage.									
f) Comilla (N)-Hathazari 230 kV Ckt-1 was switched on at 16:19.									
g) Tongi GT was forced shut down at 23:08 due to air filter problem.									
h) Meghnaghat GT-2 (450 MW CCPP) was shut down at 23:59 for checking & inspection.									
i) Ashuganj-Kishorganj 132 kV Ckt-1 & 2 tripped at 02:53 (07/07/2015) showing dist.relay and were switched on at 02:57 & 03:02 (07/07/2015) respectively.					About 333 MW Power interruption occurred under Mymensingh, Jamalpur, Netrokona, Sherpur & Kishorganj S/S areas from 02:53 to 02:57 (07/07/2015).				
j) Bheramara-Bottail 132 kV Ckt-1 is under shut down since 07:43 (07/07/2015) due to 360 MW power station project work.									
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle			

MW
MW
MW
MW
MW

MKWHR.
MKWHR.

Liter
Liter