## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date: 2-Sep-15 13-Aug-15 Till now the maximum generation is:-8177 MW Hrs The Summary of Yesterday's ( Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 1-Sep-15 Day Peak Generation 6201.0 MW Hour 12:00 Min. Gen. at 7:00 5052 Evening Peak Generation 7606.0 MW 8075 MW Hour : 20:00 Max Generation E.P. Demand (at gen end): 7486.0 MW Hour : 20:00 Max Demand 7900 MW Maximum Generation 7606.0 MW Hour : 20:00 Shortage -175 мw Total Gen (MKWH) 147 8 System L/ Factor 80 98% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -30 MW at 8:00 Energy 7.867 MKWHR Import from West grid to East grid :- Maximum MW Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 2-Sep-15 107.98 Ft.(MSL) 99.23 Ft.( MSL) Rule curve : 1068.00 MMCFD. Gas Consumed Total Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk62 467 714 Coal Tk7,851,367 : Tk360,837,573 Total: Tk431,156,654 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding ΜW MW(On Estimated Demand) Dhaka 0:00 2975 Chittagong Area 0.00 767 Khulna Area 0:00 855 Rajshahi Area 0:00 800 Comilla Area 0:00 616 0:00 469 Mymensingh Area 350 Sv lhet Area 0:00 Barisal Area 0.00 164 454 Rangpur Area 0.00 Total 7450 Information of the Generating machines under shut down

Planned Shut- Down	Forced Shut- Down
	1) Ghorasal ST: Unit-6 (18/07/2010) 9) Ashuganj 225 MW CCPP (27/08/2015)
	2) Ashuganj ST: Unit-1(28/04/2015) 10) Meghnaghat CCPP ST
	3) Khulna ST 110 MW (04/11/2014) 11) Sikalbaha ST (30/08/2015)
	4) Ghorasal ST: Unit-4 (05/01/2015)
	5) Haripur GT-3 ( 24/05/2015)
	6) Siddhirgonj ST(30/07/2015)
	7) Haripur-412 MW (25/5/15)
	8) Barapukuria ST: Unit-1 (01/09/2015)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Sirajgani 132/33 kV/T2 transformer was under shut down from 11:15 to 13:20 due to ail filing to main tank	<u> </u>

- b) After maintenance Sikalbaha Peaking GT was synchronized at 13:15.
- c) Meghnaghat CCPP GT-1 was shut down at 09:34 due to controller failure and was synchronized at 01:48 (02/09/2015).
- d) Sylhet 150 MW GT tripped at 15:27 due to main transformer problem and was synchronized at 19:38.
- e) Bheramara-G.K Project 132 kV Ckt tripped at 14:35 showing E/F due to LA burst and was switched on at 16:20.
- f) Baghabari 71 MW tripped at 17:01 due to gas control valve problem and was synchronized at 19:55. Again shut down at 04:45 (02/09/2015) due to same reason.
- g) Agargaon-Bhasantec 132 kV Ckt-2 tripped at 18:08 from both end showing E/F & O/C at Y-phase.
- h) Barisal 33 kV bus was shut down from 16:13 to 16:49 due to red hot at bus coupler breaker terminal.

About 67 MW pow er interruption occurred under Barisal S/S area

from 16:13 to 16:49.

Sub Divisional Engineer Network Operation Division

**Executive Engineer** Network Operation Division Superintendent Engineer Load Dispatch Circle