Miles Service Servic				POWER GRID	COMPANY OF BANGLADES NAL LOAD DESPATCH CE DAILY REPORT	SH LTD. NTER					OF-LDC-	
The Summary of Vesterday's (3-Sep-15 Generation & Demand 1200 May Pack Generation 1200 May Pack Generation 1200 May Research 1200 M	TP11				DAIL1 KETOKI		21.00			4-Sep-15	Page	
The peak of Centersion 1970 More 1920 More 192					and		21:00			able Cen &	Demand	
Processing Part 1930 Max Generation 776 Max 1930 Max Demand 776 Max 1930	Day Peak Generation	1 :					12:00					
Maximum Ceremistre 1930 Shorting 1930				MW	Hour:		19:30	Max Generation	:	7746	MW	
Transfer	E.P. Demand (at gen	end):	7860.0	MW	Hour:		19:30	Max Demand	:	7700	MW	
Part					Hour:				:			
Exercision Lead and a West gard & Maximum 2-10 MNW 18-20 Energy 7-867 MKWHR	Total Gen. (MKWH)) :	152.3		:			Load Shed	:	0	MW	
Marrie Marrie East grid - Maximum	English Control	da Wasanida Man		EXPORT / IMPORT		RCONNECTO		19.20	F	7 967	MEWIID	
Case Consumed 107.58		id to East grid :- Max	cimum	- 4.0 15	-210					7.807		
Proceedings Procedings Proceedings P	Actual :			pt 4-Sep-15		Rule curve	: 99.69	Ft.(MSL)				
Foot of the Consumed Feel (PDB-Pvt) Gas Tk68,946,479 Coal Tk7,891,367 Oil Tk30,263,112 Total Tk379,429,958	Gas Consumed:	Total	1075.65	MMCFD.			Oil Consu	med (PDB):				
Table Tabl												
Total Tota									FO :		Liter	
Total Tota	Ct -f th- C	J E L (DDD : D4) .	C		TI-69 046 470							
Area Yestensian	Cost of the Consume	d Fuel (PDB+Pvt) :					Oil	TI-202 622 112	Total :	Tl-270 420 05	0	
Area Yesterday			Coai .		187,831,307		Oli	. 1K302,032,112	Total .	1 K3 / 7,427,73	0	
Estimated Demand (SS end)		Los	ad Shedding & C	Other Information								
Estimated Demand (SS end)	Area	Yesterday		1				Today				
Mary	rica Testetuay			Fetimated Demand (\$/\$ end)								
Disable		MW										
Skintia Area - 0.00 827	Dhaka	-	0:00		2884				-	-		
Rajshah Area - 0.00	Chittagong Area	-	0:00						-	-		
Comilla Area - 0.00 598	Khulna Area	-	0:00						-	-		
Mymenshigh Area - 0.00	Rajshahi Area	-	0:00						-	-		
Sylbet Area - 0.00 339	Comilla Area	-							-	-		
Sarrisal Area - 0.00		-							-	-		
Total 0 7220 0 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down Forced Shut- Down Forced Shut- Down Chorasal ST: Unit-8 (1807/5) Ashuganj 225 MW CCPP (27/08/2015)		-							-	-		
Information of the Generating machines under shut down. Planned Shut- Down		-							-	-		
Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down 1 Shoreas IST: Unit-1 (\$180775) Ashuganj 225 MW CCPP (\$2708/2015) 2) Ashuganj ST: Unit-1 (\$210402 (10) Meghnaghat CCPP ST 3) Khulna ST 110 MW (\$047112 (1) Skabaha ST (\$3008/2015) 4) Ghorasa ST: Unit-4 (\$05167.5 (2) Samith Meghaghat 5) Haripur GT-3 (\$2406/2015) 3) Siddinganj GT2 (5) Siddinganj GT2 (5) Siddinganj GT3 (5) Siddinganj ST; Unit-1 (\$107.5 (2) Samith Meghaghat 5) Haripur GT-3 (\$2406/2015) 3) Siddinganj GT2 (5) Siddinganj GT3 (5) Siddinganj GT3 (5) Siddinganj ST; Unit-1 (\$107.5 (2) Samith Meghaghat 5) Haripur GT-3 (\$2406/2015) 3) Siddinganj GT2 (6) Siddinganj GT3 (6) Siddinganj ST; Unit-1 (\$107.5 (2) Siddinganj GT3 (6) Siddinganj ST; Unit-1 (\$107.5 (2) Siddinganj GT3 (6) Siddinganj GT3 (6) Siddinganj ST; Unit-1 (\$107.5 (2) Siddinganj GT3 (6) Siddinganj GT3	Rangpur Area	-	0:00		441				-	-		
Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down 1 Shoreas IST: Unit-1 (\$180775) Ashuganj 225 MW CCPP (\$2708/2015) 2) Ashuganj ST: Unit-1 (\$210402 (10) Meghnaghat CCPP ST 3) Khulna ST 110 MW (\$047112 (1) Skabaha ST (\$3008/2015) 4) Ghorasa ST: Unit-4 (\$05167.5 (2) Samith Meghaghat 5) Haripur GT-3 (\$2406/2015) 3) Siddinganj GT2 (5) Siddinganj GT2 (5) Siddinganj GT3 (5) Siddinganj ST; Unit-1 (\$107.5 (2) Samith Meghaghat 5) Haripur GT-3 (\$2406/2015) 3) Siddinganj GT2 (5) Siddinganj GT3 (5) Siddinganj GT3 (5) Siddinganj ST; Unit-1 (\$107.5 (2) Samith Meghaghat 5) Haripur GT-3 (\$2406/2015) 3) Siddinganj GT2 (6) Siddinganj GT3 (6) Siddinganj ST; Unit-1 (\$107.5 (2) Siddinganj GT3 (6) Siddinganj ST; Unit-1 (\$107.5 (2) Siddinganj GT3 (6) Siddinganj GT3 (6) Siddinganj ST; Unit-1 (\$107.5 (2) Siddinganj GT3 (6) Siddinganj GT3	Total	- 0			7220				0			
Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18077:9) Ashuganj 225 MW CCPP (27/08/2015) 2) Ashuganj ST: Unit-1 (28/04/210) Meghrasphat CCPP ST 3) Khulna ST: 110 MW (04/11/21) Skalbaha ST (30/08/2015) 4) Ghorasal ST: Unit-4 (18/05/01/12) Summit Megnaghat 5) Haripur GT-3 (24/05/2015) 13) Skidirganj GT2 6) Skidhignonj ST(300/07/2015) 7) Haripur-412 MW (25/5/15) 8) Barapukuria ST: Unit-1 (01/08/2015) 8) Barapukuria ST: Unit-1 (01/08/2015) 9) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description	Total				7220							
1) Chorasal ST: Unit-1 (2804/210) Mephaaphat COCPP (37/08/2015) 2) Ashuganj ST: Unit-1 (2804/210) Mephaaphat COCPP ST 3) Khulan ST: Unit-1 (2804/210) Mephaaphat COCPP ST 3) Khulan ST: Unit-1 (05/01/7:12) Summit Megnaphat (5) Haripur GT-3 (24/05/2015) 13) Siddirganj GT2 (6) Siddhirgonj ST(3/00/7/2015) 7) Haripur-412 MW (28/51/5) (8) Barapukuria ST: Unit-1 (01/09/2015) 7) Haripur-412 MW (28/51/5) (8) Barapukuria ST: Unit-1 (01/09/2015) 7) Haripur-412 MW (28/51/5) (9) Barapukuria ST: Unit-1 (01/09/2015) 7) Haripur-412 MW (28/51/5) (9) Barapukuria ST: Unit-1 (01/09/2015) 7) Haripur-412 MW (28/51/5) (9) Barapukuria ST: Unit-1 (01/09/2015) 7) Haripur-412 MW (28/51/5) (9) Barapukuria ST: Unit-1 (01/09/2015) 7) Haripur-412 MW (28/51/5) (9) Barapukuria ST: Unit-1 (01/09/2015) (9) Barapukuria ST: Unit-1 (ne Generating ma	chines under shut down.								
2) Ashuganj ST: Unit-1 (28/04/210) Meginaghat CCPP ST 3) Khulna ST 11 MW (04/11/21 Skalbahas ST (30/08/2015) 4) Ghorasal ST: Unit-4 (05/01/12) Summit Megnaghat 5) Harjour GT-3 (24/05/2015) 13) Siddinganj GT2 6) Siddhirgonj ST(30/07/2015) 7) Harjour-412 MW (25/5/15) 8) Barapukuria ST: Unit-1 (01/09/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Ashuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 13/2/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorgan-Hymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. e) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. e) Madanganj 132/33 kV T2 transformer tripped at 05:09 (04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 05:18(04/09/2015). e) Biblyana Summit-2 was forced shut down at 07:35(04/09/2015) from both end showing O/C relay and was switched on at 05:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer		Planned Shut- Down										
3) Khulina ST 110 MW (04/11/211) Sikabaha ST (30/08/2015) 4) Ghorasal ST : Unit-1 (0501/12) Summit Meghanghat 5) Haripur GT-3 (24/05/2015) 13) Siddirganj GT2 6) Siddhirgonj ST(30/08/2015) 7) Haripur-12 MW (25/5/15) 8) Barapukuria ST: Unit-1 (01/09/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Abshuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. 6) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:25. 6) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:26 from both end showing Dist. Z1, Z2 relays and was switched on at 10:25. 7) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. 8) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing 132 at 10:25 from both end showing Dist. Z1 relay and was switched on at 10:25. 8) Madanganj 132/33 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). 8) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer							1) Ghoras	al ST: Unit-6 (18/	07/29) Ashuganj 2	25 MW CCPP	(27/08/2015)	
4) Ghorasal ST: Unit-4 (0s/01/12) Summit Megnaghat 5) Haripur GT-3 (240/S2015) 13) Siddirganj GT2 6) Siddhirgonj ST(30/07/2015) 7) Haripur-412 MW (25/5/15) 8) Barapukuria ST: Unit-1 (01/09/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced Load shed etc. Description Forced load shaded / Interrupted Areas Alphayanj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. a) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. b) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. b) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. b) Madanganj 132/33 kV T2 transformer tripped at 05:09 (04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). b) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
5) Haripur GT-3 (24/05/2015) 13) Siddirganj GT2 6) Siddhirgonj ST(30/07/2015) 7) Haripur-412 MW (255/15) 8) Barapukuria ST: Unit-1 (01/09/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced Load shed etc. Discription Forced Load shed etc. Description Forced Load shed etc. Forced Load shaded / Interrupted Areas Forced Load sha								4) Ghorasal ST: Unit-4 (05/01/12) Summit Megnaghat 5) Haripur GT-3 (24/05/2015) 13) Siddirganj GT2				
i, 6) Siddhirgon; ST(30/07/2015) 7) Haripu-412 MW (25/5/15) 8) Barapukuria ST: Unit-1 (01/09/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description ii) Ashuganj-Sirajgon; 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 13:2/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. e) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madanganj 132/33 kV T2 transformer tripped at 05:09 (04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). e) Sibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Ashuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. Feni 13:2/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. Kishorganj-Mymenshing 13:2 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. Mymenshing end at 07:00(04/09/2015). Jestin 13:2/33 kV T2 transformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 07:10(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Ashuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishoragn-Infymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. e) Chorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madanganj 132/33 kV T2 transformer tripped at 05:09 (04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 05:16(4/09/2015). e) Sibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
a) Ashuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. e) (Chorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madanganj 132/33 kV T2 transformer tripped at 05:09 (04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). e) Sibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer								8) Barapukuria ST: Unit-1 (01/09/2015)				
a) Ashuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. e) (Chorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madanganj 132/33 kV T2 transformer tripped at 05:09 (04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). e) Sibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
a) Ashuganj-Sirajgonj 230 kV Ckt-2 tripped at 09:46 from both end showing Dist. Z1 relay and was switched on at 10:25. b) Comilla(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 13:233 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. f) Chorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madanganj 13:233 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). f) Jessore 13:2/33 kV T1 transformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). g) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer		Additional Informati	ion of Machines,	lines, Interruption / For	ced Load shed etc.							
a) Comila(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. f) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madangang 13/233 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). f) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). g) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer	Description							Forced load shaded / Interrupted Areas				
a) Comila(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. f) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madangang 13/233 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). f) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). g) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
a) Comila(N)-Meghanaghat 230 kV Ckt-1 tripped at 10:25 from both end showing Dist. Z1, Z2 relays and was switched on at 10:39. c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. d) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. f) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madangang 13/233 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). f) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). g) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer	a) Achugani-Siroiae	oni 230 kV Ckt. 2 tric	oped at 00:46 t	rom both and chausin	a Diet 71 rolay and was switched	on at 10:2F						
on at 10:39. 5. Feni 13:2/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. 2) Kishorgani-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. 8) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. 9) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. 9) Madanganj 132:33 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). 1) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:136/04/09/2015). Sub Divisional Engineer Superintendent Engineer Executive Engineer Superintendent Engineer												
c) Feni 132/33 kV T2 transformer tripped at 10:30 from showing PRD and was switched on at 11:20. 3) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. 6) Hola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. 7) Hola 23:38 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). 8) Jessors 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). 8) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer		nanagnat 200 KV CF	in inpped at	10.20 110111 00111 0110 8	mowing Dist. 21, 22 relays allu Wa	is switched						
3) Kishorganj-Mymenshing 132 kV Ckt-2 was under shut down from 11:08 to 11:17 due to Gas filling work of CB at Mymenshing end. e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. f) Chorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. g) Madanganj 13:2/33 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). f) Jessore 13:2/33 kV T1 fansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
Mymenshing end. a) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. b) Ghorashal Unit-3 was shut down at 23:37 due to FD fan maintenance. c) Madangani 132:33 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). a) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 07:35(04/09/2015). b) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
a) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41. () [A problem 27:33 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). () [A plays a summit 2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). () [B biliyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). () Sub Divisional Engineer Executive Engineer Superintendent Engineer	Mymenshing end.											
g) Madanganj 132/33 kV T2 transformer tripped at 00:10(04/09/2015) due to fire at 33 kV Haripur feeder and was switched on at 07:00(04/09/2015). n) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer	e) Bhola 225 MW was tripped at 12:32 due to GBC problem and was synchronized at 13:41.											
switched on at 07:00(04/09/2015). h) Jessore 132/33 kV T1ansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). Bibliyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer												
h) Jessore 132/33 kV Triansformer tripped at 05:09 (04/09/2015) from both end showing O/C relay and was switched on at 05:15(04/09/2015). Biblyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer Superinte			er tripped at 00):10(04/09/2015) due	to fire at 33 kV Haripur feeder and	l was						
on at 05:15(04/09/2015).) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Executive Engineer Superintendent Engineer	switched on at 07	7:00(04/09/2015).		0.4/0.0/0.0451								
) Bibiyana Summit-2 was forced shut down at 07:35(04/09/2015) due to Hazardous gas alarm and was synchronized at 09:18(04/09/2015). Sub Divisional Engineer Superintendent Engineer Superintendent Engineer Superintendent			ped at 05:09 (U4/U9/2015) from boti	n end showing O/C relay and was	switched						
at 09:18(04/09/2015). Sub Divisional Engineer Superintendent Engineer Superintendent Engineer			down at 07:05	04/00/201E) due t- 11	lozardous and clarm and	bronized						
Sub Divisional Engineer Superintendent Engineer Superintendent Engineer			uown at 07:35(04/09/2015) que to H	azaruous gas alarm and was synd	anonized						
	at 00.10(04/09/2	_0.0/.										
Network Operation Division Load Dispatch Circle												
		network Operation	Division				Network	Operation Divisi	on	Load	Dispatch Circle	