

Till now the maximum generation is :-				8177 MW		21:00		Hrs on		Reporting Date : 6-Nov-15	
The Summary of Yesterday's (5-Nov-15		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		6009.0		MW		Hour :		12:00		Min. Gen. at 7:00 4336 MW	
Evening Peak Generation :		7228.0		MW		Hour :		20:00		Max Generation : 7398 MW	
E.P. Demand (at gen end) :		7228.0		MW		Hour :		20:00		Max Demand : 6900 MW	
Maximum Generation :		7228.0		MW		Hour :		20:00		Shortage : 498 MW	
Total Gen. (MKWH) :		139.6		System L/ Factor		:		80.46%		Load Shed : 0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-100		MW		a 15:00		Energy 7.867 MKWHR.	
Import from West grid to East grid :- Maximum				-		MW		a -		Energy - MKWHR.	
Water Level of Kapt 6-Nov-15											
Actual :		104.02		Ft.(MSL) ,		Rule curve :		108.50		Ft.(MSL)	
Gas Consumed : Total		1009.23		MMCFD.		Oil Consumed (PDB) :				HSD : Liter	
										FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk66,736,341							
		Coal :		Tk2,578,061		Oil :		Tk310,645,365		Total : Tk379,959,767	
Load Shedding & Other Information											
Area		Yesterday				Estimated Demand (S/S end)		Today			
		MW				MW		Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)	
Dhaka		- 0:00				2670		-		-	
Chittagong Area		- 0:00				682		-		-	
Khulna Area		- 0:00				759		-		-	
Rajshahi Area		- 0:00				712		-		-	
Comilla Area		- 0:00				557		-		-	
Mymensingh Area		- 0:00				425		-		-	
Sylhet Area		- 0:00				314		-		-	
Barisal Area		- 0:00				148		-		-	
Rangpur Area		- 0:00				410		-		-	
Total		0				6677		0			
Information of the Generating machines under shut down.											
		Planned Shut- Down				Forced Shut- Down					
						1) Ghorasal ST: Unit-6 (18/07/2010) 9) Raozan ST: Unit-2 (18/10/2015) 2) Ashuganj ST: Unit-1(12/09/2015) 10) Ashuganj : GT-2 3) Khulna 150 MW (16/10/2015) 11) Summit Meghnaghat (25/10/2015) 4) Khulna ST 110 MW (04/11/2014) 12) Pagla 50 MW (29/10/2015) 5) Ghorasal ST: Unit-4 (05/01/2015) 13) Barapukuria ST-1 (05/11/2015) 6) Haripur GT-3 7) Sikalbaha ST 8) Haripur-412 MW (25/05/2015)					
Additional Information of Machines, lines, Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Kaptai Unit-2 was shut down from 09:32 to 12:32 due to isolator maintenance. b) Cox's Bazar-Dohazari 132 kV Ckt-1 was under shut down from 08:01 to 15:44 due to A/M. c) Mymensingh 132/33 kV T2 transformer was under shut down from 08:33 to 15:22 due to A/M. d) Khulna 230/132 kV T2 transformer was under shut down from 08:11 to 16:38 due to A/M. e) Juida-Shahmirpur 132 kV Ckt-1 was under shut down from 08:34 to 15:17 due to A/M. f) Baghabari-Seraiganj 230 kV Ckt-1 was under shut down from 08:37 to 17:28 due to A/M. g) Faridpur 132 kV bus-A was under shut down from 08:10 to 10:10 due to A/M & oil filling of bus PT. h) Kishorganj 132/33 kV T2 transformer was under shut down from 08:45 to 15:02 due to A/M. i) Feni 132/33 kV T2 transformer was under shut down from 10:08 to 10:41 due to A/M. j) Barapukuria unit-1 was forced shut down at 10:28 due to problem at coal mill. k) Faridpur 132 kV bus-B was shut down from 10:40 to 16:36 due to A/M. l) Satkhira 132/33 kV T1 & T2 transformers both side tripped at 10:44 due to fault at 33 kV Satkhira feeder and were switched on at 10:52. m) Kallyanpur-Lalbag 132 kV Ckt-2 was under shut down from 10:25 to 18:00 due to A/M. n) Kishoreganj 132/33 kV T2 transformer was under shut down from 08:16 to 16:05 due to A/M. o) Siddhirganj 132 kV Bus -2 was under shut down from 09:40 to 15:32 due to A/M. p) Haripur-Bhulta 132 kV Ckt. was under shut down from 08:50 to 17:38 due to A/M. q) Mirpur-Tongi 132 kV Ckt was under shut down from 09:15 to 15:27 due to A/M. r) After maintenance Barapukuria Unit-2 was synchronized at 06:03(06/11/15). s) Rampura-Ghorasal 230 kV Ckt-1 was shut down at 07:19 (06/11/15) due to A/M. t) Maniknagar-Bangabhaban 132 kV Ckt-1 tripped at 06:31 (06/11/15) from Maniknagar end showing pilot wire protection & main protection tripping and was switched on at 06:59.						About 25 MW power interruption occurred under Satkhira S/S area from 10:44 to 10:52.					
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle		