

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-									
The Summary of Yesterday's (
Day Peak Generation :									
Evening Peak Generation :									
E.P. Demand (at gen end) :									
Maximum Generation :									
Total Gen. (MKWH) :									
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum									
Import from West grid to East grid :- Maximum									
Actual :									
Gas Consumed :									
Cost of the Consumed Fuel (PDB+Pvt) :									
Load Shedding & Other Information									
Area									
Dhaka									
Chittagong Area									
Khulna Area									
Rajshahi Area									
Comilla Area									
Mymensingh Area									
Sylhet Area									
Barisal Area									
Rangpur Area									
Total									
Information of the Generating machines under shut down.									
Planned Shut- Down									
Forced Shut- Down									
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description									
Forced load shaded / Interrupted Areas									
a) Seraiganj-Baghabari 230 kV Ckt-2 was under shut down from 08:31 to 15:25 due to A/M.									
b) Haripur 230/132 kV T2 transformer was under shut down from 09:15 to 14:54 due to A/M.									
c) Maniknagar-Matuail 132 kV Ckt-1 was under shut down from 08:01 to 16:42 due to A/M.									
d) Madaripur 132/33 kV T1 transformer was under shut down from 09:19 to 16:57 due to A/M.									
e) HVDC Boy 20DF12 at B1PTC was under shut down from 09:52 to 16:36 due to A/M.									
f) Manikganj-Kabirpur 132 kV Ckt-1 was under shut down from 08:49 to 16:57 due to A/M.									
g) Manikganj GT3 & GT4 transformers were under shut down from 08:49 to 16:57 due to A/M.									
h) Sherpur 132/33 kV SGT-1 transformer was under shut down from 09:11 to 13:17 due to A/M.									
i) Bottail 132/33 kV T1 transformer was under shut down from 09:30 to 16:05 due to A/M.									
j) Khulna(S) 230 kV bus-1 was shut down from 08:44 to 14:37 due to A/M.									
k) Bagerhat 132/33 kV T1 transformer was shut down from 09:12 to 13:50 due to A/M.									
l) Kulaura 132/33 kV T2 transformer was shut down from 09:02 to 11:22 due to A/M.									
m) Ullon-Rampura 132 kV Ckt-1 was under shut down from 09:08 to 12:42 due to CB no. 908B maintenance at Ullon S/S end.									
n) Siddhirganj-Desh Energy 132 kV Ckt was under shut down from 10:04 to 16:59 due to A/M.									
o) Dohazari-Cox's Bazar 132 kV Ckt was under shut from 07:59 to 16:29 due to A/M.									
p) Kallanpur 132 kV bus Coupler Boy was under shut down from 10:30 to 13:30 due to A/M.									
q) Kulaura 132/33 kV T1 transformer was under shut down from 11:32 to 13:30 due to A/M.									
r) Khulna(S) 230 kV bus-2 was under shut down from 14:55 to 17:12 due to PT checking isolator maintenance.									
s) Noapara 132/33 kV T2 transformer tripped at 17:03 due to R-phase bushing burst.									
t) Noapara 132/33 kV T1 transformer was switched on at 20:55 again tripped at 21:20 showing differential relay and was switched on at 00:45 (08/11/2015).									
u) Bagerhat-Bhandaria 132 kV Ckt tripped at 07:30(08/11/15) from Bagerhat end showing dist T, auto reclose block, E/F & lock out relay.Trial given at 07:34 but again tripped showing same relay.									
v) Hasnabad-Sitalakha 132 kV Ckt was shut down at 07:20(08/11/15) due to A/M.									
w) After maintenance Madanganj-Sitalakha 132 kV Ckt was switched on at 07:16 (08/11/2015).									

Sub Divisional Engineer
Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Dispatch Circle