

Till now the maximum generation is :-				8177 MW		21:00		Hrs on 13-Aug-15		Reporting Date : 20-Nov-15			
The Summary of Yesterday's (19-Nov-15		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand					
Day Peak Generation :		5138.0		MW		Hour :		12:00		Min. Gen. at 7:00 3921 MW			
Evening Peak Generation :		7029.0		MW		Hour :		18:30		Max Generation : 7813 MW			
E.P. Demand (at gen end) :		7029.0		MW		Hour :		18:30		Max Demand : 6700 MW			
Maximum Generation :		7029.0		MW		Hour :		18:30		Shortage : 1113 MW			
Total Gen. (MKWH) :		123.7		System L/ Factor :				73.32%		Load Shed : 0 MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR													
Export from East grid to West grid :- Maximum				-40		MW		a 16:00		Energy 7.867 MKWHR.			
Import from West grid to East grid :- Maximum				-		MW		a -		Energy - MKWHR.			
Water Level of Kapt 20-Nov-15													
Actual :		102.53		Ft.(MSL) ,		Rule curve :		107.10		Ft.(MSL)			
Gas Consumed :		Total		949.60		MMCFD.		Oil Consumed (PDB) :		HSD : Liter			
										FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk59,581,622									
		Coal :		Tk6,913,889		Oil :		Tk151,433,899		Total : Tk217,929,409			
Load Shedding & Other Information													
Area		Yesterday				Today							
		MW				Estimated Demand (S/S end)				Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)	
						MW				MW			
Dhaka		-		0:00		2891				-		-	
Chittagong Area		-		0:00		743				-		-	
Khulna Area		-		0:00		829				-		-	
Rajshahi Area		-		0:00		776				-		-	
Comilla Area		-		0:00		599				-		-	
Mymensingh Area		-		0:00		456				-		-	
Sylhet Area		-		0:00		340				-		-	
Barisal Area		-		0:00		159				-		-	
Rangpur Area		-		0:00		442				-		-	
Total		0				7235				0			
Information of the Generating machines under shut down.													
		Planned Shut- Down						Forced Shut- Down					
								1) Ghorasal ST: Unit-6 (18/0 9) Raozan ST: Unit-2 (18/10/2015) 2) Ashuganj ST: Unit-1(12/0 10) Barapukuria ST-1 (05/11/2015) 3) Khulna 150 MW (16/10/2(11) Pagla 50 MW (29/10/2015) 4) Khulna ST 110 MW (04/1 12) Ghorashal Unit-2 (15/11/2015) 5) Ghorasal ST: Unit-4 (05/0 13) Ashugonj 225 MW (GT) (18/11/2015) 6) Haripur GT-3 14) Ghorashal Unit-3 (20/11/2015). 7) Sikalbaha ST 8) Haripur-412 MW (25/05/2015)					
Additional Information of Machines, lines, Interruption / Forced Load shed etc.													
Description								Forced load shaded / Interrupted Areas					
a) Siddhirganj 132 kV Bus-1 was under shut down from 08:50 to 16:55 due to A/M. b) Rampura-Haripur 230 kV Ckt-1 was under shut down from 08:20 to 21:43 due to CT maintenance at Rampura end. c) Gopalganj 132/33 kV T1 transformer was under shut down from 08:45 to 18:49 due to A/M. d) Comilla (N)-Feni 132 kV Ckt-1 was under shut down from 09:18 14:10 due to A/M. e) Cantonment 132/33 kV T1 transformer was under shut down from 08:57 to 16:42 due to A/M. f) Noapara 33 kV Bus-2 was under shut down from 10:24 to 12:57 due to A/M.								Power interruption occurred (about 7 MW) under Noapara S/S areas from 10:24 to 12:57.					
g) Bottail 132/33 kV T2 transformer tripped at 11:17 from both side showing without any relay and was switched on at 13:45. h) Rangpur-Polashbari 132 kV Ckt-1 was under shut down from 10:25 to 13:20 due to CB problem. i) Siddhirganj 230/132 kV MTR-1 was under shut down from 11:18 to 16:06 due to DS maintenance. j) After maintenance Summit Meghnaghat GT-1 was synchronized at 10:32. k) Hathazari-Raozan 230 kV Ckt-2 was under shut down from 15:58 to 19:54 due to 230 kV breaker problem at Raozan end. l) After maintenance Sylhet 150 MW was synchronized at 16:11. m) After maintenance Summit Meghnaghat ST was synchronized at 17:45. n) After maintenance Summit Meghnaghat GT-2 was synchronized at 19:23. o) Ghorashal Unit-3 was shut down at 00:02 (20/11/2015) due to inspection. p) Comilla (S) 132/33 kV T2 transformer was shut down at 06:24 (20/11/2015) due to 33 kV Y-Phase CT maintenance. q) HVDC Bheramara-Baharampur 400 kV Ckt-1 is under shut down since 07:04 (20/11/2015) due to A/M. r) Hasnabad 132/33 kV T2 transformer is under shut down since 07:24 (20/11/2015) due to A/M. s) Rampura-Ghorashal 230 kV Ckt-2 is under shut down since 07:28 (20/11/2015) due to CT replacement work.													
Sub Divisional Engineer Network Operation Division								Executive Engineer Network Operation Division				Superintendent Engineer Load Dispatch Circle	