

Till now the maximum generation is :-		8177 MW		21:00		Hrs on 13-Aug-15		3-Dec-15	
The Summary of Yesterday's (2-Dec-15		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		5248.0		MW		Hour :		12:00	
Evening Peak Generation :		6925.0		MW		Hour :		18:30	
E.P. Demand (at gen end) :		6925.0		MW		Hour :		18:30	
Maximum Generation :		6925.0		MW		Hour :		18:30	
Total Gen. (MKWH) :		120.4		System L/ Factor :				72.44%	
Export from East grid to West grid :-		Maximum		-140		MW		a 16:00	
Import from West grid to East grid :-		Maximum		-		MW		a -	
Actual :		101.20		Water Level of Kapt 3-Dec-15		Rule curve :		105.82	
		Ft.(MSL) ,				Ft.(MSL)			
Gas Consumed :		Total		899.76		MMCFD.		Oil Consumed (PDB) :	
								HSD :	
								FO :	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk56,748,282		Oil :		Tk271,360,630	
		Coal :		Tk7,773,243		Total :		Tk335,882,155	
Load Shedding & Other Information									
Area									
Yesterday									
MW									
Estimated Demand (S/S end)									
Today									
Estimated Shedding (S/S end)									
Rates of Shedding (On Estimated Demand)									
Dhaka									
Chittagong Area									
Khulna Area									
Rajshahi Area									
Comilla Area									
Mymensingh Area									
Sylhet Area									
Barisal Area									
Rangpur Area									
Total									
0									
7016									
0									
Information of the Generating machines under shut down.									
Planned Shut- Down									
Forced Shut- Down									
1) Ghorasal ST: Unit-6 (18/0 9) Raozan ST: Unit-2 (18/10/2015)									
2) Ashuganj ST: Unit-1(12/0 10) Barapukuria ST-1 (05/11/2015)									
3) Khulna 150 MW (16/10/21 11) Sikalbaha 60MW (23/11/15)									
4) Khulna ST 110 MW (04/1 12) Siddhirgonj ST (23/11/15)									
5) Ghorasal ST: Unit-4 (05/0 13) Ghorasal ST: Unit-5(01/12/2015)									
6) Haripur GT-3									
7) Haripur-412 MW (25/05/2015)									
8) Raozan ST: Unit-2 (18/10/2015)									
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description									
Forced load shaded / Interrupted Areas									
a) Sikalbaha-Dohazari 132 kV Ckt-1 was under shut down from 08:03 to 16:46 due to A/M.									
b) Sonargaon-Daudkandi 132 kV Ckt-2 was under shut down from 08:44 to 17:00 due to A/M.									
c) Feni-Chowmuhoni 132 kV Ckt-2 was under shut down from 08:19 to 15:48 due to A/M.									
d) Aminbazar-Hasnabad 230 kV Ckt-2 was under shut down from 09:45 to 16:42 due to A/M.									
e) Sherpur 132/33 kV T2 transformer was under shut down from 08:17 to 16:05 due to A/M.									
f) Kishorganj-Ashuganj 132 kV Ckt-1 was under shut down from 08:17 to 16:53 due to A/M.									
g) Mymensingh-Jamalpur 132 kV Ckt-1 was under shut down from 09:19 to 17:01 due to A/M.									
h) Munshiganj 132/33 kV T1 transformer was under shut down from 09:32 to 17:01.									
i) Shyampur-Haripur 132 kV Ckt was under shut down from 08:24 to 16:24 due to A/M.									
j) Chatak 132/33 kV T2 transformer was under shut down from 07:49 to 14:52 due to A/M.									
k) Sreemongal 132/33 kV T2 transformer was under shut down from 08:29 to 15:05 due to A/M.									
l) Bogra-Barapukuria 230 kV Ckt-2 was under shut down from 08:22 to 16:03 due to A/M.									
m) Noapara-Bogra 132 kV Ckt-1 was under shut down from 09:15 to 16:55 due to A/M.									
n) Pabna 132/33 kV T2 transformer was under shut down from 08:20 to 17:24 due to A/M.									
o) Khulna Central 132/33 kV T2 transformer was under shut down from 08:20 to 17:24 due to A/M.									
p) Siddhirganj-Dutch Bangla P/S 132 kV bay was under shut down from 09:43 to 16:41 due to A/M.									
q) Shyampur GT-3 & GT-4 transformers were under shut down from 09:35 to 16:14 due to 33 kV red hot maintenance.									
r) Agargaon 230/132 kV T2 transformer was under shut down from 09:41 to 13:14 due to relay replacement work.									
s) Tongi 230/132 kV T transformer was under shut down from 09:11 to 14:42 due to A/M.									
t) Baria 132/33 kV T1 transformer was under shut down from 09:02 to 13:03 due to A/M.									
u) Rampura 132 kV capacitor bank was under shut down from 09:50 to 15:09 due to A/M.									
v) Manikganj 132/33 kV GT-4 transformer was under shut down from 10:50 to 17:30 due to energy meter replacement work.									
w) Mymensingh 132/33 kV T1 transformer was under shut down from 10:26 to 12:30 due to oil leakage maintenance.									
x) B. Baria 132/33 kV T2 transformer was under shut down from 13:06 to 16:32 due to A/M.									
y) After maintenance Ashuganj 225 MW ST was synchronized at 17:48.									
z) After maintenance Sirajganj GT was synchronized at 19:11.									
aa) After maintenance Haripur-Rahim Steel 132 kV Ckt was switched on at 20:20.									
ab) Haripur-Shyampur 132 kV Ckt tripped at 22:23 showing dist.relay from both end and was switched on at 22:29.									
ac) Jamalpur 132/33 kV S/S both incoming Ckt interrupted manually from 21:24 to 21:50 from Mymensingh due to flash over at 33 kV Modhupur feeder. At the same time Sherpur S/S also interrupted.									
About 40 MW power interruption occurred under Shyampur S/S areas from 09:35 to 16:14.									
About 94 MW power interruption occurred under Jamalpur & Sherpur S/S areas from 21:24 to 21:50.									
Sub Divisional Engineer									
Network Operation Division									
Executive Engineer									
Network Operation Division									
Superintendent Engineer									
Load Dispatch Circle									