

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										OF-LDC-08 Page -1
Till now the maximum generation is :-		8177 MW		21:00		Hrs on		Reporting Date : 6-Jan-16		
The Summary of Yesterday's (		5-Jan-16		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand				
Day Peak Generation :	4938.0	MW	Hour :	12:00	Min. Gen. at	5:00	3732	MW		
Evening Peak Generation :	6672.0	MW	Hour :	18:30	Max Generation :		7451	MW		
E.P. Demand (at gen end) :	6672.0	MW	Hour :	18:30	Max Demand :		6700	MW		
Maximum Generation :	6672.0	MW	Hour :	18:30			751	MW		
Total Gen. (MKWH) :	116.3	System L/ Factor :		72.64%	Load Shed :		0	MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- Maximum				-30	MW	a 15:00	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	a -	Energy	-	MKWHR.	
Actual :		98.95	Water Level of Kapt 6-Jan-16 Ft.(MSL) ,		Rule curve :		102.05	Ft( MSL )		
Gas Consumed : Total		871.71	MMCFD.		Oil Consumed (PDB) :			HSD : FO :	Liter Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk55,984,878		Oil :		Tk228,707,807	Total :	Tk291,958,131	
Coal :		Tk7,265,445								
Load Shedding & Other Information										
Area	Yesterday				Today					
	MW		Estimated Demand (S/S end) MW		Estimated Shedding (S/S end) MW		Rates of Shedding (On Estimated Demand)			
Dhaka	-	0:00	2759		-		-			
Chittagong Area	-	0:00	707		-		-			
Khulna Area	-	0:00	787		-		-			
Rajshahi Area	-	0:00	737		-		-			
Comilla Area	-	0:00	574		-		-			
Mymensingh Area	-	0:00	438		-		-			
Sylhet Area	-	0:00	324		-		-			
Barisal Area	-	0:00	153		-		-			
Rangpur Area	-	0:00	423		-		-			
Total	0		6902		0					
Information of the Generating machines under shut down.										
Planned Shut- Down				Forced Shut- Down						
				1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(12/09/2015) 3) Barapukuria ST-2 (07/12/2015) 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal ST: Unit-4 (05/01/2015) 6) Haripur GT-3 7) Haripur-412 MW (25/05/2015) 8) Raozan ST: Unit-2 (18/10/2015)		09)Siddhirganj (Desh)(11/12/2015) 10) Sikalbaha 60MW (23/11/15) 11) Raozan ST: Unit-1(22/12/2015) 12)Siddhirganj (Desh)(11/12/2015) 13) Ashuganj ST: Unit- 2(05/01/2016) 14) Ashuganj 225 MW(GT)(06/01/2016)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.										
Description					Forced load shaded / Interrupted Areas					
a) Mymensingh RPCL Unit-4 was under shut down at 09:37 due to maintenance work b) After maintenance Fenchuganj GT-3 was synchronized at 11:44. c) Aminbazar-Savar 132 kV Ckt-1 was under shut down from 08:34 to 15:54 due to A/M. d) Comilla(N)-Daudkandi 132 kV Ckt-1 was under shut down from 08:37 to 16:28 due to A/M. e) Ashuganj-Sirajganj 230 kV Ckt-2 was under shut down from 08:50 to 15:51 due to A/M. f) Mirpur-Uttara 132 kV Ckt was under shut down from 09:10 to 17:05 due to A/M. g) Tongi 132/33 kV T2 transformer was under shut down from 09:12 to 15:37 due to A/M. h) Noapara-Jessore 132 kV Ckt-2 was under shut down from 08:41 to 15:58 due to A/M. i) Bheramara-Bottail 132 kV Ckt-1 was under shut down from 08:52 to 16:03 due to A/M. j) Ishurdi 230/132 kV T02 transformer was under shut down from 09:01 to 13:35 due to A/M. k) Saidpur-Purbasadipur 132 kV Ckt-1 was under shut down from 09:20 to 16:36 due to A/M. l) Madaripur-Barisal 132 kV Ckt-1 was under shut down from 09:01 to 16:52 due to A/M. m) Bheramara GK project 132/33 kV T1 transformer was under shut down from 08:55 to 11:57 due to A/M. n) Bogra 132/33 kV T3 transformer was under shut down from 08:01 to 14:02 due to A/M. o) Ashuganj 450 MW CCPP was synchronized at 17:14 due to test purpose. p) Modunaghat-Kaptai 132 kV Ckt-1 is under shut down since 07:31 (06/01/2016) due to A/M. q) Meghnaghat-Aminbazar 230 kV Ckt-2 is under shut down since 07:14(06/01/2016) due to A/M. r) Ashuganj-Sirajganj 230 kV Ckt-2 is under shut down since 07:52 (06/01/2016) due to A/M. s) Hasnabad 230/132 kV TR-2 Auto transformer is under shut down since 07:46(06/01/2016) due to A/M.										
Sub Divisional Engineer Network Operation Division					Executive Engineer Network Operation Division					Superintendent Engineer Load Dispatch Circle