

Reporting Date :
13-Aug-15

21:00

13-Aug-15

EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR				
Export from East grid to West grid :- Maximum	-160	MW	at 17:00	Energy
Import from West grid to East grid :- Maximum	-	MW	at -	Energy

Export from East grid to West grid :- Maximum	-160	MW	at 17:00	Energy
Import from West grid to East grid :- Maximum	-	MW	at -	Energy

Actual : 97.11 Ft.(MSL), Rule curve : 96.72 Ft.(MSL)

Gas Consumed :	Total	850.85	MMCFD.	Oil Consumed (PDB) :		HSD :
						FO :

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk59,269,080			
	Coal :	Tk20,852,044	Oil :	Tk280,945,744	Total :

Area	Yesterday		Today	
	MW		Estimated Demand (S/S end)	Estimated Shedding (S/S end)
Dhaka	-	0:00	2602	-
Chittagong Area	-	0:00	663	-
Khulna Area	-	0:00	738	-
Rajshahi Area	-	0:00	692	-
Comilla Area	-	0:00	544	-
Mymensingh Area	-	0:00	415	-
Sylhet Area	-	0:00	306	-
Barisal Area	-	0:00	145	-
Rangpur Area	-	0:00	400	-
	-			
Total	0		6505	0

	Planned Shut- Down	Forced Shut- Down
		1) Ghorasal ST: Unit-6 (18/07/2010)
		2) Ashuganj ST: Unit-1(12/09/2015)
		3) Siddhirgonj GT: Unit-1& 2
		4) Khulna ST 110 MW (04/11/2014)
		5) Ghorasal ST: Unit-4 (05/01/2015)
		6) Haripur GT-2 & 3 (07/01/2016)
		7) Ashuganj ST: Unit- 4
		8) Chittagong ST: Unit-2 (18/10/2015)
		9) Tongi GT
		10) Sikalbaha
		11)Ghorasal S
		12) Saidpur G
		13) Haripur P
		14) Chandpur

Description	Forced load shaded / Interrupted Areas
<p>a) Comilla(N)-Bibiyana 230 kV Ckt-2 was under shut down from 09:47 to 17:09 due to A/M.</p> <p>b) Aminbazar 230/132 kV T1 transformer was under shut down from 10:49 to 11:54 due to A/M.</p> <p>c) Aminbazar 230/132 kV T2 transformer was under shut down from 11:56 to 12:41 due to A/M.</p> <p>d) Jamalpur 132/33 kV T1 transformer was under shut down from 09:02 to 18:35 due to painting work.</p> <p>e) Agargaon 132/33 kV T2 transformer was under shut down from 12:11 to till now due to A/M.</p> <p>f) Aminbazar-Savar 132 kV Ckt-2 was under shut down from 08:11 to till now due to maintenance work.</p> <p>g) Halishahar 132/33 kV T1 transformer was under shut down from 10:37 to 13:35 due to red hot maintenance work.</p> <p>h) Comilla (S) 132/33 kV T1 transformer was under shut down from 12:02 to 13:44 due to oil leakage maintenance.</p> <p>i) Aminbazar-Kallyanpur 132 Ckt-1 was under shut down from 14:21 to 14:56 due to A/M.</p> <p>j) Aminbazar-Kallyanpur 132 kV Ckt-2 was under shut down from 14:58 to 15:19 due to A/M.</p> <p>k) After maintenance Summit Meghnaghat GT-1 was synchronized at 16:59.</p> <p>l) After maintenance Baghabari 71 MW was synchronized at 20:22.</p> <p>m) After maintenance Sirajganj CCPP 210 MW was synchronized at 21:17.</p> <p>n) Haripur 412 MW CCPP was shut down at 00:21 (03/02/2016).</p> <p>o) Meghnaghat Summit ST was synchronized at 22:51.</p> <p>p) Madunaghat-Kaptai 132 kV Ckt-1 is under shut down since 07:32 (03/02/2016) due to disk insulator replacement work.</p>	
<p>Sub Divisional Engineer Network Operation Division</p>	<p>Executive Engineer Network Operation Division</p>
	<p>Superintendent Load Division</p>

3-Feb-16
4160 7555 7100 455 0
7.867 -
Tk361,066,868
Rates of Shedding (On Estimated Demand)
- - - - - - - -
160MW (23/11/15) ST: Unit-5 ST ower CCPP r CCPP
endent Engineer Dispatch Circle