

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-				8177 MW	21:00	Hrs on	13-Aug-15	Reporting Date : 26-Feb-16	
The Summary of Yesterday's ( 25-Feb-16				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	6076.0	MW	Hour :	12:00	Min. Gen. at	5:00	4771		
Evening Peak Generation :	7475.0	MW	Hour :	19:00	Max Generation :		8040		
E.P. Demand (at gen end) :	7475.0	MW	Hour :	19:00	Max Demand :		7200		
Maximum Generation :	7475.0	MW	Hour :	19:00			840		
Total Gen. (MKWH) :	134.0	System L/ Factor :		74.71%	Load Shed :		0		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-280	MW	a 24:00	Energy	7.867	
Import from West grid to East grid :- Maximum				-	MW	a -	Energy	-	
Water Level of Kapt 26-Feb-16									
Actual :	94.29	Ft.(MSL) ,			Rule curve :	93.45	Ft.( MSL )		
Gas Consumed : Total	945.57	MMCFD.			Oil Consumed (PDB) :				
					HSD : FO :				
Cost of the Consumed Fuel (PDB+Pvt) :									
Gas :			Tk60,776,681						
Coal :			Tk10,709,198		Oil :	Tk219,050,394	Total :	Tk290,536,274	
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand (S/S end)		Today				
	MW		MW		Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)		
Dhaka	-	0:00	2653		-		-		
Chittagong Area	-	0:00	677		-		-		
Khulna Area	-	0:00	754		-		-		
Rajshahi Area	-	0:00	707		-		-		
Comilla Area	-	0:00	554		-		-		
Mymensingh Area	-	0:00	423		-		-		
Sylhet Area	-	0:00	312		-		-		
Barisal Area	-	0:00	147		-		-		
Rangpur Area	-	0:00	407		-		-		
Total	0		6634		0				
Information of the Generating machines under shut down.									
	Planned Shut- Down				Forced Shut- Down				
					1) Ghorasal ST: Unit-6 (18/09) Tongi GT 2) Ashuganj ST: Unit-1(12/0 10) Sikalbaha 60MW (23/11/15) 3) Siddhirgonj GT: Unit-1& 2 11)Ghorasal ST: Unit-1 4) Khulna ST 110 MW (04/1 12) Saidpur GT 5) Ghorasal ST: Unit-4 (05/0 13) Bhola GT-2 6) Haripur GT- 1 & 3 14) Ashuganj : GT-2 7) Chandpur CCPP 15) Chittagong ST: Unit-1 8) Chittagong ST: Unit-2 (18/10/2015)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) After maintenance Kishoreganj 132/33 kV T2 transformer was switched on at 11:51. b) Barisal 132/33 kV T1 & T2 transformers tripped at 13:01 from both side showing O/C relay and were switched on at 13:08 c) Sylhet 132/33 kV T1 & T2 transformers were under shut down from 12:38 to 14:13 due to problem with 33/11 kV distribution transformer.					About 42 MW power interruption occurred under Barisal S/S areas from 13:01 to 13:08. About 30 MW power interruption occurred under Sylhet S/S areas from 12:38 to 14:13.				
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle			