

Description	Comments on Power Interruption
a) Khulna(S) 230/132 kV T1 transformers was under shut down from 09:27 to 17:28 for maintenance work.	About 80 MW power interruption occurred under Bagherhat,Mongla,Bha areas from 12:37 to 12:44
b) Goalpara-Bagherhat 132 kV Ckt tripped at 12:37 from Goalpara end showing dist Z1 relays at the same time KPCL-2 also trip and line was switched on at 12:44 and KPCL-2 was synchronized at 13:01.	
c) Rajshahi-Natore 132 kV Ckt-1 tripped at 15:37 from Rajshahi end showing dist CAS,CE relay and was switched on at 16:12.	
d) Bogra-Natore 132 kV Ckt-2 tripped at 17:20 from both end showing dist C Bogra end & dist C, CAT, PTAW at Natore end and was switched on at 17:45..	
e) Ishurdi-Ghorasal 230 kV Ckt-1 tripped at 18:08 from Ishurdi end showing PD3,PTAW and was switched on at 19:14.	
f) Tongi-Kabirpur 132 kV Ckt-1 tripped at 18:22 from Tongi end showing dist AB,Z1 relay at Ckt-1 and were switched on at 19:05.	
g) Tongi-Kabirpur 132 kV Ckt-2 tripped at 18:22 from Tongi end showing CAR,CAS,CD,CSW,CE relay at Ckt-2 and was switched on at 19:05.	About 60 MW power interruption occurred under Mymensing S/S areas from 05:38 to 06:42
h) Joydabpur-Kodda 132 kV Ckt-1,2 was shut down at 18:22 from Tongi end for 33 kV CB burst at Joydabpur S/S and was switched on at 19:26...	
i) Shaympur-Haripur 132 kV Ckt tripped at 18:30 from Haripur end showing dist AN,Z1 relay and was switched on at 18:52.	
j) Ashuganj-Ghorasal 132 kV Ckt-2 tripped at 19:01 from both end showing dist AB phase relay and was switched on at 19:47.	
k) Narshingdi 132/33 kV T1 transformers tripped at 19:25 due to over voltage and was switched on at 20:10.	
l) Feni-Comilla 132 kV Ckt-1 tripped at 18:15 from both end showing dist Z1,Z2,BC phase and was switched on at 06:27(07/03/2016)	
m) Feni-Comilla 132 kV Ckt-2 tripped at 19:30 from both end showing dist A,Z2,C phase and and was switched on at 06:28(7/03/16)..	
n) Chandpur-Chowmohoni 132 kV Ckt-1,2 tripped at 19:42 from Chandpur end and was switched on at 08:50(7/03/16)..	
o) Ashuganj 225 MW CCPP tripped at 18:22 due to over frequency and was synchronized at 22:18.	
p) Baghabari 100 MW tripped at 23:41 due to exhaust temperature high and was synchronized at 00:37(07/03/16).	
q) Mymensingh 132/33 kV T1 & T3 transformer was shut down from 05:38 to 06:42 (07/03/16) for 33 kV project work.	