POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 21-Jun-16 Till now the maximum generation is:The Summary of Yesterday' 20-Jun-16 8776 MW 21:00 Hrs 15-Jun-16 The Summary of Yesterday' Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand 12:00 Day Peak Generation 7345.0 MW Hour Min. Gen. at 7:00 6563 Evening Peak Generation 8679.0 Max Generation E.P. Demand (at gen end) : 0.0088 MW Hour 21:00 Max Demand (Evening) 8800 Maximum Generation 8679.0 MW Hour 21:00 Reserve(Generation end) 45 System L/ Factor Total Gen. (MKWH) 182.5 87.60% Load Shed 0 EXPORT/ IMPORT THROUGH EAST-WEST INTERCONNECTO Export from East grid to West grid :- Maximum 7.867 -30 MW at 18:30 Energy Import from West grid to East grid :- Maximum MW at Energy Water Level of Kaptai Lake at 21-Jun-16 85.16 Ft.(MSL), 81.30 Ft.(MSL) Actual : Rule curve : Gas Consumed: Total 1072.29 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PI Gas Tk74.176.906 Tk14,335,583 : Tk583,263,470 Total : Tk671,775,959 Coal Load Shedding & Other Information Area Today Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW (On Estimated Demand) 19:30-21:30 3199 Chittagong Area 19:30-21:30 895 12 19:30-21:30 Khulna Area 906 Rajshahi Area 15 19:30-21:30 875 Comilla Area 10 19:30-21:30 659 Mymensingh Are 10 19:30-21:30 500 321 Sylhet Area 0:00 0:00 175 Rangpur Area 8 19:30-21:30 487 Total 8017 Information of the Generating Units under shut down. Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010 9) Sikalbaha 60MW (23/11/15) 2) Ashugani ST: Unit-1 (12/09/201:10) Saidpur GT Nil 3) Ashuganj CCPP 225 MW 4) Khulna ST 110 MW (04/11/2014) 5) Kaptai Hvdro: Unit-5. 6) Haripur GT-1,2,3 7 Bhola GT-2 8) Meghnaghat 450 MW(24/04/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Gopalganj S/S-Gopalganj P/S 132 kV Ckt was under shut down from 09:50 to 10:51 for red hot maintenance at Gopalganj S/S end. b) Barisal(N)-Bhola P/S 230 kV Ckt-2 was under shut down from 09:46 to 16:52 for development work. c) Mongla132/33 kV T1 & T2 transformers tripped at 09:15 from both sides of T1 and 33 kV side of T2 About 20 MW power interruption occurred under Mongla S/S area showing E/F & O/C relay and were switched on at 09:31. d) Mymensingh RPCL GT-1 & ST tripped at 10:12 due to auxiliary failure of ST and GT-1 w as About 60 MW power interruption occurred under Mymensingh, synchronized on at 11:41. Kishoreganj, Niamothpur, Jamalpur, Sherpur S/S areas from 10:12 to 11:41. e) Kabirpur-Manikganj 132 kV Ckt-1 w as under shut down from 11:56 to 13:42 for changing CT ratio About 25 MW power interruption occurred under Manikganj S/S area from 11:56 to 13:42. f) HVDC 20DF22 filter w as under shut down from 12:55 to 13:54 for maintenance w ork g) Shahjibazar 330 MW GT was synchronized at 15:45 and tripped at 16:45. h) Mymensingh 132/33 kV T1 & T2 transformers tripped at 22:16 show ing O/C & Differential relay due to 33 kV About 108 MW power interruption occurred under Mymensingh S/S feeder fault and were switched on at 22:34. area from 22:16 to 22:34. About 45 MW power interruption occurred under Mymensingh S/S

i) Mymensingh 132/33 kV T2 transformer again tripped at 06:20 (21/06/2016) and T1 transformer 33 kV

CB tripped and T1 was switched on at 06:54(21/6/16).

j) Tangail-Kabirpur 132 kV Ckt-2 is shut down since 07:16 (21/06/2016) for project work.

area from 06:20 (21/06/2016) to till now.

Sub Divisional Engineer **Network Operation Division**

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle