| POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER | | | | | | | | | | |
|--|---------------------------|---------------------------|--|---------------|------------------|------------------|--|--------------------------------|-------------------------------|-----------------------|
| | | | | DAILY | REPORT | • | | | Baparting Data : | 10 10 16 |
| Till now the max | kimum genera | tion is : - | 9036 MW | | | | 21:00 | Hrs on | Reporting Date : 30-Jun-16 | 10-Jul-16 |
| The Summary of | | 9-Jul-16 | Generation & | Demand | | | | | | e Gen. & Demand |
| Day Peak Generati Evening Peak Gen | | 5271.0 7361.0 | MW MW | | | Hour : Hour : | 12:00 20:00 | Min. Gen. at Max Generation | 7:00 | 5095 8662 |
| E.P. Demand (at g | | 7361.0 | MW | | | Hour : | 20:00 | Max Demand (Ev | ening): | 8000 |
| Maximum Genera | | 7422.0 | MW | | | Hour : | 22:00 | Reserve (Generati | ion end) | 662 |
| Total Gen. (MKWH | H) : | 143.9 | System L/ Fact | | H EAST-WEST INT | EPCONNECTO | 80.76% | Load Shed | : | 0 |
| Export from East g | rid to West grid | :- Maximum | | | -300 | LIGONALOIO | | 18:30 | Energy | 7.867 |
| Import from West g | | | | - | | | MW at | - | Energy | - |
| Actual | Water Level of 94.88 F | 'KaptaiLake a t.(MSL), | t 10-Jul-16 | | | Rule curve : | 95.44 | Et (MSL) | | |
| Actual : | 94.00 F | L.(IVIOL), | | | | Rule cuive . | 85.44 | Ft.(MSL) | | |
| Gas Consumed : | Total | 992.62 | MMCFD. | | | | Oil Consume | ed (PDB): | HSD : FO : | |
| | | | | | | | | | 10 . | |
| Cost of the Consun | ned Fuel (Pl | Gas | : | Tk6 | 3,721,941 | | | | | |
| | | Coal | : | Tk1 | 6,327,711 | | Oil : | TK223,830,616 | Total : | TK303,880,267 |
| Load Shedding & Other Information | | | | | | | | | | |
| Area | Yester | day | 1 | | | | | Today | | |
| | | | | Estimated | Demand (S/S end) | | | Estimated Sheddi | | Rates of Shedding |
| Dhaka | MW | 0:00 | | | MW | | | | MW | (On Estimated Demand) |
| Dhaka Chittagong Area | - | 0:00 0:00 | | | 2867 802 | | | | - | - |
| Khulna Area | - | 0:00 | | | 801 | | | | - | - |
| Rajshahi Area | - | 0:00 | | | 779 | | | | - | - |
| Comilla Area | - | 0:00 | | | 595 | | | | - | - |
| Mymensingh Area | - | 0:00 | | | 453 | | | | - | - |
| Sylhet Area | - | 0:00 | | | 282 | | | | - | - |
| Barisal Area | - | 0:00 | | | 158 | | | | - | - |
| Rangpur Area | - | 0:00 | | | 439 | | | : | - | - |
| Total | 0 | | | | 7176 | | | 1 | 0 | |
| | | | | | | | | | | |
| | Informati | ion of the Gen | erating Units und | er shut down. | | | | | | |
| Planned Shut- Down | | | | | | | | t- Down | | |
| Nii | | | | | | | 1) Ghorasal ST: Unit-6 (18/07/2010) Sikalbaha 60MW (23/11/15) 2) Ashuganj ST: Unit-1 (12/09/20110) Ashuganj ST: Unit-2 (12/6/16) 3) Ashuganj CCFP 225 WM 4) Khulna ST 110 MW (04/11/2014 12) Sikalbaha 150 MW (07/07/16) 5) Kaptai Hydro: Unit-5, 13) Siddhirganj ST: Grif-2 6) Haripur GT-3 14) Ghorasal ST: Unit-4 7 Bhola GT-2 8) Meghnaghat 450 MW(24/04/2016) | | | |
| | | | | | | | | | | |
| Additional Information of Machines, lines, Interruption / Forced Load shed etc. | | | | | | | | | | |
| Description | | | | | | | 1 | Con | nments on Po | wer Interruption |
| | | | | | | | | | | |
| a) Hathazari 230/132 kV MT2 tripped at 07:46 show ing 5BCD,1GF & 4GL and w as sw itched on at 16:38. b) Joydebpur 132/33 kV T3 transformer tripped at 08:50 due to breaker problem of 33 kV Konabari feeder and w as sw itched on at 19:38. c) Aminbazar 230/132 kV TR3 transformer w as under shut dow n from 09:04 to 12:56 to attend LT & HT bushing red hot. d) Tripura-Comila(S) 132 kV Ckt-1 & 2 tripped at 13:55 from Tripura end and w as sw itched on at 14:43. e) Aminbazar 230 kV TR2 transformer w as under shut dow n from 15:35 to 16:30 due to red hot at 13:55 to 14:43. | | | | | | | | | er Comila(S) S/S area | |
| f) Kulaura 132/33 kV TR2 transformer tripped at 15:01 showing Buchholz relay and was switched on at 16:27 g) Rajshahi-Natore 132 kV Ckt-2 tripped at 20:30 from Natore end showing no signal and switched on at 20:44 Again tripped at 20:44 from Natore end and was switched on at 21:03. h) Rajshahi-Natore 132 kV Ckt-1 tripped at 20:30 from Rajshahi end showing O/C and was switched | | | | | | | About 180 M | /W power interrup | | |
| on at 20:58.Along this tripping Amnura 50 MW ,Rajshahi NPSL also tripped and were synchronized at 21:36 & 21:20 respectively. i) Comila(S) 132/33 kV T3 transformer tripped at 20:46 operating PRD. | | | | | | | Chapainaw a | abganj S/S areas f | rom 20:30 to 20:5 | 8. |
| Sub Divisional Engineer Network Operation Division | | Ν | Executive Engineer Network Operation Division | | | | oerintendent E .oad Dispatch | - | | |