POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Till now the maximum generation is :-9036 MW 30-Jun-16 The Summary of Yesterday's Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 6476 0 N/M// 12:00 Min. Gen. at 7:00 ഒറുള Evening Peak Generation 8197.0 MW 21:00 Max Generation 8924 8197.0 8500 E.P. Demand (at gen end) : MW 21:00 Max Demand (Evening) : Maximum Generation 8197.0 MW 21:00 Reserve (Generation end) Total Gen. (MKWH) 164.8 System L/ Factor 83.78% oad Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

-280 MW

Export from East grid to West grid :- Maximum 18:30 Energy 7.867 Import from West grid to East grid :- Maximum MW Energy

Water Level of Kaptai Lake at 6:00, 13-Jul-16

95.78 Rule curve : 85.92 Ft.(MSL) Actual Ft.(MSL)

1037.68 MMCFD. Gas Consumed : Total Oil Consumed (PDB):

HSD FO

Reporting Date :

13-Jul-16

Cost of the Consumed Fuel (PDB+P) Gas Tk68,562,508

Coal Tk16,015,222

: Tk388,649,780 Total : Tk473,227,510

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	-	0:00	3130		
Chittagong Area	-	0:00	875		
Khulna Area	-	0:00	884		
Rajshahi Area	-	0:00	855		
Comilla Area	-	0:00	646		
Mymensingh Area	-	0:00	491		
Sylhet Area	-	0:00	313		
Barisal Area	-	0:00	171		
Rangpur Area	-	0:00	477		
Total	0		7842		0

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut-Down
	1) Ghorasal ST: Unit-6 (18/07/20109) Sikalbaha 60MW (23/11/15)
Nil	2) Ashuganj ST: Unit-1 (12/09/201է10) Siddhirganj ST (6/07/2016)
	3) Ashuganj CCPP 225 MW 11) Ashuganj GT: Unit-2 (29/6/16)
	4) Khulna ST 110 MW (04/11/2014 12) Ghorasal ST: Unit-4
	5) Kaptai Hydro: Unit-5, 13) Ghorasal ST: Unit-2
	6) Haripur GT-3
	7 Bhola GT-2
	8) Meghnaghat 450 MW (24/04/2016)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption

- a) Halishahar 132/33 kV T-3 transformer was under shut down from 08:58 to 20:25 for replacing 33 kV CT.
- b) Bogra 132/33 kV T-2 transformer was under shut down from 10:24 to 14:16 for red hot maint. at 132 kV CB terminal.
- c) Summit Bibiyana #2 ST was shut down at 10:19 for gland sealing problem.
- d) Khulna CCPP 225 MW GT tripped at 10:16 showing supervision alarm and was sync.at 11:51.
- e) Siddirganj Desh-100 MW tripped at 10:12 due to Y-phase PT burst and was sync.at 11:55.
- f) After maintenance Ashuganj ST #2 was synchronized at 00:12(13/7/16).
- and Ckt-1 was switched on at 07:28 (13/7/16).

g) Rampura-Mothertek 132 kV Ckt-1 & 2 tripped at 06:20 (13/7/16) showing diff.E/F & 🗛 Dout 30 MW power interruption occurred under Mothertek S/S areas from 06:20 to 07:28 (13/7/16).

h) Noapara 33 kV Bus was shut down at 07:10 (13/7/16) for red hot maintenance at 33 About 20 MW power interruption occurred under Noapara S/S areas feeder Bus isolator

since 07:10 (13/7/16).

i) Sitalakkha 132/33 kV GT-2 transformer is under shut down at 07:52(13/7/16) for main About 20 MW power interruption occurred under Sitakkha S/S areas

since 07:52 (13/7/16).

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer **Load Dispatch Circle**