			R GRID COMPANY OF BAN TIONAL LOAD DESPATCI DAILY REPORT			D.		
			DAILY REPORT				Reporting Date :	14-Jul-16
Till now the maxi			9036 MW		21:00	Hrs on	30-Jun-16	
The Summary of		13-Jul-16	Generation & Demand			Today's Actual Min Gen. & Pr		
Day Peak Generation		6861.0	MW	Hour :	12:00	Min. Gen. at	7:00	6445
Evening Peak Gene		8366.0	MW	Hour :	21:00	Max Generation :		8763
E.P. Demand (at ge		8366.0	MW	Hour :	21:00	Max Demand (Evening) :		8700
Maximum Generati		8366.0	MW	Hour :	21:00	Reserve (Generation end)		63
Total Gen. (MKWH)	: :	172.1	System L/ Factor :		85.71%	Load Shed :		0
			XPORT / IMPORT THROUGH EAST-WEST INTE				_	
Export from East gri			-190			19:00	Energy	7.867
mport from West gr	Water Level of		-		MW at	-	Energy	
Actual :		t.(MSL),		Rule curve :	86.08	Ft.(MSL)		
/totadi .		(moz) ,		rtaio carro :	00.00	r a (moz)		
Gas Consumed :	Total	1060.61	MMCFD.		Oil Consume	d (PDB):		
							HSD :	
							FO :	
Cost of the Consum	ed Fuel (PDE	Gas	: Tk70,210,467		0.11			
		Coal	: Tk15,546,489		Oil :	Tk452,168,441	Total :	Tk537,925,397
	Lo	ad Shedding &	Other Information					
Area	Yestero	lav				Today		
		,	Estimated Demand (S/S end)			Estimated Shedding (S/S end)		Rates of Shedding
	MW		MW				MW	(On Estimated Demand)
Dhaka	-	0:00	3183				-	-
Chittagong Area	-	0:00	890				_	_
Khulna Area	_	0:00	901					
Rajshahi Area	_	0:00	870				_	_
Comilla Area	_	0:00	656				_	-
Mymensingh Area	-	0:00	498				•	•
Sylhet Area	-	0:00	319					
Barisal Area	-	0:00	174				•	•
Rangpur Area	-	0:00	485				-	
rtangpui Arca	_	0.00	400					
Total	0		7976				0	
	Informatio	n of the Gener	ating Units under shut down.					
	Planned Shut- Down					- Down		
						ST: Unit-6 (18/07/2010)		60MW (23/11/15)
	Nil				Ashuganj	ST: Unit-1 (12/09/2015)		nj ST (6/07/2016)
					3) Ashuganj	CCPP 225 MW	11) Ashugan	j GT-2
					4) Khulna S	T 110 MW (04/11/2014)	12) Ghorasa	I ST: Unit-4
					Kaptai Hy	dro: Unit-5,	13) Ghorasal	ST: Unit-2
				1	Haripur G	T-3	14) Rangpur	GT
					7 Bhola GT-		15) Saidpur	GT
					Meghnag	hat 450 MW(24/04/2016)		
	Additional Info	ormation of Ma	chines, lines, Interruption / Forced Load shed etc	c.				
Description					Comments on Power Interruption			
a) Hasnabad 230/ on at 17:58.	132 kV TR-2 tr	ansformer trip	ped at 11:32 showing E/F relay and was switched	ed				
b) After maintenar			as synchronized at 13:11.					
c) After maintenance Megnaghat-450 MW GT-2 was synchronized at 12:35 for steam blowing purpose. d) Madaripur 132/33 kV T-3 transformer tripped at 12:52 showing O/C & E/F relays and was switched on at 14:31.					About 15 MW power interruption occurred under Madaripur S/S areas from 12:52 to 14:31.			
e) Haripur EGCB (f) Khulna CCPP-2			15:37. 4/7/16) due to feed water pump problem.					
	onal Engine		Executive Engineer Network Operation Division	1	•	erintendent Engineer oad Dispatch Circle		