	PC		COMPANY OF E					
		NATIONAL	LOAD DESP <i>A.</i> DAILY REPO		IIEK			
Till now the maxi	imum generation is : -	9036 MW	DAILT KEFO	KI	21:00	Hrs on	Reporting Date: 30-Jun-16	15-Jul-16
The Summary of	Yesterday's 14-Jul-	16 Generation & D	emand			Today's Actual M	lin Gen. & Probabl	e Gen. & Demand
Day Peak Generation	on : 7276.) MW		Hour :	12:00	Min. Gen. at	7:00	6282
Evening Peak Gene	eration: 8528.	O MW		Hour:	20:00	Max Generation	:	8939
E.P. Demand (at ger	n end) : 8528.			Hour:	20:00	Max Demand (Eve	ening) :	8600
Maximum Generation	on : 8528.	O MW		Hour:	20:00	Reserve (Generat	ion end)	339
Total Gen. (MKWH)	: 178.9	System L/ Factor	r :		87.41%	Load Shed	:	0
		EXPORT / IMPO	RT THROUGH EAST-WEST	T INTERCONNECT	OR	•		
Export from East gri	id to West grid :- Maximu	m	-210		MW at	18:30	Energy	7.867
mport from West gr	rid to East grid :- Maximu	m -			MW at	-	Energy	-
	Water Level of Kaptai La							
Actual :	95.65 Ft.(MSL),			Rule curv	e: 86.24	Ft.(MSL)		
Gas Consumed :	Total 1052.0	9 MMCFD.			Oil Consume	d (PDB):		
							HSD :	
							FO :	
Cost of the Consum	ed Fuel (PDI (Sas :	Tk68.324.087					
		oal :	Tk15,937,102		Oil	Tk522,534,990	Total	Tk606,796,178
	Load Shede	ling & Other Information	<u>on</u>					
Area Yesterday						Today		
			Estimated Demand (S/S)	end)		Estimated Sheddii	ng (S/S end)	Rates of Shedding
	MW		MW				MW	(On Estimated Demand
Dhaka	- 0:00		3192					-
Chittagong Area	- 0:00		893				-	_
Chulna Area	- 0:00		904				_	
Rajshahi Area	- 0:00		873					
Comilla Area								
	- 0:00		657				-	-
Mymensingh Area	- 0:00		499				-	-
Sylhet Area	- 0:00		320				-	-
Barisal Area	- 0:00		175				-	-
Rangpur Area	- 0:00		486				-	-
Total	0		7999				0	
IOlai	U		1333				<u> </u>	
	Information of the 0	Senerating Units under s	hut down.					
	Planned Shut- Down				Forced Shu	- Down		
					1) Ghorasa	ST: Unit-6 (18/07	/201(9) Sikalbaha	60MW (23/11/15)
	Nil						9/201! 10) Siddhirga	
						anj CCPP 225 MW 11) Ashuganj GT-2		
							/201412) Ghorasa	
						/dro: Unit-5,		
							13) Ghorasal	
					6) Haripur (14) Rangpu	
					7 Bhola GT		15) Saidpur	GI
					8) Meghnaç	hat 450 MW(24/0	4/20116) Sylhet 15	0 MW
	Additional Information	of Machines, lines, Inte	erruption / Forced Load she	d etc.				
	Additional Information	of Machines, lines, Inte	erruption / Forced Load she	d etc.		Comn	nents on Powe	r Interruption
		of Machines, lines, Inte	erruption / Forced Load she	d etc.		Comn	nents on Powe	r Interruption
a) After maintenar	Description nce Ashuganj 450 MW	was synchronized at 0	8:12.					•
a) After maintenar	Description nce Ashuganj 450 MW	was synchronized at 0			About 35 M		nents on Powe	•
a) After maintenar b) Ghorasal 132/3:	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri	was synchronized at 0	8:12. g E/F, O/C and switched on	at 10:40.		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from	8:12. g E/F, O/C and switched on Ashuganj end showing Dist	at 10:40.		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was nce Khulna 150 MW ST	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at	8:12. g E/F, O/C and switched on Ashuganj end showing Dist l1:08.	at 10:40. ance,RST,Genera		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan e) Ishurdi-Ghorasa	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was nce Khulna 150 MW ST al 230 kV Ckt-2 was trip	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at 1 ped at 11:40 showing	8:12. g E/F, O/C and switched on Ashuganj end showing Dist	at 10:40. ance,RST,Genera		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan a) Ishurdi-Ghorasa DT at Ghorasal	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was ice Khulna 150 MW ST al 230 kV Ckt-2 was trip end and switched on a	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at ped at 11:40 showing 12:10.	8:12. gE/F, O/C and switched on Ashuganj end showing Dist 1:08. DT, PD3 at Ishurdi end and	at 10:40. ance,RST,Genera		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan e) Ishurdi-Ghorasa DT at Ghorasal f) Matuail GT-1 wa	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was nce Khulna 150 MW ST al 230 kV Ckt-2 was trip end and switched on a as under shut down fror	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at 1 ped at 11:40 showing 12:10.	8:12. BE/F, O/C and switched on Ashuganj end showing Dist 11:08. DT, PD3 at Ishurdi end and occrrective maintenance	at 10:40. ance,RST,Genera		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan e) Ishurdi-Ghorasa DT at Ghorasal f) Matuail GT-1 wa g) Baghabari 71 M	Description nce Ashuganj 450 MW 3 kV T-1 transformer tir gganj 132 kV Ckt-1 was nce Khulna 150 MW ST al 230 kV Ckt-2 was trip end and switched on a su under shut down fror IW was shut down at 0f	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at 1 ped at 11:40 showing 12:10. 07:30 to 09:25 due to 1:17(15/07/2016) for m	8:12. g E/F, O/C and switched on Ashuganj end showing Dist 11:08. DT, PD3 at Ishurdi end and o corrective maintenance aintenance work.	at 10:40. ance,RST,Genera		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan e) Ishurdi-Ghorasa DT at Ghorasal f) Matuail GT-1 wa g) Baghabari 71 M	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was nce Khulna 150 MW ST al 230 kV Ckt-2 was trip end and switched on a as under shut down fror	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at 1 ped at 11:40 showing 12:10. 07:30 to 09:25 due to 1:17(15/07/2016) for m	8:12. g E/F, O/C and switched on Ashuganj end showing Dist 11:08. DT, PD3 at Ishurdi end and o corrective maintenance aintenance work.	at 10:40. ance,RST,Genera		W power interrupt		•
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan e) Ishurdi-Ghorasa DT at Ghorasal f) Matuail GT-1 wa g) Baghabari 71 M	Description nce Ashuganj 450 MW 3 kV T-1 transformer tri uganj 132 kV Ckt-1 was ice Khulna 150 MW ST al 230 kV Ckt-2 was trip end and switched on a as under shut down fror IVI was shut down at 0 was shut down at 05:0	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at ped at 11:40 showing 12:10. n 07:30 to 09:25 due to 1:17(15/07/2016) for m 5 due to filter changing	8:12. g E/F, O/C and switched on Ashuganj end showing Dist 11:08. DT, PD3 at Ishurdi end and o corrective maintenance aintenance work.	at 10:40. ance,RST,Genera I PTAW,	I tri areas from	W power interrupt 09:42 to 10:40.	ion occurred unde	r Ghorasal S/S
a) After maintenar b) Ghorasal 132/3: c) Serajgonj -Ashu d) After maintenan e) Ishurdi-Ghorasa DT at Ghorasal d) Matuail GT-1 wa g) Baghabari 71 M	Description nce Ashuganj 450 MW 3 kV T-1 transformer tir gganj 132 kV Ckt-1 was nce Khulna 150 MW ST al 230 kV Ckt-2 was trip end and switched on a su under shut down fror IW was shut down at 0f	was synchronized at 0 pped at 09:42 showing tripped at 10:54 from was synchronized at 1 ped at 11:40 showing 12:10. 107:30 to 09:25 due to 1:17(15/07/2016) for m 5 due to filter changing	8:12. g E/F, O/C and switched on Ashuganj end showing Dist 11:08. DT, PD3 at Ishurdi end and o corrective maintenance aintenance work.	at 10:40. ance,RST,Genera I PTAW,		W power interrupt 09:42 to 10:40.		r Ghorasal S/S