POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date 7-Aug-16 Till now the maximum generation is: 9036 MW 21:00 Hrs The Summary of Yester Day Peak Generation Evening Peak Generation Generation & Demand MW MW Today's Actual Min Gen. & Probable Gen. & Dem Min. Gen. at 8:00 6175 Max Generation : 8770 6-Aug-16 6822.0 8438.0 12:00 19:30 MW E.P. Demand (at gen end) 8438.0 19:30 Max Demand (Evening) 8700 Maximum Generation 8438.0 MW 19:30 Reserve (Generation end) 70 Total Gen. (MKWH) System L/ Factor : 85.68% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 173.5 Load Shed Export from East grid to West grid :- Maxim Import from West grid to East grid :- Maxim Water Level of Kaptai Lake7-Aug-16 MW a 18:30 7.867 Actual: 96.18 Ft.(MSL), 90.92 Ft.(MSL) Gas Consumed Total 1060.88 MMCFD Oil Consumed (PDB) HSD FO Tk78,411,942 Cost of the Consumed Fue Tk7,691,086 : Tk426,778,522 Total : Tk512,881,551 Load Shedding & Other Information Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding On Estimated Dema Chittagong Are 0:00 901 Khulna Area 0:00 913 0:00 881 Comilla Area 0:00 663 My mensingh A Sy lhet Area 503 323 0:00 0:00 Barisal Area 0:00 176 Rangpur Area 490 Total 8071 Information of the Generating Units under shut down Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/0 10) Ghorasal ST: Unit-4 2) Ashuganj ST: Unit-1 11) Haripur GT-3. 3) Ashuganj CCPP 225 MW 4) Khulna ST 110 MW (04/11/2014) 5) Kaptai Hydro: Unit-5 6) Ghorasal ST: Unit-5 7 Bhola GT-2 8) Meghnaghat 450 MW(24/04/2016) 9) Barapukuria ST: Unit-1 Additional Information of Machines, lines, Interruption / Forced Load shed etc Description Comments on Power Interruption a) Bakulia 132/33 kV T3 transformer was under shut down from 08:57 to 12:35 for 33 kV breaker replacement. b) Maniknagar 230/132 kV T1 transformer was under shut down from 09:09 to 10:37 due to oil leakage. c) Siddhirganj 132/33 kV T1 & T2 transformers tripped at 12:33 showing O/C relay and wen About 116 MW power interruption occurred under Siddhirgan from 12:33 to 12:39. d) Kaptai Unit-3 was under shut down from 12:50 to 13:05 to reset control system. e) After maintenance Haripur-Siddhirganj 132 kV Ckt-1 was switched on at 22:15. f) Sikalbaha 150 MW was shut down at 22:47 due to problem at cooling water pump. g) Bottail 33 kV Bus was under shut down from 06:25 to 07:22 (07/08/2016) due to red hot I About 65 MW power interruption occurred under Bottail S/S at 33 kV housing feeder. h) Tongi 132/33 kV T1 transformer was under shut down from 07:02 to 08:15 (07/08/2016) due to 33 kV CT terminal red hot. Sub Divisional Engineer Executive Engineer Superintendent Engineer

Network Operation Division

Load Dispatch Circle

Network Operation Division