

Load Shedding & Other Information

Information of the Generating machines under maintenance

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to gas pressure low, RPCL (175 MW) , Siddhirganj (190 MW), Tongi (105 MW) and Haripur Power Co. Ltd. (360 MW) were limited to 105 MW, 100 MW, 70MW and 271MW respectively.</p> <p>c) Due to gas limitation, Raozan -2, Sikalbaha Barge & Steam and Shahjibazar -2, 3, 5 are under shut down.</p> <p>d) Due to low water level, Kaptai - 2 & 5 are under shut down.</p> <p>e) Comilla (N) - Ashuganj 230 KV line -1 was under shut down from 08:32 to 14:06 due to NLDC project work.</p> <p>f) Ishurdi - Pabna 132 KV line was under shut down from 08:23 to 14:01 due to OPGW work.</p> <p>g) Rampura - Basundhara line -1 was under shut down from 08:35 to 11:08 due to red hot maintenance of B- phase isolator at Rampura end.</p> <p>h) Noapara - Jessore 132 KV line -1 was under NLDC project work at 10:07. It is still under maintenance</p> <p>i) Dohazari - Cox'sbazar line-2 was under shut down from 10:28 to 13:20 due to flashing at tower # 74.</p> <p>j) Mymensing 132/33 kV T1 and T3 transformers was under shut down from 12:02 to 12:50 & 11:59 to 14:35 respectively due to red hot maintenance at 33 KV bus isolator.</p> <p>k) Chatak 132/33 kV T2 transformer was under annual maintenance from 12:47 to 13:28</p> <p>l) Hathazari 132/33 kV T2 transformer was under shut down from 20:40 to 21:05 due to red hot maintenance at 33 KV bus isolator.</p> <p>m) Pabna - Baghabari - Shahjadpur 132 KV line was under shut down at 08:14 (23/04/09) due to OPGW work.</p> <p>n) Khulna - Ishurdi 230 KV line-1 & Comilla - Ashuganj 230 KV line -2 were under shut down at 08:30 (23/04/09) & 08:29 (23/04/09) due to NLDC project work.</p>	<p>So about 1192 MW (19:00) of load shed was imposed over the whole area (except Sylhet) of the national grid.</p> <p>Partial power interruption (26 MW) occurred under Mymensing S/S areas from 12:02 to 12:50 .</p> <p>Due to generation shortage and MVAR problem , about 450 MW (09:00) of load shed has been running since morning (23/04/09) over the whole area (except Sylhet) of the national grid.</p>

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle