POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date 29-Sep-16 Till now the maximum generation is : The Summary of Yesterday! 28-Sep-16 Day Peak Generation : 7209.0 9036 MW Hrs 30-Jun-16 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Hour 12:00 6441 Evening Peak Generation 8593.0 Hour Max Generation 9260 E.P. Demand (at gen end) : 8750.0 MW Hour 20:00 Max Demand (Evening) 8900 Maximum Generation 8628.0 MW 21:00 Reserve (Generation end) 360 Total Gen. (MKWH) System L/ Factor 182.5 88.12% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 7.867 -300 at 9:00 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 29-Sep-16 MW Energy 107.54 Ft.(MSL), Rule curve : 105.52 Ft.(MSL) Actual : Gas Consumed : Total 1012.95 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PI Gas Tk78.494.763 Tk15,546,481 : Tk515,559,111 Total : Tk609,600,355 Coal Load Shedding & Other Information Today Area Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW (On Estimated Dema Dhaka Chittagong Area 19 0:00 904 19 0:00 917 Khulna Area Rajshahi Area 21 0:00 884 Comilla Area 14 0:00 665 Mymensingh Are 14 0:00 505 Sylhet Area 9 0:00 324 0:00 177 Rangpur Area 12 0.00 492 Total 141 8100 Information of the Generating Units under shut down. Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(10) Sikalbaha ST 2) Chittagong ST: Unit-1 11) Svlhet 20 MW GT Nil 3) Ashuganj ST: Unit- 1 12) Siddhirgonj GT: Unit-1 4) Khulna ST 110 MW (04/11/2014 13) Meghnaghat 450 MW 5) Kaptai Hydro: Unit-5 6) Ashuganj GT2 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT- 3 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Rangpur-Palashbari 132 kV Ckt-1 w as under shut down from 09:08 to 10:08 due to red hot at CT clamp at Rangpur end. b) Natore 132/33 kV T1 transformer was under shut down from 09:05 to for A/M. About 7MW power interruption occurred under Natore S/S area c) After maintenance Bhola GT-2 w as synchronized at 10:04. from 09:05 to d) After maintenance Chandpur 150 MW CCPP ST was synchronized at 18:27. e)Comilla(N)-Bibiyana 230 kV Ckt-2 tripped at 15:54 from both end showing dist Z1 at both ends and w as switched on at 16:07. f) Sirajganj 225 MW GT was shut down at 05:56 (29/09/2016) for gas booster maintenance. g) Haripur 412 MW GT was shut down at 06:17 (29/09/2016) due to DP high. h) Kaptai Unit-4 was shut down at 01:27 (29/09/2016) due to leakage at head cover drainage pump. i) Goalpara-Bagherhat 132 kV Ckt-2 tripped at 06:18 (29/09/2016) from Bagherhat end showing dist DT-2.3 and was switched on at 06:41. j) Hathazari 132/33 kV T1 transformer is shut down since 07:33 (29/09/2016) for corrective maintenance. k) Siddhirganj Peaking GT-2 w as synchronized at 07:45 (29/09/2016). Sub Divisional Engineer **Executive Engineer** Superintendent Engineer **Network Operation Division Network Operation Division** Load Dispatch Circle