## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 27-Oct-16 Till now the maximum generation is : - 9036 MW 21:00 Hrs 30-Jun-16 The Summary of Yester 26-Oct-16 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 12:00 Hour Min. Gen. at Evening Peak Generation 8850.0 MW Hour : 19:00 Max Generation 9210 E.P. Demand (at gen end) 19:00 Max Demand (Evening) 8500 Maximum Generation 8850.0 MW Hour 19:00 Reserve (Generation end) 710 System L/ Factor Total Gen. (MKWH) 178.4 83.99% Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 7.867 Export from East grid to West grid :- Maximum -190 MW at 15:00 Energy Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 27-Oct-16 108.50 Ft.( MSL ) Actual: Rule curve : 106.85 Ft.(MSL) Gas Consumed: Total 1022.56 MMCFD. Oil Consumed (PDB): HSD : FO Cost of the Consumed Fuel (F Gas Tk75.182.589 Coal Tk15.585.549 : Tk393,400,626 Total: Tk484,168,764 Load Shedding & Other Information Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) Dhaka 0:00 3154 Chittagong Area 0 0:00 882 Khulna Area 0:00 892 Raishahi Area 0 0.00 862 Comilla Area 0 0:00 650 Mymensingh Are 0 0.00 494 0 315 Sylhet Area 0:00 Rarisal Area 0 0:00 173 Rangpur Area 0 0:00 480 Total 0 7902 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 10) Chandpur CCPP ST 2) Kaptai Unit-5 11) Tongi GT 3) Ashuganj ST: Unit- 1 12) Chittagong ST Unit-2 4) Khulna ST 110 MW (04/11/2014) 13) Ashugonj CCPP South 5) Ghorasal Unit-5 6) Baghabari 100 MW 7) Haripur SBU GT- 3 8) Sylhet 20 MW GT 9) Ghorasal Unit-4 (13/10/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Sirajgonj 132/33 kV was under shut down from 07:30 to 13:54 for A/M. About 4 MW pow er interruption occurred under Sirajgonj S/S area b) Barisal(Old) 132/33 kV T-1 transformer was under shut down from 07:04 to 16:33 for A/M. from 07:30 to 13:54. c) Bheramara HVDC-Khulna (S) 230 kV Ckt-2 was under shut down from 07:54 to 16:53 for A/M. d) Bagerhat 132/33 kV T-1 transformer was under shut down from 09:09 to 16:26 for A/M. About 4 MW pow er interruption occurred under Bagerhat S/S area e) Palashbari 132/33 kV T-2 transformer was under shut down from 08:17 to 16:40 for A/M. from 09:09 to 16:26. f) Bheramara HVDC 400 kV 10CF15 filter w as isolated from 09:53 to 16:58 for maintenance. g) Mongla 132 kV Bus bar was under shut down from 09:53 to 16:58 for A/M. About 20 MW power interruption occurred under Mongla S/S area h) After maintenance Khulna 225 MW CCPP STG was synchronized at 11:20. from 09:53 to 16:58. i) Ghorashal-Ashugonj South 230 kV Ckt-2 tripped at 14:48 from both end showing Y-phase, E/F and switched on at 15:28. j) Tongi 33 kV Bus under T-1 & T-2 were under shut down from 13:30 to 14:33 for 33 kV Uttara feeder Redhot maintenance. About 60 MW pow er interruption occurred under Daksin khan ADA, k) Ashugonj 450 MW was shut down at 00:41(27/10/2016) due to gas line tie-in work. Uttara, Board bazar &Tongi S/S area from 13:30 to 14:33. I) Shyampur-Hasnabad 132 kV tripped at 07:10 from Hasnabad showing Dist. Z1, B-phase and switched on at 07:17. Sub Divisional Engineer Executive Engineer Superintendent Engineer

**Network Operation Division** 

Load Dispatch Circle

Network Operation Division