POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

DAILY REPORT

Reporting Date: 5-Nov-16 Till now the maximum generation is: -9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yesterda 4-Nov-16 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 5301.0 MW Hour: 9:00 Min. Gen. at 7:00 4902 Evening Peak Generation 7263.0 MW Max Generation 9481 Hour: 19:30 E.P. Demand (at gen end) 7263.0 MW 19:30 Max Demand (Evening) 8000 Hour Maximum Generation 7263.0 MW Hour 19:30 Reserve (Generation end) 1481 Total Gen. (MKWH) System L/ Factor 84.55% Load Shed 147.4 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum at 17:00 Energy 7.867

Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 5-Nov-16

105.48 Ft.(MSL)

868 00

MMCFD

Oil Consumed (PDB):

108.60

MW

Rule curve :

HSD FO

Energy

Cost of the Consumed Fuel (F

Actual Gas Consumed: Total

Gas

Tk69,016,415 Tk15,741,793

Oil : Tk206,766,547

Ft.(MSL)

Total: Tk291,524,755

Load Shedding & Other Information

Area	Yesterday			Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	2990	-	-
Chittagong Area	0	0:00	836	-	-
Khulna Area	0	0:00	840	=	-
Rajshahi Area	0	0:00	814	-	-
Comilla Area	0	0:00	618	-	-
Mymensingh Area	0	0:00	471	-	-
Sylhet Area	0	0:00	296	-	-
Barisal Area	0	0:00	164	-	-
Rangpur Area	0	0:00	456	-	-
Total	0		7485	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

Forced Shut-Down

- 1) Ghorasal ST: Unit-6 (18/07/2010 10) Chandpur CCPP ST
- 2) Kaptai Unit-5 11) Tongi GT
- 3) Ashuganj ST: Unit- 1 12) Chittagong ST Unit-2 4) Khulna ST 110 MW (04/11/2014 13) Ashuganj #3 (1/11/16) 5) Ghorasal Unit-5 14) DPA Pagla 50 MW

- 6) Baghabari 100 MW 7) Haripur SBU GT- 3 8) Ashugonj CCPP South
- 9) Ghorasal Unit-4 (13/10/2016)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

Comments on Power Interruption

- a) Chandpur 132/33 kV T-1 transformer was under shut down from 08:20 to 08:58 due to Red hot at 33 kV side R-phase isolator.
- About 24 MW power interruption occurred under Chandpur S/S area from 08:20 to 08:58.
- b) Rajshahi 132/33 Kv TR-2 transformer was under shut down from 08:38 to 10:40 for 132 kV side CB maintenance work c) Bhulta 132/33 kV T-2 transformer was under shut down from 09:26 to 12:48 for changing 33 kV side PT.
- d) Ullon-Rampura 132 kV Ckt-1 was shut down at 08:21 for development work.
- e) After maintenance Ashuganj 225 MW was synchronized at 12:19.
- f) After maintenance Siddhirganj GT-2 was synchronized at 13:03.
- g) Chandpur 132/33 kV T-2 transformer was under shut down from 15:30 to 17:54 due to 33 kV DS maintenance of Matlab feeder
- h) Jamalpur S/S-Jamalpur 100 MW P/P 132 kV Ckt charged at 17:28 from Jamalpur.
- i) Comilla(N)-Meghnaghat 230 kV Ckt-1 was opened at 22:221 from Comilla (N) due to Red hot at R-phase line isolator of Comilla (N) end and switched on at 07:58 (05/11/2016)
- j) After maintenance Ashuganj 225 MW CCPP ST was synchronized at 00:01(05/11/2016).
- k) Bibiyana-Comilla(N) 230 kV Ckt-2 was shut down at 06:20 (05/11/2016) due to development work.
- I) Comilla(N) 132/33 kV T-04 transformer tripped at 05:58 (05/11/2016) from both end showing winding temperature high.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle