POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 7-Nov-16 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yester 6-Nov-16 Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand Hour Min. Gen. at Evening Peak Generation 7200.0 MW Hour 19:30 Max Generation 9140 E.P. Demand (at gen end) 7200.0 Hour 19:30 Max Demand (Evening) 7600 Maximum Generation 7200.0 MW Hour 19:30 Reserve (Generation end) 1540 Total Gen. (MKWH) System L/ Factor 123.2 71.32% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 7.867 Export from East grid to West grid :- Maximum -160 MW at 16:00 Energy Import from West grid to East grid :- Maximum Energy at Water Level of Kaptai Lake at 7-Nov-16 108.40 Ft.(MSL) Rule curve : Actual: 105.69 Ft.(MSL) Gas Consumed: Total 833.34 MMCFD. Oil Consumed (PDB): HSD FΟ Cost of the Consumed Fuel (F Gas Tk55.680.358 Coal Tk15.898.038 : Tk139,663,790 Total: Tk211,242,186 Load Shedding & Other Information Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) 0:00 Chittagong Area 0 0:00 787 Khulna Area 0:00 785 Raishahi Area n 0.00 764 0 0:00 585 Comilla Area Mymensingh Are 0 0.00 446 Sylhet Area 0 0:00 276 Rarisal Area 0 0:00 156 Rangpur Area 0 0:00 431 Total 0 7045 Information of the Generating Units under shut dow n. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(10) Chandpur CCPP ST 2) Kaptai Unit-5 11) Tongi GT 3) Ashuganj ST: Unit- 1 12) Chittagong ST Unit-2 4) Khulna ST 110 MW (04/11/2014 13) Ghorasal Unit-3 5) Ghorasal Unit-5 14) DPA Pagla 50 MW 6) Baghabari 100 MW 7) Haripur SBU GT- 3 8) Ashugonj CCPP South 9) Ghorasal Unit-4 (13/10/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Hasnabad 132/33 kV T5 transformer was under shut down from 08:31 to 17:22 for A/M. b) Kabirpur-Manikganj 132 kV Ckt-1 was under shut down from 09:50 to 12:53 for A/M. c) My mensing 132/33 kV T3 transformer was under shut down from 08:14 to 14:20 for A/M. d) Kishoreganj 132/33 kV T2 transformer was under shut down from 09:15 to 15:30 for A/M. e) Jamalpur-Sherpur 132 kV Ckt-1 was under shut down from 08:02 to 16:05 for A/M. f) Aminbazar-Tongi 230 kV Ckt-2 was under shut down from 09:06 to 13:48 for A/M. g) B.Baria 132/33 kV T2 transformer was under shut down from 10:02 to 11:25 for A/M. h) B.Baria 132/33 kV T3 transformer was under shut down from 11:28 to 16:44 for A/M. i) Rampura-Bashundhara 132 kV Ckt-1 was under shut down from 08:02 to 15:48 for A/M. j) Sirajganj-Baghabari 230 kV Ckt-1 was under shut down from 08:16 to 14:56 for A/M. k) B.Baria 132/33 kV T3 transformer was under shut down from 10:28 to 16:44 for A/M. I) Rampura-Basundhara 132 kV Ckt-1 was under shut down from 08:02 to 15:48 for A/M. m) Sirajganj-Baghabari 230 kV Ckt-1 was under shut down from 08:16 to 14:56 for A/M. n) Siraigani 132/33 kV T3 transformer was under shut down from 09:14 to 15:44 for A/M. o) Natore-Ishurdi 132 kV Ckt-2 was under shut down from 08:22 to 14:49 for A/M. p) Gopalganj 132/33 kV T5 transformer was under shut down from 08:41 to 16:33 for A/M. g) Bottail 132/33 kV T1 transformer was under shut down from 09:05 to 12:13 for A/M. r) Shyampur-Haripur 132 kV Ckt tripped at 10:35 showing no relay and was switched on at 11:09. s) Shyampur 132/33 kV T3 & T4 transformers tripped at 10:35 showing O/C relay and were switched on at 11:10. About 65 MW power interruption occurred under Shympur S/S areas from 10:35 to 11:09. t) After maintenance Ashuganj Unit-5 was synchronized at 12:40. u) Barisal 132/33 kV T1 transformer was under shut down from 11:40 to 12:15 for compressor maintenance work. v) Hasnabad 230 kV bay-2 was under shut down from 08:16 to 12:58 at Haripur end for A/M. w) My mensingh-Jamalpur 132 kV Ckt was under shut down from 10:52 to 13:45 for bus maintenance work at Jamalpur end x) Kulaura 132/33 kV T2 transformer tripped at 15:07 operating PRD and was switched on at 18:08. y) Siddhirganj GT-1 was synchronized at 16:58. z) After maintenance Ashuganj Unit-3 was synchronized at 21:48. aa) Ghorasal ST Unit-3 tripped at 23:18 showing stator cooling problem ab) Patuakhali 132/33 kV T1 transformer was shut down since 07:05 (07/11/2016) for A/M. ac) Siraigani 132/33 kV T4 transformer was, shut down since 07:16 (07/11/2016) for A/M ad) Bogra 132/33 kV T2 transformer was under shut down at 07:30(07/11/2016) for A/M. ae) Bibiyana-Comilla(N) 230 kV Ckt-T2 is under shut down at 06:06(07/11/2016) for development work Superintendent Engineer Sub Divisional Engineer Executive Engineer Network Operation Division Network Operation Division Load Dispatch Circle