POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 10-Nov-16 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yester Today's Actual Min Gen. & Probable Gen. & Demand 9-Nov-16 Generation & Demand Hour 12:00 Evening Peak Generation 133.0 MW Hour 18:00 Max Generation 9004 Hour E.P. Demand (at gen end) 7630.0 18:00 Max Demand (Evening) 7900 Maximum Generation 7630.0 MW Hour 18:00 Reserve (Generation end) 1104 Total Gen. (MKWH) System L/ Factor Load Shed 141.3 77.14% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 7.867 Export from East grid to West grid :- Maximum 46 MM at 12:00 Energy Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 10-Nov-16 Ft.(MSL) 108.10 Actual: 105.80 Ft.(MSL) Rule curve : Gas Consumed: Total 880.24 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (F Gas Tk64.868.116 Coal Tk12.382.503 Oil : Tk217,868,541 Total: Tk295,119,160 Load Shedding & Other Information Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) 0:00 Chittagong Area 0 0:00 832 Khulna Area 0:00 Raishahi Area 0 0.00 810 0 0:00 Comilla Area 616 Mymensingh Are 0 0.00 469 Sylhet Area 0 0:00 295 Rarisal Area 0 0:00 164 Rangpur Area 0 0:00 455 Total 7454 0 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(10) Chandpur CCPP ST 2) Kaptai Unit-5 11) Tongi GT 3) Ashuganj ST: Unit- 1 12) Chittagong ST Unit-2 4) Khulna ST 110 MW (04/11/2014 13) Ghorasal Unit-3 5) Ghorasal Unit-5 14) DPA Pagla 50 MW 6) Baghabari 100 MW 7) Haripur SBU GT- 3 8) Ashugonj CCPP South 9) Ghorasal Unit-4 (13/10/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) AKSML-BSRM 230 kV Ckt was under shut down from 08:59 to 23:21 for A/M. b) Bakulia-Khulshi 132 kV Ckt-1 was under shut down from 08:34 to 15:01 for A/M. c) Madunaghat-Sikalbaha 132 kV Ckt was under shut down from 07:53 to 16:07 for A/M. d) Feni-Chow muhoni 132 kV Ckt was under shut down from 10:08 to 19:53 for A/M. e) Tongi 230/132 kV T01 transformer was under shut down from 09:10 to 15:56 for A/M. f) Haripur-Rampura 230 kV Ckt-1 was under shut down from 08:17 to 15:35 for A/M. g) Siddhirganj-Dutchbangla 132 kV Ckt and associated bay was under shut down from 09:36 to 16:39 for A/M. h) Shonargaon 132/33 kV T1 transformer was under shut down from 07:40 to 15:36 for A/M. i) Jamalpur-Sherpur 132 kV Ckt-1 was under shut down from 08:21 to 15:38 for A/M. j) Mymensingh-Jamalpur 132 kV Ckt-1 w as under shut down from 08:17 to 16:06 for A/M. k) Kallyanpur 132 kV main bus-2 was shut down at 10:00 for A/M. I) Aminbazar-Tongi 230 kV Ckt-2 was under shut down from 08:19 to 17:00 for A/M m) Hasnabad 132/33 kV T1 transformer was under shut down from 07:50 to 17:27 for A/M. n) Chattak 132/33 kV T3 transformer was under shut down from 08:45 to 16:55 for A/M. o) Fenchugani 132/33 kV T1 transformer was under shut down from 08:30 to 09:09 for A/M. p) Fenchuganj 132/33 kV T2 transformer w as under shut down from 09:13 to 14:06 for A/M. q) Uttara 132 kV reserve bus was under shut down from 09:00 to 14:30 for A/M. r) Bogra 230/132 kV T02 transformer was under shut down from 09:10 to 16:02 for A/M. s) Thakurgaon 132/33 kV T2 transformer was under shut down from 08:50 to 15:53 for A/M. t) Pabna-Ishurdi 132 kV Ckt was under shut down from 08:12 to 15:09 for A/M. u) Noapara 132/33 kV T1 transformer was under shut down from 08:57 to 14:55 for A/M. v) Khulna(S) 230/132 kV T01 auto transformer was under shut down from 08:58 to 16:44 for A/M. w) Madaripur 132/33 kV T3 transformer w as under shut down from 08:51 to 17:05 for A/M. x) Bheramara HVDC 20DF21 filter bank was shut down at 09:48 for A/M. y) Goalpara-NWPGCL 132 kV Ckt was under shut down from 07:38 to 16:38 for A/M. z) After maintenance Ghorasal ST Unit-5 was synchronized at 14:23. aa) Barapukuria ST Unit-1 was shut down at 14:45 due to super heater tube leakage. ab) Baghabari GT 71 MW tripped at 20:49 showing loss of frame and was synchronized at 21:28 and Again tripped at 00:03 due to same reason. ac) After maintenance Ghorasal ST Unit-1 was synchronized at 08:32. ad) Chow muhoni-Feni 132 kV Ckt-2 w as shut down since 00:50 (10/11/2016) for A/M. are) Khulna 225 MW CCPP ST was synchronized at 02:01 (10/11/2016). af) Patuakhali 132/33 kV T2 transformer w as shut down since 07:11 (10/11/2016). Sub Divisional Engineer Executive Engineer Superintendent Engineer Network Operation Division Network Operation Division Load Dispatch Circle