## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

DAILY REPORT

Till now the maximum generation is: -		9036 MW	21:00	Hrs on 30-Jun-1	6	
The Summary of Yester	d: 1-Jan-17	Generation & Demand		Today's Actual Min Gen. & P	robable Gen. & Demand	
Day Peak Generation	: 5518.0	MW	10:00	Min. Gen. at 4:00	4169	
Evening Peak Generation :	7294.0	MW	19:00	Max Generation :	9269	
E.P. Demand (at gen end)	7294.0	MW	19:00	Max Demand (Evening):	7400	
Maximum Generation	7294.0	MW	19:00	Reserve (Generation end)	1869	
Total Gen. (MKWH)	: 131.4	System L/ Factor :	75.07%	Load Shed :	0	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR						

Export from East grid to West grid :- Maximum -360 MW at 15:00 Energy 7.867 Import from West grid to East grid :- Maximum MW Energy

Water Level of Kaptai Lake at 2-Jan-17

102.81 Ft.(MSL) Actual 100.96 Ft.(MSL) Rule curve :

874.31 MMCFD. Oil Consumed (PDB): Gas Consumed: Total

HSD FO

Reporting Date:

2-.lan-17

Tk63,198,040 Cost of the Consumed Fuel (F Gas

Tk7,812,303 : Tk175,869,985 Total: Tk246,880,327

## Load Shedding & Other Information

Area	Y	esterday	Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	2721	-	-
Chittagong Area	0	0:00	761	-	-
Khulna Area	0	0:00	755	-	-
Rajshahi Area	0	0:00	737	-	=
Comilla Area	0	0:00	567	-	-
Mymensingh Area	0	0:00	432	-	=
Sylhet Area	0	0:00	265	-	-
Barisal Area	0	0:00	151	-	=
Rangpur Area	0	0:00	417	-	-
Total	0	•	6806	0	

Information of the Generating Units under shut down.

1) Ghorasal ST: Unit-6 (18/07/2010 10) Ghorasal Unit- 2 Nil 2) Kaptai Unit-2 & 5 11) Sylhet 150 MW GT 3) Ashuganj ST: Unit- 1 12) Sikalbaha Peaking GT 4) Khulna ST 110 MW (04/11/2014 13) Skabbaha ST	Planned Shut- Down	Forced Shut-Down	
3) Ashuganj ST: Unit- 1 12) Sikalbaha Peaking GT 4) Khulna ST 110 MW (04/11/201413) Sikalbaha ST		1) Ghorasal ST: Unit-6 (18/07/201010) Ghorasal Unit-2	
4) Khulna ST 110 MW (04/11/201413) Sikalbaha ST	Nil	2) Kaptai Unit-2 & 5 11) Sylhet 150 MW GT	
, , ,		3) Ashuganj ST: Unit- 1 12) Sikalbaha Peaking GT	
E) Chargood Unit E 14) Chahiihazar/Enargy prima)		4) Khulna ST 110 MW (04/11/2014 13) Sikalbaha ST	
5) Gnorasai Unit-5 14) Snanjibazar(Energyprima)		5) Ghorasal Unit-5 14) Shahjibazar(Energyprima)	
6) Baghabari 100 MW 15) Shahjibazar GT: Unit- 8, 9		6) Baghabari 100 MW 15) Shahjibazar GT: Unit- 8, 9	
7) Haripur SBU GT- 2,3 16) Barapukuria ST: Unit-2		7) Haripur SBU GT- 2,3 16) Barapukuria ST: Unit-2	
8) Fenchugonj CCPP-2 17) Santahar Peaking		8) Fenchugonj CCPP-2 17) Santahar Peaking	
9) Chittagong Unit-1		9) Chittagong Unit-1	

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	
) December 11-th and 3 400 13 / Old 4	

- a) Baraulia-Hathazari 132 kV Ckt-1 was under shut down from 08:58 to 12:57 for A/M.
- b) Dohazari-Cox's bazar 132 kV Ckt-1 was under shut down from 08:35 to 16:58 for A/M.
- c) Tongi-Uttara 132 kV Ckt was under shut down from 09:05 to 16:02 for A/M.
- d) Rampura-Ghorasal 132 kV Ckt-1 was under shut down from 09:06 to 13:59 for A/M.
- e) Mymensingh-Netrokona 132 kV Ckt-1 was under shut down from 08:07 to 16:20 for A/M.
- f) Meghnaghat-Hasnabad 230 kV Ckt-1 was under shut down from 08:20 to 16:20 for A/M.
- g) Fenchuganj P/S-Fenchuganj S/S 132 kV Ckt-2 was under shut down from 09:02 to 13:24 for A/M.
- h) Fenchuganj P/S-Sylhet S/S 132 kV Ckt was under shut down from 08:45 to 14:52 for A/M.
- i) After maintenance Ghorasal ST Unit-1 was synchronized at 11:55.
- j) Hathazari 230 kV breaker no 808 was under shut down from 11:50 to 12:34 due to problem with hydraulic pressure pump.
- k) Shahjadpur- All 132 kV lines and all transformers were shut down from 14:16 to 16:5 About 15 MW power interruption occurred under Shahjadpur S/S areas system failure at Shahjadpur end. from 11:50 to 12:34.
- l) Haripur-Ullon 132 kV Ckt tripped at 14:36 from Haripur end showing dist Z3 ,Z4 B-phase and was switched on at 14:51.
- m) Mymensingh-Netrokona 132 kV Ckt-2 tripped at 15:41 from both end showing inst E/F at Mymensing end
- & directional O/C at Netrokona end and it is under maintenance.

Sub Divisional Engineer **Network Operation Division** 

**Executive Engineer Network Operation Division** 

Superintendent Engineer Load Dispatch Circle

**Comments on Power Interruption**